


**ALLIANT ENERGY
Wisconsin Power and Light Company
Edgewater Generating Station**

CCR SURFACE IMPOUNDMENT

SAFETY FACTOR ASSESSMENT

Report Issued: September 21, 2016
Revision 0



EXECUTIVE SUMMARY

This Safety Factor Assessment (Report) is prepared in accordance with the requirements of the United States Environmental Protection Agency (USEPA) published Final Rule for Hazardous and Solid Waste Management System – Disposal of Coal Combustion Residual (CCR) from Electric Utilities (40 CFR Parts 257 and 261, also known as the CCR Rule) published on April 17, 2015 and effective October 19, 2015.

This Report assesses the safety factors of each CCR unit at Edgewater Generating Station in Sheboygan, WI in accordance with §257.73(b) and §257.73(e) of the CCR Rule. For purposes of this Report, “CCR unit” refers to existing CCR surface impoundments.

Primarily, this Report is focused on assessing if each CCR surface impoundment achieves the minimum safety factors, which include:

- Static factor of safety under long-term, maximum storage pool loading condition,
- Static factor of safety under the maximum surcharge pool loading condition,
- Seismic factor of safety; and,
- Post-Liquefaction factor of safety for embankments constructed of soils that have susceptibility to liquefaction.



Table of Contents

1	INTRODUCTION	1
1.1	CCR Rule Applicability	1
1.2	Safety Factor Assessment Applicability	1
2	FACILITY DESCRIPTION	2
2.1	EDG Slag Pond	3
2.2	EDG North A-Pond.....	3
2.3	EDG South A-Pond	4
2.4	EDG B-Pond.....	5
3	SAFETY FACTOR ASSESSMENT- §257.73(e).....	7
3.1	Safety Factor Assessment Methods	7
3.1.1	Soil Conditions in and under the impoundments	8
3.1.2	Design water surface in impoundments maximum normal pool and maximum pool under design inflow storm	9
3.1.3	Selection of Seismic Design Parameters and Description of Method.....	9
3.1.4	Liquefaction Assessment Method and Parameters	10
3.2	EDG Slag Pond	11
3.2.1	Static Safety Factor Assessment Under Maximum Storage Pool Loading - §257.73(e)(1)(i)	11
3.2.2	Static Safety Factor Assessment Under Maximum Surge Pool Loading - §257.73(e)(1)(ii)	11
3.2.3	Seismic Safety Factor Assessment - §257.73(e)(1)(iii).....	12
3.2.4	Liquefaction Safety Factor Assessment - §257.73(e)(1)(iv).....	12
3.3	EDG North A-Pond.....	12
3.3.1	Static Safety Factor Assessment Under Maximum Storage Pool Loading - §257.73(e)(1)(i)	12
3.3.2	Static Safety Factor Assessment Under Maximum Surge Pool Loading - §257.73(e)(1)(ii)	13
3.3.3	Seismic Safety Factor Assessment - §257.73(e)(1)(iii).....	13
3.3.4	Liquefaction Safety Factor Assessment - §257.73(e)(1)(iv).....	13
3.4	EDG South A-Pond	13
3.4.1	Static Safety Factor Assessment Under Maximum Storage Pool Loading - §257.73(e)(1)(i)	14
3.4.2	Static Safety Factor Assessment Under Maximum Surge Pool Loading - §257.73(e)(1)(ii)	14
3.4.3	Seismic Safety Factor Assessment - §257.73(e)(1)(iii).....	14
3.4.4	Liquefaction Safety Factor Assessment - §257.73(e)(1)(iv).....	14
3.5	EDG B-Pond.....	15
3.5.1	Static Safety Factor Assessment Under Maximum Storage Pool Loading - §257.73(e)(1)(i)	15
3.5.2	Static Safety Factor Assessment Under Maximum Surge Pool Loading - §257.73(e)(1)(ii)	15
3.5.3	Seismic Safety Factor Assessment - §257.73(e)(1)(iii).....	15
3.5.4	Liquefaction Safety Factor Assessment - §257.73(e)(1)(iv).....	16



4	RESULTS SUMMARY	17
5	QUALIFIED PROFESSIONAL ENGINEER CERTIFICATION	18

Figures

- Figure 1:** Site Location
- Figure 2:** Soil Boring and Cross-Section Locations
- Figure 3:** Analysis Cross-Sections EDG B-Pond and EDG South A-Pond
- Figure 4:** Analysis Cross-Sections EDG North A-Pond and EDG Slag Pond
- Figure 5:** Cross-Sections at Borings R and Q (Deep borings showing silt layer)

Appendices

- Appendix A:** Soil Boring Logs
- Appendix B:** Soil Strength Properties
- Appendix C:** Earthquake and Liquefaction Analysis
- Appendix D:** Slope Stability Analysis



1 INTRODUCTION

The owner or operator of the Coal Combustion Residual (CCR) unit must conduct an initial and periodic safety factor assessments to determine if each CCR surface impoundment achieves the minimum safety factors, which include:

- Static factor of safety under long-term, maximum storage pool loading condition,
- Static factor of safety under the maximum surcharge pool loading condition,
- Seismic factor of safety; and,
- Post-Liquefaction factor of safety for embankments constructed of soils that have susceptibility to liquefaction.

This Report has been prepared in accordance with the requirements of §257.73(b) and §257.73(e) of the CCR Rule.

1.1 CCR Rule Applicability

The CCR Rule requires a periodic safety factor assessment by a qualified professional engineer (PE) for existing CCR surface impoundments with a height of 5 feet or more and a storage volume of 20 acre-feet or more; or the existing CCR surface impoundment has a height of 20 feet or more.

1.2 Safety Factor Assessment Applicability

The Edgewater Generating Station (EDG) in Sheboygan, WI (Figure 1) has four existing CCR surface impoundments, identified as follows:

- EDG Slag Pond
- EDG North A-Pond
- EDG South A-Pond
- EDG B-Pond

Each of the identified existing CCR surface impoundments meet the requirements of §257.73(b)(1) and/or §257.73(b)(2), they are subject to the periodic safety factor assessment requirements of §257.73(e) of the CCR Rule.



2 FACILITY DESCRIPTION

EDG is located on the south edge of the City of Sheboygan, Wisconsin along the western shore of Lake Michigan in Sheboygan County, at 3739 Lakeshore Drive, Sheboygan, Wisconsin (Figure 1).

EDG is a fossil-fueled electric generating station that initiated operations in 1930. EDG consists of two steam electric generating units (Unit 4 and Unit 5). A third steam electric generating unit (Unit 3) was removed from service in 2015. Sub-bituminous coal is the primary fuel used at EDG for producing steam. The burning of coal produces CCR byproducts. The CCR at EDG is categorized into five types: precipitator fly ash, slag, bottom ash, economizer ash, and scrubber byproducts.

The Unit 4 precipitator fly ash is collected by Unit 4's electrostatic precipitators and sent to an on-site storage silo located southwest of the generating plant. The precipitator fly ash is then transported off-site for either beneficial reuse or for disposal at the EDG I-43 CCR landfill. The Unit 5 precipitator fly ash is collected by Unit 5's electrostatic precipitators and sent to a separate on-site storage silo located southwest of the generating plant. Unit 5's precipitator fly ash is then transported off-site for beneficial reuse or for disposal at the EDG I-43 CCR landfill..

The slag at EDG is produced from Unit 4 and is sluiced from the generating plant to a surface impoundment identified as the EDG Slag Pond (Figure 2). The EDG Slag Pond is located southwest of the generating plant.

Byproducts from the circulating dry scrubber (CDS) system are transported offsite for disposal at the EDG I-43 CCR Landfill.

General Facility Information:

Date of Initial Facility Operations:	1930
WPDES Permit Number:	WI-0001589-07-0
Latitude / Longitude:	43.716153, -87.706262



Nameplate Ratings:	Unit 1 (Retired)
	Unit 2 (Retired)
	Unit 3 (Retired)
	Unit 4 351 MW
	Unit 5 414 MW

2.1 EDG Slag Pond

The EDG Slag Pond is located southwest of the generating plant and north of the EDG North A-Pond. The EDG Slag Pond receives influent flow from the generating plant via the Unit 4 boiler slag tanks. The water-slag slurry discharges into the southwest portion of the EDG Slag Pond. The slag is dredged out of the EDG Slag Pond and stockpiled in a containerized area adjacent to the existing CCR surface impoundment for dewatering. The slag is then screened to separate the coarsely graded material from the finely graded material prior to being transported off-site for beneficial reuse. The water in the EDG Slag Pond flows to the southwest where it gravity flows through a V-notch weir and through a four feet wide concrete structure into a 48-inch diameter corrugated metal pipe. The water from the EDG Slag Pond, which combines with flows from the EDG North A-Pond and EDG South A-Pond in the 48-inch diameter corrugated metal pipe, flows to the south into the northwest corner of the EDG B-Pond.

The surface area of the EDG Slag Pond is approximately 2.2 acres and has an embankment height of approximately 12 feet from the crest to the toe of the downstream slope. The interior storage depth of the EDG Slag Pond is approximately 17 feet. The total volume of impounded CCR and water within the EDG Slag Pond is approximately 47,000 cubic yards.

2.2 EDG North A-Pond

The EDG North A-Pond is located southwest of the generating plant and south of the EDG Slag Pond. Historically, the EDG North A-Pond has received influent flows from the surge tank. Water in the surge tank includes excess process water from the Unit 5 hydrobin, steam water treatment reject water, and water from the facility floor drains. Therefore, the EDG North A-Pond has likely received residual bottom ash from the



hydrobin system, de minimis quantities of fly ash from routine maintenance operations, coal fines, and other materials from the plant floor drains. The water was pumped from the surge tank to the EDG North A-Pond via a 10-inch diameter steel pipe. The steel pipe, at a location northeast of the EDG North A-Pond, splits into two separate 10-inch diameter pipes. Each pipe then discharged into the northeast corner of both the EDG North A-Pond and EDG South A-Pond. Currently, EDG North A-Pond does not receive operational process discharges from the generating plant, although it still has the ability to be routed to the EDG North A-Pond.

Previously, water within the EDG North A-Pond flowed to the west. The EDG North A-Pond discharge consists of an 18-inch diameter corrugated plastic pipe located in the southwest corner of the existing CCR surface impoundment. The water would flow through the corrugated plastic pipe to the west into a concrete sluice box. The water within the sluice box flows through a Parshall flume prior to discharging into a 48-inch diameter corrugated metal pipe, which also receives influent flow from the EDG Slag Pond and EDG South A-Pond, prior to gravity flowing to the south into the northwest corner of the EDG B-Pond. Presently, no water within the EDG North A-Pond discharges through the 18-inch diameter corrugated plastic pipe as the pipe has been plugged.

The surface area of the EDG North A-Pond is approximately 2.2 acres and has an embankment height of approximately 18 feet from the crest to the toe of the downstream slope. The interior storage depth of the EDG Secondary Ash Pond is approximately 21 feet. The total volume of impounded CCR and water within the EDG North A-Pond is approximately 73,000 cubic yards.

2.3 EDG South A-Pond

The EDG South A-Pond is located southwest of the generating plant and south of the EDG North A-Pond. As currently configured, the EDG South A-Pond receives influent flows from the surge tank. Water in the surge tank includes excess process water from the Unit 5 hydrobin, steam water treatment reject water, and water from the facility floor



drains. Therefore, the EDG North A-Pond has likely received residual bottom ash from the hydrobin system, de minimis quantities of fly ash from routine maintenance operations, coal fines, and other materials from the plant floor drains. The water is pumped from the surge tank to the EDG South A-Pond via a 10-inch diameter steel pipe. The steel pipe, at a location northeast of the EDG North A-Pond, splits into two separate 10-inch diameter pipes. Each pipe then discharges into the northeast corner of both the EDG North A-Pond and EDG South A-Pond. Note, the EDG North A-Pond no longer receives operational process flows from the generating plant.

The water within the EDG South A-Pond flows to the west. The EDG South A-Pond consists of an 18-inch diameter corrugated plastic pipe located in the northwest corner of the existing CCR surface impoundment. The water flows through the corrugated plastic pipe to the west into a concrete sluice box. The water within the sluice box flows through a Parshall flume prior to discharging into a 48-inch diameter corrugated metal pipe, which also receives influent flow from the EDG Slag Pond, prior to gravity flowing to the south into the northwest corner of the EDG B-Pond.

The surface area of the EDG South A-Pond is approximately 2.2 acres and has an embankment height of approximately 18 feet from the crest to the toe of the downstream slope. The interior storage depth of the EDG South A-Pond is approximately 25 feet. The total volume of impounded CCR and water within the EDG South A-Pond is approximately 90,500 cubic yards.

2.4 EDG B-Pond

The EDG B-Pond is located southwest of the generating plant and south of the EDG South A-Pond. The EDG B-Pond receives influent flow via a 48-inch diameter corrugated metal pipe from the EDG Slag Pond and EDG South A-Pond. Additionally, the EDG B-Pond receives storm water drainage from a part of the closed ash landfill west of the EDG B-Pond. The storm water from the closed ash landfill discharges into the west side of the EDG B-Pond via a small corrugated plastic pipe.



The water in the EDG B-Pond flows to the east through an overflow weir wet well structure, Figure 2. The elevated weir prevents CCR that has settled in the EDG B-Pond from flowing out of the impoundment. The water gravity flows to the east through a 24-inch diameter corrugated metal pipe where it discharges into the west side of the EDG C-Pond. The water in the EDG C-Pond gravity flows to the east into the EDG F-Pond. The water in the EDG F-Pond flows through the facility's Wisconsin Pollution Discharge Elimination System (WPDES) Outfall 004 and discharges into Lake Michigan. As determined by WPL, process water discharging from the EDG B-Pond does not contain a significant quantity of CCR, and downstream impoundments contain only de minimis quantities of CCR.

The water surface area of the EDG B-Pond is approximately 1.9 acres and has an embankment height of approximately 24 feet from the crest to the toe of the downstream slope in EDG C-Pond. The interior storage depth of the EDG B-Pond is approximately 15 feet. The total volume of impounded CCR and water within the EDG B-Pond is approximately 46,500 cubic yards.



3 SAFETY FACTOR ASSESSMENT- §257.73(e)

This Report documents if each CCR surface impoundment achieves the minimum safety factors, which are identified on the table below.

Safety Factor Assessment	Minimum Safety Factor
Static Safety Factor Under Maximum Storage Pool Loading	1.50
Static Safety Factor Under Maximum Surcharge Pool Loading	1.40
Seismic Safety Factor	1.00
Liquefaction Safety Factor	1.20

3.1 Safety Factor Assessment Methods

The safety factor assessment is completed with the two dimensional limit-equilibrium slope stability analyses program STABL5M (1996)¹. The program analyzes many potential failure circles or block slides by random generation of failure surfaces using the toe and crest search boundaries set for each analysis. The solution occurs by balancing the resisting forces along the failure plane due to the Mohr-Columb failure strength parameters of friction angle and cohesion. The gravity driving forces are divided by the resisting forces to produce a safety factor for the slope. The minimum of hundreds of searches is presented as the applicable safety factor.

There are both total stress and effective stress friction angle and cohesion values for clay. For the total stress case clay has only cohesion. For effective stress clay has both cohesion and friction angle. When clay receives a load that is applied only briefly (i.e., earthquake or high water), it responds as a total stress soil. For long term loadings such as normal water elevation, the clay resistance to failure is based on effective stress parameters. Because effective stress clay parameters are not readily available from the soil testing and because the total stress parameters for compacted and over consolidated clay yield a

¹ STABL User Manual by Ronald A. Siegal, Purdue University, June 4, 1975 and STABL5 – The Spencer Method of Slices: Final Report by J. R. Carpenter, Purdue University, August 28, 1985
Wisconsin Power and Light Company – Edgewater Generating Station
Safety Factor Assessment
September 21, 2016



conservative answer for safety factor, the static analysis with normal operating water elevation is performed with the total stress parameters for the clay components in the embankments.

3.1.1 Soil Conditions in and under the impoundments

In December of 2010, Miller Engineers and Scientists installed thirteen soil borings through the embankments of the EDG CCR impoundments. The locations of the borings and cross-sections of the embankments are shown on Figures 2 through 5. The topography of the embankments was also determined in late 2010. Since no substantial changes have occurred at the EDG CCR impoundments since 2010, the 2010 investigative results combined with the present impoundment operating conditions (normal water elevations) are used in the stability analysis.

The soil boring logs, Appendix A, indicate that the embankments of the EDG CCR impoundments are constructed of very stiff to stiff compacted clay (CL). The embankment foundation is medium dense to very loose silt starting at elevation 586 feet and extending to a medium stiff clay at an elevation of 560 to 569 feet, Borings E, Q, and R in Appendix A. The borings on other cross-sections are not as deep but generally show the same subsurface layers with the exception of borings on the south incised slope of the impoundments which indicate the presence of CCR in the slope.

The properties of the clay in the embankment and the deeper natural clays used in the stability assessment are based on the pocket penetrometer readings shown on the boring logs. The cohesion values range from 1,500 to 4,000 psf.

The internal angle of friction for the medium dense to very loose silt layer under the embankment is selected based on Figure 3-7 Navfac DM-7, Appendix B². The internal friction angle is 27° where the silt is very loose to 30° where the silt is medium dense.

² Naval Facilities Engineering Command, “Design Manual Soil Mechanics, Foundations, and Earth Structures”, NAVFAC DM-7, March 1971



The upper layer of the embankment for the EDG South A-Pond is dense bottom ash a coarse grained soil and is assigned an internal angle of friction of 37°. Loose saturated CCR behind the embankments is assigned an internal angle of friction of 27° the same as for the very loose silt foundation layer.

3.1.2 Design water surface in impoundments maximum normal pool and maximum pool under design inflow storm

The EDG CCR impoundments each have specific functions in the handling of process water from the EDG Plant. The Slag Pond is the settling basin for the coarse slag from the Unit 4 boiler, EDG South A-Pond is the settling basin for various sumps and boiler feed water conditioning reject, and EDG B-Pond is the final settling basin for the fines that do not get deposited in the other impoundments. The total process water flow from the plant is 4.8 MGD. In addition each impoundment does accept a small watershed area from the slope to the south of the impoundments on the closed landfill site.

The process water flows and the rainfall from a 1,000 year Type II SCS storm distribution are routed through the impoundments to create a maximum pool for each impoundment during the design storm. The normal operating flows in 2016 and the maximum storm pool are:

CCR Pond	Normal Pool Water Elevation (feet)	Maximum Pool Elevation (feet)	Embankment Crest Elevation (feet)
EDG Slag pond	606.6	607.5	609.7
EDG North A-Pond	607	609.1	611.8
EDG South A-Pond	609.2	610.0	611.9
EDG B-Pond	599.0	599.9	607.9

3.1.3 Selection of Seismic Design Parameters and Description of Method

The design earthquake ground acceleration is selected from the United States Geologic Survey (USGS) detailed seismic design maps based on the latitude and longitude of the EDG. The peak ground acceleration (PGA) value is selected for a 2% probability of exceedance in 50 years (2,500 year return period) as required by § 257.53. Since the site soils are clay with cohesion greater than 1,000 psf, excepting the silt layer, and extend to



bedrock at 130 feet³, the site class as defined in the 2009 International Building Code 1613.5.5 is Site Class D. For Site Class D the ground surface PGA for slope stability and liquefaction assessment is 0.05g, Appendix C.

3.1.4 Liquefaction Assessment Method and Parameters

Certain soils may have zero effective stress (liquefaction) during an earthquake or from static shear of a saturated embankment slope. Soils that will liquefy include loose or very loose uniform fine sand or silt, and low plasticity clay (plastic index of less than 12). The liquefaction resistance of a soil is based on its strength and effective confining stress. The strength of the saturated silt is measured by the SPT results shown on the borings in Appendix A. Some of the site clay has plastic index less than 12 as shown on Figures 3 through 5. However the clay is stiff or very stiff and not subject to liquefaction.

The test results for Boring E located on the north embankment of EDG B-Pond, Figure 2 at the highest embankment height and with the lowest silt strength measured indicate the silt is very loose (SPT blowcount less than 5 blows per foot).

The simplified assessment of liquefaction procedure as first proposed by Seed and most recently updated and published by Idriss and Boulanger⁴ is used to assess the potential for liquefaction of the silt. The procedure uses the strengths determined by the SPT test adjusted to normalize for overburden pressure and for fines content to determine the cyclic resistance ratio for the soil at earthquake magnitude 7.5 and at 1 atmosphere pressure. The cyclic resistance ratio is then adjusted for the actual earthquake magnitude of the design event which is 7.7 for a New Madrid Fault source earthquake⁵. The cyclic stress ratio caused by the design surface PGA is then used to determine the actual cyclic

³ Ground water well records on file with the State of Wisconsin for area near EDG

⁴ Idriss I. M. and R. W. Boulanger, "Soil Liquefaction During Earthquakes", EERI MNO-12, 2008.

⁵ Elnashi et al, "Impact of Earthquakes on the Central USA", FEMA Report 8-02, Mid-American Earthquake Center, 2002



stress ratio at 65% of maximum strain at depth in the soil profile. The cyclic resistance ratio is divided by the cyclic stress ratio to determine the factor of safety for liquefaction.

The results for the soil profile of Boring E at the north end of the west embankment of the EDG B-Pond are shown in Appendix C. The results indicate the silt layer will not liquefy during the site design earthquake.

3.2 EDG Slag Pond

The critical EDG Slag Pond cross-section analyzed for slope stability is cross-section P-P', Figure 2. The section is the north slope of the EDG Slag Pond and is more critical than the slightly higher East slope due to the proximity of the pond water surface to the crest of the slope. The cross-section is shown on Figure 4 and does not include the foundation soil below the recorded impoundment bottom. For analysis, the soil profile was extended using the results of the deeper borings Q and R, Figure 5, to include the loose silt and deeper medium stiff clay foundation soils.

3.2.1 Static Safety Factor Assessment Under Maximum Storage Pool Loading - §257.73(e)(1)(i)

The EDG Slag Pond receives 3.7 cubic feet per second of average process water flow from sluicing of bottom slag from Boiler 4. The process flow maintains a maximum average storage pool of 606.6 feet in the impoundment. Analysis of both circular and block sliding surfaces, Appendix D, show a minimum factor of safety of 8.6 for the circular failure surface passing through the foundation soil.

3.2.2 Static Safety Factor Assessment Under Maximum Surcharge Pool Loading - §257.73(e)(1)(ii)

The EDG Slag Pond will contain the 1,000 year return period design storm through a combination of storage in the impoundment and discharge to the EDG B-Pond. The maximum surcharge pool elevation is 607.5 at the peak of the storm. Analysis for both circular and block sliding surface, Appendix D, show a minimum factor of safety of 8.5 for the circular surface passing through the foundation soil.



3.2.3 Seismic Safety Factor Assessment - §257.73(e)(1)(iii)

The EDG Slag Pond was assigned a pseudo-static earthquake coefficient equal to 0.05 g acceleration and a vertical downward component equal to $2/3$ of the horizontal component (0.03 g) as recommended by Newmark⁶. Analysis for both a circular and block sliding surface, Appendix D, show a minimum factor of safety of 5.9 for the circular sliding surface through the foundation soil.

3.2.4 Liquefaction Safety Factor Assessment - §257.73(e)(1)(iv)

The EDG Slag Pond foundation soil (very loose to loose silt) is susceptible to liquefaction. An analysis of liquefaction potential, Section 3.1.4, shows that the design earthquake does not cause liquefaction and no post-liquefaction stability analysis is required.

3.3 EDG North A-Pond

The critical EDG North A-Pond cross-section analyzed for slope stability is cross-section N-N', Figure 2. The section is the East slope of the EDG North A-Pond and is the only outside embankment slope for the impoundment. The cross-section is shown on Figure 4 and does not include the foundation soil below the recorded impoundment bottom. For analysis, the soil profile was extended using the results of the deeper borings Q and R, Figure 5, to include the loose silt and deeper medium stiff clay foundation soils.

3.3.1 Static Safety Factor Assessment Under Maximum Storage Pool Loading - §257.73(e)(1)(i)

The EDG North A-Pond is a zero-discharge pond that no longer receives process water flow. In addition, the outlet of the North A-Pond is blocked to prevent discharge of ponded water to EDG B-Pond. The normal water elevation in the impoundment due to exfiltration loss and evaporation is elevation 607 feet. Analysis of both circular and block sliding surfaces, Appendix D, show a minimum factor of safety of 3.7 for the circular failure surface passing through the foundation soil.

⁶ Newmark, N. M. and W. J. Hall, "Earthquake Spectra and Design", EERI Monograph, Earthquake Engineering Research Institute, Berkeley, California, 1982



3.3.2 Static Safety Factor Assessment Under Maximum Surcharge Pool Loading - §257.73(e)(1)(ii)

The EDG North A-Pond will contain the 1,000 year return period design storm through storage in the impoundment without discharge. The maximum surcharge pool elevation is 609.1 at the peak of the storm. Analysis for both circular and block sliding surface, Appendix D, show a minimum factor of safety of 3.6 for the circular surface passing through the foundation soil.

3.3.3 Seismic Safety Factor Assessment - §257.73(e)(1)(iii)

The EDG North A-Pond was assigned a pseudo-static earthquake coefficient equal to 0.05 g acceleration and a vertical downward component equal to $\frac{2}{3}$ of the horizontal component (0.03 g) as recommended by Newmark⁷. Analysis for both a circular and block sliding surface, Appendix D, show a minimum factor of safety of 2.8 for the circular sliding surface through the foundation soil.

3.3.4 Liquefaction Safety Factor Assessment - §257.73(e)(1)(iv)

The EDG North A-Pond foundation soil (very loose to loose silt) is susceptible to liquefaction. An analysis of liquefaction potential, Section 3.1.4, shows that the design earthquake does not cause liquefaction and no post-liquefaction stability analysis is required.

3.4 EDG South A-Pond

The critical EDG South A-Pond cross-section analyzed for slope stability is cross-section I-I', Figure 2. The section is the Southeast corner slope of the EDG South A-Pond and is more critical than Section R-R' due to its overall height and the toe of the slope being in EDG C-Pond. The cross-section is shown on Figure 3 and does not include the complete depth of the foundation soil below the recorded impoundment bottom. For analysis, the soil profile was extended using the results of the deeper borings Q and R, Figure 5 to include the deeper medium stiff clay foundation soils below the loose silt.

⁷ Newmark, N. M. and W. J. Hall, "Earthquake Spectra and Design", EERI Monograph, Earthquake Engineering Research Institute, Berkeley, California, 1982
Wisconsin Power and Light Company – Edgewater Generating Station
Safety Factor Assessment
September 21, 2016



3.4.1 Static Safety Factor Assessment Under Maximum Storage Pool Loading - §257.73(e)(1)(i)

The EDG South A-Pond receives 3.7 cubic feet per second of average process water flow from plant sumps and reject treatment water. The process flow maintains a maximum average storage pool of 609.2 feet in the impoundment. Analysis of both circular and block sliding surfaces, Appendix D, show a minimum factor of safety of 2.3 for the circular failure surface passing through the foundation soil.

3.4.2 Static Safety Factor Assessment Under Maximum Surge Pool Loading - §257.73(e)(1)(ii)

The EDG South A-Pond will contain the 1,000 year return period design storm through a combination of storage in the impoundment and discharge to the EDG B-Pond. The maximum surge pool elevation is 610.0 at the peak of the storm. Analysis for both circular and block sliding surface, Appendix D, show a minimum factor of safety of 2.3 for the circular surface passing through the foundation soil.

3.4.3 Seismic Safety Factor Assessment - §257.73(e)(1)(iii)

The EDG South A-Pond was assigned a pseudo-static earthquake coefficient equal to 0.05 g acceleration and a vertical downward component equal to $2/3$ of the horizontal component (0.03 g) as recommended by Newmark⁸. Analysis for both a circular and block sliding surface, Appendix D, show a minimum factor of safety of 1.7 for the circular sliding surface through the foundation soil.

3.4.4 Liquefaction Safety Factor Assessment - §257.73(e)(1)(iv)

The EDG South A-Pond foundation soil (very loose to loose silt) is susceptible to liquefaction. An analysis of liquefaction potential, Section 3.1.4, shows that the design earthquake does not cause liquefaction and no post-liquefaction stability analysis is required.

⁸ Newmark, N. M. and W. J. Hall, "Earthquake Spectra and Design", EERI Monograph, Earthquake Engineering Research Institute, Berkeley, California, 1982
Wisconsin Power and Light Company – Edgewater Generating Station
Safety Factor Assessment
September 21, 2016



3.5 EDG B-Pond

The critical EDG B-Pond cross-section analyzed for slope stability is cross-section E-E', Figure 2. The section is the East slope of the EDG B-Pond and is more critical than Section Q-Q' due to its overall height and the toe of the slope being in EDG C-Pond. The cross-section is shown on Figure 3. Since Boring E does not show a clay cohesion value for the clay below the loose silt layer, a value of 1,500 psf similar to Section I-I' was assigned to the foundation clay.

3.5.1 Static Safety Factor Assessment Under Maximum Storage Pool Loading - §257.73(e)(1)(i)

The EDG B-Pond receives 7.4 cubic feet per second of average process water flow from EDG Slag Pond and South A-Pond. The process flow is controlled by an overflow weir and maintains a maximum average storage pool of 599.0 feet in the impoundment. Analysis of both circular and block sliding surfaces, Appendix D, show a minimum factor of safety of 2.6 for the circular failure surface passing through the foundation soil.

3.5.2 Static Safety Factor Assessment Under Maximum Surge Pool Loading - §257.73(e)(1)(ii)

The EDG B-Pond will contain the 1000 year return period design storm through a combination of storage in the impoundment and discharge to the EDG C-Pond. The maximum surge pool elevation is 599.9 at the peak of the storm. Analysis for both circular and block sliding surface, Appendix D, show a minimum factor of safety of 2.7 for the circular surface passing through the foundation soil.

3.5.3 Seismic Safety Factor Assessment - §257.73(e)(1)(iii)

The EDG B-Pond was assigned a pseudo-static earthquake coefficient equal to 0.05 g acceleration and a vertical downward component equal to $\frac{2}{3}$ of the horizontal component (0.03 g) as recommended by Newmark⁹. Analysis for both a circular and

⁹ Newmark, N. M. and W. J. Hall, "Earthquake Spectra and Design", EERI Monograph, Earthquake Engineering Research Institute, Berkeley, California, 1982



block sliding surface, Appendix D, show a minimum factor of safety of 2.0 for the circular sliding surface through the foundation soil.

3.5.4 Liquefaction Safety Factor Assessment - §257.73(e)(1)(iv)

The EDG B-Pond foundation soil (very loose to loose silt) is susceptible to liquefaction. An analysis of liquefaction potential, Section 3.1.4, shows that the design earthquake does not cause liquefaction and no post-liquefaction stability analysis is required.



4 RESULTS SUMMARY

The results of the safety factor assessment indicate that the EDG embankments meet the requirements of § 257.73(e). The results are:

	Static Stability Normal Water Elevation	Static Stability Flood Water Elevation	Pseudo Static Earthquake with Normal Water Elevation	Liquefaction Potential	Post-Earthquake Static Stability Normal Water Elevation
Required Safety Factor	1.5	1.4	1.0		1.2
EDG Slag Pond	8.6	8.5	5.9	no	
EDG North A-Pond	3.7	3.6	2.8	no	
EDG South A-Pond	2.3	2.3	1.7	no	
EDG B-Pond	2.6	2.7	2.0	no	



5 QUALIFIED PROFESSIONAL ENGINEER CERTIFICATION

To meet the requirements of 40 CFR 257.73(e)(2), I Mark W. Loerop hereby certify that I am a licensed professional engineer in the State of Wisconsin; and that, to the best of my knowledge, all information contained in this document is correct and the document was prepared in compliance with all applicable requirements in 40 CFR 257.73(b) and 40 CFR 257.73(e).



By: 
Name: MARK LOEROP
Date: 10/5/2016



FIGURES

Alliant Energy
Wisconsin Power and Light Company
Edgewater Generating Station
Sheboygan, WI

Safety Factor Assessment




Historical Topo Map


2013



Historical Aerial Photo



This report includes information from the following map sheet(s).



TP, Sheboygan South, 2013, 7.5-minute

SITE NAME: Edgewater Generating Station
 ADDRESS: 3739 Lakeshore Drive
 Sheboygan, WI 53081
 CLIENT: Environmental Site Assessors



----- Approximate Property Boundary



Site Location
 Edgewater Generating Station
 Wisconsin Power and Light Company

Drawing
 Figure 1
 Date
 7/12/2016


MAP SOURCE:
 MODIFIED FROM MILLER ENGINEERS
 SCIENTISTS, ASH POND SLOPE STABILITY
 EVALUATION, IMPOUNDMENT ANALYSIS,
 SHEET 1 OF 5, FEB. 25, 2011.

LEGEND

- A 589.5 MILLER ENGINEERS & SCIENTISTS JANUARY AND FEBRUARY 2011 SOIL EXPLORATION BORINGS & GROUND ELEVATION MEASUREMENTS
- A A' BERM CROSS SECTION LOCATION



SITE LOCATION MAP



ELEVATIONS IN NGVD DATUM
 UNLESS NOTED OTHERWISE
 PLANT DATUM= NGVD+ 0.78'

NOTICE
 THIS DRAWING IS THE PROPERTY
 OF HARD HAT SERVICES AND IS
 NOT TO BE REPRODUCED,
 CHANGED, OR COPIED IN ANY FORM
 OR MANNER WITHOUT PRIOR
 WRITTEN PERMISSION. ALL RIGHTS
 RESERVED.

REV	DATE	BY	DESCRIPTION








SCALE: AS SHOWN
 DATE: 7-18-16
 DRAWN BY: JFD
 CHKD BY: MWL
 APRVD BY: TJH

CLIENT / LOCATION
 ALLIENT ENERGY
 EDGEWATER GENERATING STATION
 SHEBOYGAN WISCONSIN

DRAWING DESCRIPTION
 SAFETY FACTOR ASSESSMENT
 BORING AND CROSS-SECTION LOCATIONS

JOB 154.018.012.006
 SHT. FIGURE 2
 DWG. -----

MAP SOURCE:
 MODIFIED FROM MILLER ENGINEERS
 SCIENTISTS, ASH POND SLOPE STABILITY
 EVALUATION, IMPOUNDMENT ANALYSIS,
 SHEET 3 OF 5, FEB. 25, 2011.




LEGEND

SOIL LAYER BOUNDARY USED IN STABILITY ANALYSIS

N= SPT BLOW COUNTS
 MC= SOL MOISTURE CONTENT
 MD= SOL MOIST DENSITY
 C= SOL COHESIVE STRENGTH
 θ = ESTIMATED SOIL INTERNAL ANGLE OF FRICTION

GRAPHIC SCALE
 0 10 0
 (IN FEET)



NOTICE
 THIS DRAWING IS THE PROPERTY
 OF HARD HAT SERVICES AND IS
 NOT TO BE REPRODUCED,
 CHANGED, OR COPIED IN ANY FORM
 OR MANNER WITHOUT PRIOR
 WRITTEN PERMISSION. ALL RIGHTS
 RESERVED.

REV	DATE	BY	DESCRIPTION






SCALE: AS SHOWN
 DATE: 7-18-16
 DRAWN BY: JFD
 CHKD BY: MWL
 APRVD BY: TJH

CLIENT / LOCATION
 ALLIENT ENERGY
 EDGEWATER GENERATING STATION
 SHEBOYGAN WISCONSIN

DRAWING DESCRIPTION
 SAFETY FACTOR ASSESSMENT
 CROSS-SECTIONS
 EDG POND B AND SOUTH-A POND

JOB 154.018.012.006
 SHT. FIGURE 3
 DWG. -----





LEGEND

SOIL LAYER BOUNDARY USED IN STABILITY ANALYSIS

N= SPT BLOW COUNTS
 MC= SOIL MOISTURE CONTENT
 MD= SOIL MOIST DENSITY
 C= SOIL COHESIVE STRENGTH
 θ = ESTIMATED SOIL INTERNAL ANGLE OF FRICTION

GRAPHIC SCALE

0 10 0
 (IN FEET)



MAP SOURCE:
 MODIFIED FROM MILLER ENGINEERS
 SCIENTISTS, ASH POND SLOPE STABILITY
 EVALUATION, IMPOUNDMENT ANALYSIS,
 SHEET 4 OF 5, FEB. 25, 2011.

NOTICE
 THIS DRAWING IS THE PROPERTY
 OF HARD HAT SERVICES AND IS
 NOT TO BE REPRODUCED,
 CHANGED, OR COPIED IN ANY FORM
 OR MANNER WITHOUT PRIOR
 WRITTEN PERMISSION. ALL RIGHTS
 RESERVED.

REV	DATE	BY	DESCRIPTION





SCALE: AS SHOWN
 DATE: 7-18-16
 DRAWN BY: JFD
 CHKD BY: MWL
 APRVD BY: TJH

CLIENT / LOCATION
 ALLIENT ENERGY
 EDGEWATER GENERATING STATION
 SHEBOYGAN WISCONSIN

DRAWING DESCRIPTION
 SAFETY FACTOR ASSESSMENT
 CROSS-SECTIONS
 EDG POND A-NORTH AND SLAG POND

JOB 154.018.012.006
 SHT. FIGURE 4
 DWG. -----



MAP SOURCE:
 MODIFIED FROM MILLER ENGINEERS
 SCIENTISTS, ASH POND SLOPE STABILITY
 EVALUATION, IMPOUNDMENT ANALYSIS,
 SHEET 5 OF 5, FEB. 25, 2011.

LEGEND

SOIL LAYER BOUNDARY USED IN STABILITY ANALYSIS

N= SPT BLOW COUNTS
 MC= SOIL MOISTURE CONTENT
 MD= SOIL MOIST DENSITY
 C= SOIL COHESIVE STRENGTH
 θ = ESTIMATED SOIL INTERNAL ANGLE OF FRICTION

GRAPHIC SCALE
 0 10 0
 (IN FEET)

NOTICE
 THIS DRAWING IS THE PROPERTY
 OF HARD HAT SERVICES AND IS
 NOT TO BE REPRODUCED,
 CHANGED, OR COPIED IN ANY FORM
 OR MANNER WITHOUT PRIOR
 WRITTEN PERMISSION. ALL RIGHTS
 RESERVED.

REV	DATE	BY	DESCRIPTION



SCALE: AS SHOWN
 DATE: 7-18-16
 DRAWN BY: JFD
 CHKD BY: MWL
 APRVD BY: TJH

CLIENT / LOCATION
 ALLIENT ENERGY
 EDGEWATER GENERATING STATION
 SHEBOYGAN WISCONSIN

DRAWING DESCRIPTION
 SAFETY FACTOR ASSESSMENT
 CROSS-SECTIONS AT BORING Q AND R
 DEEP SOIL BORINGS

JOB 154.018.012.006
 SHT. FIGURE 5
 DWG. -----

APPENDIX A – Soil Boring Logs

Alliant Energy
Wisconsin Power and Light Company
Edgewater Generating Station
Sheboygan, WI

Safety Factor Assessment




CLASSIFICATION OF SOILS FOR ENGINEERING PURPOSES

ASTM Designation: D 2487 – 69 AND D 2488 – 69

(Unified Soil Classification System)

Major divisions		Group symbols	Typical names	Classification criteria			
Coarse-grained soils More than 50% retained on No. 200 sieve*	Gravels 50% or more of coarse fraction retained on No. 4 sieve	GW	Well-graded gravels and gravel-sand mixtures, little or no fines	Classification on basis of percentage of fines Less than 5% pass No. 200 sieve GW, GP, SW, SP More than 12% pass No. 200 sieve GM, GC, SM, SC 5 to 12% pass No. 200 sieve <i>Borderline</i> classifications requiring use of dual symbols	$C_u = \frac{D_{60}}{D_{10}}$ greater than 4; $C_z = \frac{(D_{30})^2}{D_{10} \times D_{60}}$ between 1 and 3		
		GP	Poorly graded gravels and gravel-sand mixtures, little or no fines		Not meeting both criteria for GW		
		Gravels with fines	GM		Silty gravels, gravel-sand-silt mixtures	Atterberg limits below "A" line or P.I. less than 4	Atterberg limits plotting in hatched area are <i>borderline</i> classifications requiring use of dual symbols
			GC		Clayey gravels, gravel-sand-clay mixtures	Atterberg limits above "A" line with P.I. greater than 7	
	Sands More than 50% of coarse fraction passes No. 4 sieve	Clean sands	SW		Well-graded sands and gravelly sands, little or no fines	$C_u = \frac{D_{60}}{D_{10}}$ greater than 6; $C_z = \frac{(D_{30})^2}{D_{10} \times D_{60}}$ between 1 and 3	
			SP		Poorly graded sands and gravelly sands, little or no fines	Not meeting both criteria for SW	
		Sands with fines	SM		Silty sands, sand-silt mixtures	Atterberg limits below "A" line or P.I. less than 4	Atterberg limits plotting in hatched area are <i>borderline</i> classifications requiring use of dual symbols
			SC		Clayey sands, sand-clay mixtures	Atterberg limits above "A" line with P.I. greater than 7	

Fine-grained soils 50% or more passes No. 200 sieve*	Silts and clays Liquid limit 50% or less	ML	Inorganic silts, very fine sands, rock flour, silty or clayey fine sands
		CL	Inorganic clays of low to medium plasticity, gravelly clays, sandy clays, silty clays, lean clays
		OL	Organic silts and organic silty clays of low plasticity
	Silts and clays Liquid limit greater than 50%	MH	Inorganic silts, micaceous or diatomaceous fine sands or silts, elastic silts
		CH	Inorganic clays of high plasticity, fat clays
		OH	Organic clays of medium to high plasticity, organic silts
	Pt	Peat, muck and other highly organic soils	



*Based on the material passing the 3 in. (76 mm) sieve.

LOG OF TEST BORING GENERAL NOTES

SYMBOLS

Descriptive Soil Classification

GRAIN SIZE TERMINOLOGY

Soil Fraction	Particle Size	U.S. Sieve Size
Boulders.....	Larger Than 12".....	Larger Than 12"
Cobbles.....	3" to 12".....	3" to 12"
Gravel: Coarse.....	3/4" to 3".....	3/4" to 3"
Fine.....	4.76mm to 3/4".....	#4 to 3/4"
Sand: Coarse.....	2.00mm to 4.76mm.....	#10 to #4
Medium.....	0.42mm to 2.00mm.....	#40 to #10
Fine.....	0.074mm to 0.42mm.....	#200 to #40
Fines.....	Less Than 0.074mm.....	Smaller Than #200
Silt.....	0.005mm to 0.074mm.....	Smaller Than #200
Clay.....	Smaller Than 0.005mm	

(Plasticity characteristics differentiate between silt and clay.)

COMPOSITION TERMINOLOGY (ASTM D2487)

Primary Constituent:

Gravel

with sand...>=15% sand
with silt.....5-12% silt
with clay.....5-12% clay
silty.....>12% silt
clayey.....>12% clay

Sand

with gravel.....>=15% gravel
with silt.....5-12% silt
with clay.....5-12% clay
silty.....>12% silt
clayey.....>12% clay

Fines (Silt or Clay)

with gravel....15-29% gravel
gravelly.....>=30% gravel
with sand.....15-29% sand
sandy.....>=30% sand

RELATIVE DENSITY

COHESIONLESS SOILS

Term	"N" Value
Very Loose.....	0-4
Loose.....	4-10
Medium Dense.....	10-30
Dense.....	30-50
Very Dense.....	over 50

The penetration resistance, N, is the summation of the number of blows required to affect two successive 6" penetrations of the 2" split-barrel sampler. The sampler is driven with a 140 lb. weight falling 30" and is seated to a depth of 6" before commencing the standard penetration test (ASTM 1586).

CONSISTENCY

COHESIVE SOILS

Term	pp (tons/sq. ft.)	"N" Value
Very Soft.....	0.00 to 0.25.....	<2
Soft.....	0.25 to 0.50.....	2-4
Medium.....	0.50 to 1.00.....	4-8
Stiff.....	1.00 to 2.00.....	8-15
Very Stiff.....	2.00 to 4.00.....	15-30
Hard.....	over 4.00.....	>30

PLASTICITY

Term	Plasticity Index
None to slight.....	0 to 4
Slight.....	5 to 7
Medium.....	8 to 22
High to Very High.....	over 22

DRILLING AND SAMPLING

CS--Continuous Sampling
RC--Rock Coring: Size AW, BW, NW, 2" W
RQD--Rock Quality Designator
RB--Rock Bit
FT--Fish Tail
DC--Drove Casing
C--Casing: Size 2 1/2", NW, 4", HW
CW--Clear Water
DM--Drilling Mud
HSA--Hollow Stem Auger
FA--Flight Auger
HA--Hand Auger
SS--2" Diameter Split-Barrel Sample
2ST--2" Diameter Thin-Walled Tube Sample
3ST--3" Diameter Thin-Walled Tube Sample
PT--3" Diameter Piston Tube Sample
AS--Auger Sample
PS--Pitcher Sample
NR--No Recovery
VS--Vane Shear Test

LABORATORY TESTS

pp--Penetrometer Reading, tons/sq.ft.
qu--Unconfined Strength, tons/sq. ft.
MC--Moisture Content, %
LL--Liquid Limit, %
PL--Plastic Limit, %
PI--Plasticity Index, %
SL--Shrinkage Limit, %
LI--Loss on Ignition, %
D--Dry Unit Weight, lbs./cu. ft.
pH--Measure of Soil Alkalinity or Acidity
FS--Free Swell, %
HNu--ppmv as Benzene
TLV--ppmv as Hexane
TPH--Total Petroleum Hydrocarbons, ppm


WATER LEVEL MEASUREMENTS

▼--Water Table Interpretation

Note: Water level measurements recorded in notes on the boring logs represent conditions at the time indicated and may not reflect static levels, especially in cohesive soils.

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: C
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 590.1
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 12/20/10	Drilling Completed: 12/20/10


SAMPLE TYPE 1" Geoprobe No Recovery Grab Sample Auger Sample 3" Shelby Tube 2" Split Spoon




GEOLOG GINT_18634.GPJ MILLR_ENG.GDT 2/9/11 09:59

	Water Level Cave-in Depth		Borehole Abandonment		Crew: M&K Drill/WGF
	Date: 12/20/2010	Time: _____	dry ft. 13	ft. _____	Date: 12/20/2010
	Date: _____	Time: _____	ft. _____	ft. _____	Material: BENTONITE
					Rig: Mobile B52
					Method: HSA

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: D
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 590.9
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 12/10/10	Drilling Completed: 12/10/10




GEOLOG GINT_18634.GPJ MILLR_ENG GDT 2/19/11 09:59



Date _____ Time _____ ft. _____ ft.		Water Level		Cave-in Depth		Borehole Abandonment		Crew: M&K Drill/WGF	
Date _____ Time _____ ft. _____ ft.						Date: 12/10/2010		Rig: Mobile B52	
Date _____ Time _____ ft. _____ ft.						Material: BENTONITE		Method: HSA	

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: E
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 607.9
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 12/21/10	Drilling Completed: 12/21/10

SAMPLE TYPE 1" Geoprobe No Recovery Grab Sample Auger Sample 3" Shelby Tube 2" Split Spoon



GEOTLOG GINT_18634.GPJ MILLR_ENG.GDT 2/9/11 09:59


MILLER ENGINEERS SCIENTISTS

Date: 12/21/2010	Time: 3 ft	32.5 ft
Date: _____	Time: _____	_____ ft
Date: _____	Time: _____	_____ ft

Water Level	Cave-in Depth	Borehole Abandonment
		Date: 12/21/2010
		Material: BENTONITE

Crew: M&K Drill/WGF
Rig: Mobile B52
Method: HSA

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: E
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 607.9
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 12/21/10	Drilling Completed: 12/21/10
SAMPLE TYPE <input checked="" type="checkbox"/> 1" Geoprobe <input type="checkbox"/> No Recovery <input type="checkbox"/> Grab Sample <input type="checkbox"/> Auger Sample <input checked="" type="checkbox"/> 3" Shelby Tube <input checked="" type="checkbox"/> 2" Split Spoon		



GEOLOG GINT_18634.GPJ MILLR_ENG.GDT 2/9/11 09:59




Date	12/21/2010	Time	3	ft.	32.5	ft.
Date		Time		ft.		ft.
Date		Time		ft.		ft.

Water Level	Cave-in Depth	Borehole Abandonment
		Date: 12/21/2010
		Material: BENTONITE

Crew:	M&K Drill/WGF
Rig:	Mobile B52
Method:	HSA

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: F
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 609.0
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 12/21/10	Drilling Completed: 12/21/10
SAMPLE TYPE <input checked="" type="checkbox"/> 1" Geoprobe <input type="checkbox"/> No Recovery <input checked="" type="checkbox"/> Grab Sample <input type="checkbox"/> Auger Sample <input type="checkbox"/> 3" Shelby Tube <input type="checkbox"/> 2" Split Spoon		



GEOTLOG GINT_18634.GPJ MILLR_ENG.GDT 2/9/11 09:59

MILLER ENGINEERS SCIENTISTS

Water Level Cave-in Depth

Date 12/21/2010 Time _____ dry ft. 26 ft.

Date _____ Time _____ ft. _____ ft.

Date _____ Time _____ ft. _____ ft.

Borehole Abandonment

Date: 12/21/2010


Material: BENTONITE

Crew: M&K Drill/WGF

Rig: Mobile B52

Method: HSA

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: F
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 609.0
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 12/21/10	Drilling Completed: 12/21/10
SAMPLE TYPE <input checked="" type="checkbox"/> 1" Geoprobe <input type="checkbox"/> No Recovery <input checked="" type="checkbox"/> Grab Sample <input type="checkbox"/> Auger Sample <input type="checkbox"/> 3" Shelby Tube <input type="checkbox"/> 2" Split Spoon		



GEOLOG GINT 18634.GPJ MILLR_ENG.GDT 2/9/11 09:59


MILLER ENGINEERS SCIENTISTS

Date	12/21/2010	Time	dry	ft.	26	ft.
Date		Time		ft.		ft.
Date		Time		ft.		ft.

Water Level	Cave-in Depth	Borehole Abandonment
		Date: 12/21/2010
		Material: BENTONITE

Crew:	M&K Drill/WGF
Rig:	Mobile B52
Method:	HSA

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: I
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 611.9
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 12/21/10	Drilling Completed: 12/21/10



GEOTLOG GINT_18634.GPJ MILLR_ENG_GDT_29/11 09:59

MILLER ENGINEERS SCIENTISTS


Date: 12/21/2010	Time: _____	dry ft. 27	ft. _____
Date: _____	Time: _____	ft. _____	ft. _____
Date: _____	Time: _____	ft. _____	ft. _____

Water Level	Cave-in Depth	Borehole Abandonment
		Date: 12/21/2010
		Material: BENTONITE

Crew:	M&K Drill/WGF
Rig:	Mobile B52
Method:	HSA

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: I
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 611.9
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 12/21/10	Drilling Completed: 12/21/10

SAMPLE TYPE 1" Geoprobe No Recovery Grab Sample Auger Sample 3" Shelby Tube 2" Split Spoon




GEOLOG GINT_18634.GPJ MILLR_ENG.GDT 2/9/11 09:59

MILLER ENGINEERS SCIENTISTS

Water Level Cave-in Depth Borehole Abandonment
 Date 12/21/2010 Time dry ft. 27 ft.
 Date _____ Time _____ ft. _____ ft.
 Date _____ Time _____ ft. _____ ft.

Crew: **M&K Drill/WGF**
 Rig: **Mobile B52**
 Method: **HSA**
 Date: **12/21/2010**
 Material: **BENTONITE**

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: N
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 611.8
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 12/21/10	Drilling Completed: 12/21/10
SAMPLE TYPE <input checked="" type="checkbox"/> 1" Geoprobe <input type="checkbox"/> No Recovery <input type="checkbox"/> Grab Sample <input type="checkbox"/> Auger Sample <input checked="" type="checkbox"/> 3" Shelby Tube <input type="checkbox"/> 2" Split Spoon		




GEOLOG GINT_18634.GPJ MILLR_ENG.GDT 2/19/11 10:00



Date 12/21/2010 Time _____ dry ft. 29 ft.		Borehole Abandonment		Crew: M&K Drill/WGF	
Date _____ Time _____ ft. _____ ft.	Date: 12/21/2010			Rig: Mobile B52	
Date _____ Time _____ ft. _____ ft.	Material: BENTONITE			Method: HSA	

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: N
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 611.8
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 12/21/10	Drilling Completed: 12/21/10
SAMPLE TYPE <input checked="" type="checkbox"/> 1" Geoprobe <input type="checkbox"/> No Recovery <input checked="" type="checkbox"/> Grab Sample <input checked="" type="checkbox"/> Auger Sample <input type="checkbox"/> 3" Shelby Tube <input checked="" type="checkbox"/> 2" Split Spoon		




GEOLOG GINT_18634.GPJ MILLR_ENG.GDT 2/9/11 10:00

MILLER ENGINEERS SCIENTISTS

Date 12/21/2010 Time dry ft. 29 ft.		Water Level		Cave-in Depth		Borehole Abandonment		Crew: M&K Drill/WGF	
Date	Time	ft.	ft.	Date:	12/21/2010	Rig:	Mobile B52	Method: HSA	
Date	Time	ft.	ft.	Material:	BENTONITE				

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: P
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 609.7
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 12/20/10	Drilling Completed: 12/20/10
SAMPLE TYPE <input checked="" type="checkbox"/> 1" Geoprobe <input type="checkbox"/> No Recovery <input type="checkbox"/> Grab Sample <input checked="" type="checkbox"/> Auger Sample <input type="checkbox"/> 3" Shelby Tube <input type="checkbox"/> 2" Split Spoon		



Boring terminated at 20 feet.

GEOLOG GINT_18634.GPJ MILLR_ENG.GDT 2/9/11 10:00

MILLER ENGINEERS SCIENTISTS


Date	12/20/2010	Time	dry	ft.	16	ft.
Date		Time		ft.		ft.
Date		Time		ft.		ft.

Water Level	Cave-in Depth	Borehole Abandonment
		Date: 12/20/2010
		Material: BENTONITE

Crew:	M&K Drill/WGF
Rig:	Mobile B52
Method:	HSA

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: Q
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 609.2
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 2/23/11	Drilling Completed: 2/23/11

SAMPLE TYPE 1" Geoprobe No Recovery Grab Sample Auger Sample 3" Shelby Tube 2" Split Spoon



GEOLOG GINT 18634.GPJ MLLR.ENG.GDT 3/16/11 10:17


MILLER ENGINEERS SCIENTISTS

Date _____	Time _____	ft. _____	ft. _____
Date _____	Time _____	ft. _____	ft. _____
Date _____	Time _____	ft. _____	ft. _____

Water Level	Cave-in Depth	Borehole Abandonment
		Date: 2/23/2011
		Material: BENTONITE

Crew: M&K Drill/WGF
Rig: Mobile B52
Method: Mud Rotary

Project: POND STABILITY EVALUATION	Job No: 10-1-18634	Boring No: R
Client: ALLIANT UTILITIES	Drilled By: M&K ENV & SOILS DRILLING	Elevation: 612.2
Location: EDGEWATER - SHEBOYGAN, WI	Drilling Begun: 2/24/11	Drilling Completed: 2/24/11
SAMPLE TYPE <input checked="" type="checkbox"/> 1" Geoprobe <input type="checkbox"/> No Recovery <input checked="" type="checkbox"/> Grab Sample <input type="checkbox"/> Auger Sample <input type="checkbox"/> 3" Shelby Tube <input checked="" type="checkbox"/> 2" Split Spoon		



GEOTLOG GINT 18634.GPJ MILLR_ENG_GDT 3/16/11 10:17



Date _____ Time _____ ft. _____ ft.		Water Level _____ Cave-in Depth _____		Borehole Abandonment		Crew: M&K Drill/WGF	
Date _____ Time _____ ft. _____ ft.		Date: 2/24/2011		Material: BENTONITE		Rig: Mobile B52	
Date _____ Time _____ ft. _____ ft.						Method: Mud Rotary	

APPENDIX B – Soil Strength Properties

Alliant Energy
Wisconsin Power and Light Company
Edgewater Generating Station
Sheboygan, WI

Safety Factor Assessment






Fig. 8. Correlations Between the Effective Friction Angle in Triaxial Compression and the Dry Density, Relative Density, Grain Size, and Gradation for Granular Soils (After DM-7).

$$\gamma_{ur} = \frac{(1 + w_{sat}) \gamma_w}{w_{sat} + \frac{1}{G_s}}$$

APPENDIX C – Earthquake and Liquefaction Analysis

Alliant Energy
Wisconsin Power and Light Company
Edgewater Generating Station
Sheboygan, WI

Safety Factor Assessment




Design Maps Detailed Report

ASCE 7-10 Standard (43.707°N, 87.707°W)

Site Class D – “Stiff Soil”, Risk Category I/II/III

Section 11.4.1 — Mapped Acceleration Parameters

Note: Ground motion values provided below are for the direction of maximum horizontal spectral response acceleration. They have been converted from corresponding geometric mean ground motions computed by the USGS by applying factors of 1.1 (to obtain S_s) and 1.3 (to obtain S_1). Maps in the 2010 ASCE-7 Standard are provided for Site Class B. Adjustments for other Site Classes are made, as needed, in Section 11.4.3.

From [Figure 22-1](#) ^[1]

$S_s = 0.067 \text{ g}$

From [Figure 22-2](#) ^[2]

$S_1 = 0.040 \text{ g}$

Section 11.4.2 — Site Class

The authority having jurisdiction (not the USGS), site-specific geotechnical data, and/or the default has classified the site as Site Class D, based on the site soil properties in accordance with Chapter 20.

Table 20.3-1 Site Classification

Site Class	\bar{v}_s	\bar{N} or \bar{N}_{ch}	\bar{s}_u
A. Hard Rock	>5,000 ft/s	N/A	N/A
B. Rock	2,500 to 5,000 ft/s	N/A	N/A
C. Very dense soil and soft rock	1,200 to 2,500 ft/s	>50	>2,000 psf
D. Stiff Soil	600 to 1,200 ft/s	15 to 50	1,000 to 2,000 psf
E. Soft clay soil	<600 ft/s	<15	<1,000 psf
Any profile with more than 10 ft of soil having the characteristics:			
<ul style="list-style-type: none"> • Plasticity index $PI > 20$, • Moisture content $w \geq 40\%$, and • Undrained shear strength $\bar{s}_u < 500 \text{ psf}$ 			
F. Soils requiring site response analysis in accordance with Section 21.1	See Section 20.3.1		

For SI: 1ft/s = 0.3048 m/s 1lb/ft² = 0.0479 kN/m²

Section 11.4.3 — Site Coefficients and Risk-Targeted Maximum Considered Earthquake (MCE_R) Spectral Response Acceleration Parameters

Table 11.4-1: Site Coefficient F_a

Site Class	Mapped MCE _R Spectral Response Acceleration Parameter at Short Period				
	$S_s \leq 0.25$	$S_s = 0.50$	$S_s = 0.75$	$S_s = 1.00$	$S_s \geq 1.25$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.2	1.2	1.1	1.0	1.0
D	1.6	1.4	1.2	1.1	1.0
E	2.5	1.7	1.2	0.9	0.9
F	See Section 11.4.7 of ASCE 7				

Note: Use straight-line interpolation for intermediate values of S_s

For Site Class = D and $S_s = 0.067$ g, $F_a = 1.600$

Table 11.4-2: Site Coefficient F_v

Site Class	Mapped MCE _R Spectral Response Acceleration Parameter at 1-s Period				
	$S_1 \leq 0.10$	$S_1 = 0.20$	$S_1 = 0.30$	$S_1 = 0.40$	$S_1 \geq 0.50$
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.7	1.6	1.5	1.4	1.3
D	2.4	2.0	1.8	1.6	1.5
E	3.5	3.2	2.8	2.4	2.4
F	See Section 11.4.7 of ASCE 7				

Note: Use straight-line interpolation for intermediate values of S_1

For Site Class = D and $S_1 = 0.040$ g, $F_v = 2.400$

Equation (11.4-1): $S_{MS} = F_a S_S = 1.600 \times 0.067 = 0.107 \text{ g}$

Equation (11.4-2): $S_{M1} = F_v S_1 = 2.400 \times 0.040 = 0.095 \text{ g}$

Section 11.4.4 — Design Spectral Acceleration Parameters


Equation (11.4-3): $S_{DS} = \frac{2}{3} S_{MS} = \frac{2}{3} \times 0.107 = 0.071 \text{ g}$

Equation (11.4-4): $S_{D1} = \frac{2}{3} S_{M1} = \frac{2}{3} \times 0.095 = 0.063 \text{ g}$

Section 11.4.5 — Design Response Spectrum


From [Figure 22-12](#) ^[3]

$T_L = 12 \text{ seconds}$



Section 11.4.6 — Risk-Targeted Maximum Considered Earthquake (MCE_R) Response Spectrum

The MCE_R Response Spectrum is determined by multiplying the design response spectrum above by 1.5.



Section 11.8.3 — Additional Geotechnical Investigation Report Requirements for Seismic Design Categories D through F

From [Figure 22-7](#) ^[4]

$$PGA = 0.031$$

Equation (11.8-1):

$$PGA_M = F_{PGA} PGA = 1.600 \times 0.031 = 0.05 \text{ g}$$

Table 11.8-1: Site Coefficient F_{PGA}

Site Class	Mapped MCE Geometric Mean Peak Ground Acceleration, PGA				
	PGA ≤ 0.10	PGA = 0.20	PGA = 0.30	PGA = 0.40	PGA ≥ 0.50
A	0.8	0.8	0.8	0.8	0.8
B	1.0	1.0	1.0	1.0	1.0
C	1.2	1.2	1.1	1.0	1.0
D	1.6	1.4	1.2	1.1	1.0
E	2.5	1.7	1.2	0.9	0.9
F	See Section 11.4.7 of ASCE 7				

Note: Use straight-line interpolation for intermediate values of PGA

For Site Class = D and PGA = 0.031 g, $F_{PGA} = 1.600$

Section 21.2.1.1 — Method 1 (from Chapter 21 – Site-Specific Ground Motion Procedures for Seismic Design)

From [Figure 22-17](#) ^[5]

$$C_{RS} = 0.909$$

From [Figure 22-18](#) ^[6]

$$C_{R1} = 0.876$$

Section 11.6 — Seismic Design Category

Table 11.6-1 Seismic Design Category Based on Short Period Response Acceleration Parameter

VALUE OF S_{DS}	RISK CATEGORY		
	I or II	III	IV
$S_{DS} < 0.167g$	A	A	A
$0.167g \leq S_{DS} < 0.33g$	B	B	C
$0.33g \leq S_{DS} < 0.50g$	C	C	D
$0.50g \leq S_{DS}$	D	D	D

For Risk Category = I and $S_{DS} = 0.071 g$, Seismic Design Category = A

Table 11.6-2 Seismic Design Category Based on 1-S Period Response Acceleration Parameter

VALUE OF S_{D1}	RISK CATEGORY		
	I or II	III	IV
$S_{D1} < 0.067g$	A	A	A
$0.067g \leq S_{D1} < 0.133g$	B	B	C
$0.133g \leq S_{D1} < 0.20g$	C	C	D
$0.20g \leq S_{D1}$	D	D	D

For Risk Category = I and $S_{D1} = 0.063 g$, Seismic Design Category = A

Note: When S_1 is greater than or equal to 0.75g, the Seismic Design Category is **E** for buildings in Risk Categories I, II, and III, and **F** for those in Risk Category IV, irrespective of the above.

Seismic Design Category \equiv "the more severe design category in accordance with Table 11.6-1 or 11.6-2" = A

Note: See Section 11.6 for alternative approaches to calculating Seismic Design Category.

References

1. Figure 22-1: http://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-1.pdf
2. Figure 22-2: http://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-2.pdf
3. Figure 22-12: http://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-12.pdf
4. Figure 22-7: http://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-7.pdf
5. Figure 22-17: http://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-17.pdf
6. Figure 22-18: http://earthquake.usgs.gov/hazards/designmaps/downloads/pdfs/2010_ASCE-7_Figure_22-18.pdf

Simplified Seed and Idriss Liquefaction Analysis
SPT Based Analysis
Edgewater Generating Station
Interstate Electric Power
Equations from "Soil Liquefaction During Earthquakes" Idriss & Boulanger
Soil Conditions at Boring E Figure 3
Edgewater Generating Station

Input Parameters:

Peak Ground Acceleration (g) = 0.05
Earthquake Magnitude, M = 7.7
Water Table Depth (ft) = 10
Average Soil Density above water table (lb/ft³) = 115.0
Average Soil Density below water table (lb/ft³) = 120.0
Borehole Diameter (mm) = 100
Rod Lengths assumed equal to depth plus 5.0 feet (for the above ground extension)

SPT #	Depth (ft)	Measured N	Soil Type (USCS)	Flag "Clay" "Unsaturated"	Fines Content (%)	Energy Ratio, ER (%)	C _e	C _b	C _r	N ₆₀	σ _{vc} (lb/ft ²)	σ _{vc} ' (lb/ft ²)	C _n	(N ₁) ₆₀	ΔN for fines content	(N ₁) _{60-CS}	Stress Reduction Coeff, r _d	CSR	MSF for sand	k _σ for sand	CRR 7.5M & 1 atm	CRR	Factor of Safety
2	3	9	CL	Clay		75%	1.25	1	0.75	8.4	345	345	1.70	n.a.	n.a.	n.a.	1.00	0.033	0.95	1.10	n.a.	n.a.	n.a.
3	4.5	16	CL	Clay		75%	1.25	1	0.75	15.0	518	518	1.70	n.a.	n.a.	n.a.	1.00	0.032	0.95	1.10	n.a.	n.a.	n.a.
4	6.5	16	CL	Clay		75%	1.25	1	0.8	16.0	748	748	1.68	n.a.	n.a.	n.a.	0.99	0.032	0.95	1.10	n.a.	n.a.	n.a.
5	9.5	18	CL	Clay		75%	1.25	1	0.85	19.1	1093	1093	1.39	n.a.	n.a.	n.a.	0.99	0.032	0.95	1.10	n.a.	n.a.	n.a.
6	11.5	18	CL	Clay		75%	1.25	1	0.85	19.1	1330	1236	1.31	n.a.	n.a.	n.a.	0.98	0.034	0.95	1.10	n.a.	n.a.	n.a.
7	14.5	16	CL	Clay		75%	1.25	1	0.85	17.0	1690	1409	1.23	n.a.	n.a.	n.a.	0.97	0.038	0.95	1.10	n.a.	n.a.	n.a.
8	16.5	20	CL	Clay		75%	1.25	1	0.95	23.8	1930	1524	1.18	n.a.	n.a.	n.a.	0.97	0.040	0.95	1.10	n.a.	n.a.	n.a.
9	19.5	16	CL	Clay		75%	1.25	1	0.95	19.0	2290	1697	1.12	n.a.	n.a.	n.a.	0.96	0.042	0.95	1.07	n.a.	n.a.	n.a.
10	24.5	13	ML		50	75%	1.25	1	0.95	15.4	2890	1985	1.03	15.9	5.6	21.6	0.94	0.044	0.95	1.01	0.226	0.217	2.00
11	29.5	2	ML		50	75%	1.25	1	1	2.5	3490	2273	0.97	2.4	5.6	8.0	0.92	0.046	0.95	0.99	0.105	0.099	2.00
12	34.5	4	ML		50	75%	1.25	1	1	5.0	4090	2561	0.91	4.5	5.6	10.2	0.90	0.047	0.95	0.98	0.119	0.111	2.00
13	39.5	7	CL	Clay		75%	1.25	1	1	8.8	4690	2849	0.86	n.a.	n.a.	n.a.	0.88	0.047	0.95	0.91	n.a.	n.a.	n.a.


APPENDIX D – Slope Stability Analysis

Alliant Energy
Wisconsin Power and Light Company
Edgewater Generating Station
Sheboygan, WI

Safety Factor Assessment




EGS Section-N with Normal Water Level Static Case (A Pond North @ 607')
 Ten Most Critical. E:\EGS40B.PLT 07-13-16 7:20pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	120	120	1800	0	0	0	W1
2 Clay	125	125	4000	0	0	0	W1
3 Clay	120	120	2200	0	0	0	W1
4 Silt	110	110	0	27	0	0	W1
5 Clay	120	120	2500	0	0	0	W1
6 Ash	120	120	0	27	0	0	W1

EGS Section-N with Normal Water Level Earth Quake Case (A Pond North @ 607')
 Ten Most Critical, E:\EGS40BEQ.PLT 07-13-16 7:21pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	120	120	1800	0	0	0	W1
2 Clay	125	125	4000	0	0	0	W1
3 Clay	120	120	2200	0	0	0	W1
4 Silt	110	110	0	27	0	0	W1
5 Clay	120	120	2500	0	0	0	W1
6 Ash	120	120	0	27	0	0	W1

EGS Section-N with Normal Water Level Static Case (A Pond North @ 607')
 Ten Most Critical. E:\EGS40C.PLT 07-13-16 7:22pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	120	120	1800	0	0	0	W1
2 Clay	125	125	4000	0	0	0	W1
3 Clay	120	120	2200	0	0	0	W1
4 Silt	110	110	0	27	0	0	W1
5 Clay	120	120	2500	0	0	0	W1
6 Ash	120	120	0	27	0	0	W1

EGS Section-N with Normal Water Level Earth Quake Case (A Pond North @ 607')
 Ten Most Critical. E:EGS40CEQ.PLT 07-13-16 7:22pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	120	120	1800	0	0	0	W1
2 Clay	125	125	4000	0	0	0	W1
3 Clay	120	120	2200	0	0	0	W1
4 Silt	110	110	0	27	0	0	W1
5 Clay	120	120	2500	0	0	0	W1
6 Ash	120	120	0	27	0	0	W1

EGS Section-N with 1,000 Yr. Water Level Static Case (A Pond North @ 609')
 Ten Most Critical. E:EGS41B.PLT 07-13-16 7:23pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	120	120	1800	0	0	0	W1
2 Clay	125	125	4000	0	0	0	W1
3 Clay	120	120	2200	0	0	0	W1
4 Silt	110	110	0	27	0	0	W1
5 Clay	120	120	2500	0	0	0	W1
6 Ash	120	120	0	27	0	0	W1

EGS Section-N with 1,000 Yr. Water Level Static Case (A Pond North @ 609')
 Ten Most Critical. E:EGS41C.PLT 07-13-16 7:24pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	120	120	1800	0	0	0	W1
2 Clay	125	125	4000	0	0	0	W1
3 Clay	120	120	2200	0	0	0	W1
4 Silt	110	110	0	27	0	0	W1
5 Clay	120	120	2500	0	0	0	W1
6 Ash	120	120	0	27	0	0	W1

EGS Section-P with Normal Water Level Static Case (Slag Pond @ 606.7')
 Ten Most Critical. E:EGS50B.PLT 07-13-16 7:41pm



Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	125	125	3300	0	0	0	W1
2 Silt	110	110	0	27	0	0	W1
3 Clay	120	120	2500	0	0	0	W1


EGS Section-P with Normal Water Level Earth Quake Case (Slag Pond @ 606.7')
 Ten Most Critical. E:EGS50BEQ.PLT 07-13-16 7:27pm



PCSTABL5M/SI FSmin=7.24 X-Axis (ft)


Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	125	125	3300	0	0	0	W1
2 Silt	110	110	0	27	0	0	W1
3 Clay	120	120	2500	0	0	0	W1

EGS Section-P with Normal Water Level Static Case (Slag Pond @ 606.7')
 Ten Most Critical. E:EGS50C.PLT 07-13-16 7:31pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	125	125	3300	0	0	0	W1
2 Silt	110	110	0	27	0	0	W1
3 Clay	120	120	2500	0	0	0	W1

EGS Section-P with Normal Water Level Earth Quake Case (Slag Pond @ 606.7')
 Ten Most Critical. E:EGS50CEQ.PLT 07-13-16 7:34pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	125	125	3300	0	0	0	W1
2 Silt	110	110	0	27	0	0	W1
3 Clay	120	120	2500	0	0	0	W1

EGS Section-P with 1,000 yr. Water Level Static Case (Slag Pond @ 607.5')
 Ten Most Critical. E:EGS51B.PLT 07-13-16 7:37pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	125	125	3300	0	0	0	W1
2 Silt	110	110	0	27	0	0	W1
3 Clay	120	120	2500	0	0	0	W1

EGS Section-P with 1,000 yr. Water Level Static Case (Slag Pond @ 607.5')
 Ten Most Critical. E:\EGS51C.PLT 07-13-16 7:39pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	125	125	3300	0	0	0	W1
2 Silt	110	110	0	27	0	0	W1
3 Clay	120	120	2500	0	0	0	W1

EGS Section-E with Normal Water Level Static Case (B Pond @ 598.8')
 Ten Most Critical. E:\EGS60B.PLT 07-13-16 7:55pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	125	125	3100	0	0	0	W1
2 Silt	110	110	0	27	0	0	W1
3 Clay	120	120	1500	0	0	0	W1

EGS Section-E with Normal Water Level Earth Quake Case (B Pond @ 598.8')
 Ten Most Critical. E:\EGS60BEQ.PLT 07-13-16 7:59pm




Soil Type No.	Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1	Clay	125	125	3100	0	0	0	W1
2	Silt	110	110	0	27	0	0	W1
3	Clay	120	120	1500	0	0	0	W1

EGS-Section E with Normal Water Level Static Case (B Pond @ 598.8')
 Ten Most Critical. E:EGS60C.PLT 07-13-16 8:08pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	125	125	3100	0	0	0	W1
2 Silt	110	110	0	27	0	0	W1
3 Clay	120	120	1500	0	0	0	W1

EGS-Section E with Normal Water Level Earth Quake Case (B Pond @ 598.8')
 Ten Most Critical. E:\EGS60CEQ.PLT 07-13-16 8:10pm




Soil Type No.	Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1	Clay	125	125	3100	0	0	0	W1
2	Silt	110	110	0	27	0	0	W1
3	Clay	120	120	1500	0	0	0	W1

EGS Section-E with 1,000 yr. Water Level Static Case (B Pond @ 599.2')
 Ten Most Critical. E:\EGS61B.PLT 07-13-16 8:22pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	125	125	3100	0	0	0	W1
2 Silt	110	110	0	27	0	0	W1
3 Clay	120	120	1500	0	0	0	W1

EGS Section-E with 1,000 yr. Water Level Static Case (B Pond @ 599.2')
 Ten Most Critical. E:\EGS61C.PLT 07-13-16 8:17pm




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Clay	125	125	3100	0	0	0	W1
2 Silt	110	110	0	27	0	0	W1
3 Clay	120	120	1500	0	0	0	W1

EGS Section-I with Normal Water Level Static Case (South A Pond @ 609.2')
 Ten Most Critical. E:EGS70B.PLT 07-14-16 6:56am




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Ash	125	125	0	37	0	0	W1
2 Mixture	125	125	3600	0	0	0	W1
3 Clay	125	125	3100	0	0	0	W1
4 Silt	110	110	0	30	0	0	W1
5 Clay	120	120	1500	0	0	0	W1

EGS Section-I with Normal Water Level Earth Quake Case (South A Pond @ 609.2')
 Ten Most Critical. E:EGS70BEQ.PLT 07-14-16 6:59am




Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Ash	125	125	0	37	0	0	W1
2 Mixture	125	125	3600	0	0	0	W1
3 Clay	125	125	3100	0	0	0	W1
4 Silt	110	110	0	30	0	0	W1
5 Clay	120	120	1500	0	0	0	W1

EGS Section-I with Normal Water Level Static Case (South A Pond @ 609.2')
 Ten Most Critical. E:EGS70C.PLT 07-14-16 7:12am




Soil Type No.	Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1	Ash	125	125	0	37	0	0	W1
2	Mixture	125	125	3600	0	0	0	W1
3	Clay	125	125	3100	0	0	0	W1
4	Silt	110	110	0	30	0	0	W1
5	Clay	120	120	1500	0	0	0	W1

EGS Section-I with Normal Water Level Earth Quake Case (South A Pond @ 609.2')
 Ten Most Critical. E:\EGS70CEQ.PLT 07-14-16 7:09am




Soil Type No.	Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1	Ash	125	125	0	37	0	0	W1
2	Mixture	125	125	3600	0	0	0	W1
3	Clay	125	125	3100	0	0	0	W1
4	Silt	110	110	0	30	0	0	W1
5	Clay	120	120	1500	0	0	0	W1

EGS Section-I with 1,000 yr. water level Static Case (South A Pond @ 609.97')
 Ten Most Critical. E:EGS71B.PLT 07-14-16 7:24am



Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Ash	125	125	0	37	0	0	W1
2 Mixture	125	125	3600	0	0	0	W1
3 Clay	125	125	3100	0	0	0	W1
4 Silt	110	110	0	30	0	0	W1
5 Clay	120	120	1500	0	0	0	W1

EGS Section-I with 1,000 yr. water level Static Case (South A Pond @ 609.97')
 Ten Most Critical. E:EGS71C.PLT 07-14-16 7:38am



Soil Type No. Label	Total Unit Wt. (pcf)	Saturated Unit Wt. (pcf)	Cohesion Intercept (psf)	Friction Angle (deg)	Pore Pressure Param.	Pressure Constant (psf)	Piez. Surface No.
1 Ash	125	125	0	37	0	0	W1
2 Mixture	125	125	3600	0	0	0	W1
3 Clay	125	125	3100	0	0	0	W1
4 Silt	110	110	0	30	0	0	W1
5 Clay	120	120	1500	0	0	0	W1