


ALLIANT ENERGY
Interstate Power and Light Company
Burlington Generating Station

CCR SURFACE IMPOUNDMENT

STRUCTURAL STABILITY ASSESSMENT

Report Issued: August 25, 2016
Revision 0



EXECUTIVE SUMMARY

This Structural Stability Assessment (Report) is prepared in accordance with the requirements of the United States Environmental Protection Agency (USEPA) published Final Rule for Hazardous and Solid Waste Management System – Disposal of Coal Combustion Residual (CCR) from Electric Utilities (40 CFR Parts 257 and 261, also known as the CCR Rule) published on April 17, 2015 and effective October 19, 2015.

This Report assesses the structural stability of each CCR unit at Burlington Generating Station in Burlington, Iowa in accordance with §257.73(b) and §257.73(d) of the CCR Rule. For purposes of this Report, “CCR unit” refers to an existing CCR surface impoundment.

Primarily, this Report documents whether the design, construction, operation, and maintenance of the CCR unit is consistent with recognized and generally accepted good engineering practices for the maximum volume of CCR and CCR wastewater which can be impounded within each CCR unit.



Table of Contents

1	Introduction	1
1.1	CCR Rule Applicability	1
1.2	Structural Stability Assessment Applicability	1
2	FACILITY DESCRIPTION	2
2.1	BGS Ash Seal Pond	2
2.2	BGS Main Ash Pond	3
2.3	BGS Economizer Pond	4
2.4	BGS Upper Ash Pond	6
3	STRUCTURAL STABILITY ASSESSMENT- §257.73(d)	8
3.1	BGS Ash Seal Pond	8
3.1.1	CCR Unit Foundation and Abutments - §257.73(d)(1)(i)	8
3.1.2	Slope Protection - §257.73(d)(1)(ii)	9
3.1.3	CCR Embankment Density- §257.73(d)(1)(iii)	9
3.1.4	Vegetation Management - §257.73(d)(1)(iv)	10
3.1.5	Spillway Management - §257.73(d)(1)(v)	10
3.1.6	Hydraulic Structures - §257.73(d)(1)(vi)	10
3.1.7	Sudden Drawdown - §257.73(d)(1)(vii)	10
3.2	BGS Main Ash Pond	11
3.2.1	CCR Unit Foundation and Abutments - §257.73(d)(1)(i)	11
3.2.2	Slope Protection - §257.73(d)(1)(ii)	11
3.2.3	CCR Embankment Density- §257.73(d)(1)(iii)	12
3.2.4	Vegetation Management - §257.73(d)(1)(iv)	12
3.2.5	Spillway Management - §257.73(d)(1)(v)	13
3.2.6	Hydraulic Structures - §257.73(d)(1)(vi)	13
3.2.7	Sudden Drawdown - §257.73(d)(1)(vii)	13
3.3	BGS Economizer Pond	14
3.3.1	CCR Unit Foundation and Abutments - §257.73(d)(1)(i)	14
3.3.2	Slope Protection - §257.73(d)(1)(ii)	15
3.3.3	CCR Embankment Density- §257.73(d)(1)(iii)	15
3.3.4	Vegetation Management - §257.73(d)(1)(iv)	16
3.3.5	Spillway Management - §257.73(d)(1)(v)	16
3.3.6	Hydraulic Structures - §257.73(d)(1)(vi)	17
3.3.7	Sudden Drawdown - §257.73(d)(1)(vii)	17
3.4	BGS Upper Ash Pond	17
3.4.1	CCR Unit Foundation and Abutments - §257.73(d)(1)(i)	18
3.4.2	Slope Protection - §257.73(d)(1)(ii)	18
3.4.3	CCR Embankment Density- §257.73(d)(1)(iii)	18
3.4.4	Vegetation Management - §257.73(d)(1)(iv)	19



3.4.5	Spillway Management - §257.73(d)(1)(v).....	19
3.4.6	Hydraulic Structures - §257.73(d)(1)(vi).....	19
3.4.7	Sudden Drawdown - §257.73(d)(1)(vii).....	20
4	QUALIFIED PROFESSIONAL ENGINEER CERTIFICATION	21

Figures

Figure 1: Site Location

Figure 2: Storm Water Routing

Figure 3: Soil Boring and Analyses Cross-Sections

Appendices

Appendix A: Deep Soil Borings

Appendix B: Geoprobe Soil Borings on CCR Embankments

Appendix C: CPT Soil Probes on CCR Embankments

Appendix D: Laboratory Testing on CCR Embankment Soils



1 Introduction

The owner or operator of the Coal Combustion Residual (CCR) unit must conduct an initial and periodic structural stability assessments and document whether the design, construction, operation, and maintenance of the CCR unit is consistent with recognized and generally accepted good engineering practices for the maximum volume of CCR and CCR wastewater which can be impounded therein. This Report has been prepared in accordance with the requirements of §257.73(b) and §257.73(d) of the CCR Rule.

1.1 CCR Rule Applicability

The CCR Rule requires a periodic structural stability assessment by a qualified professional engineer (PE) for existing CCR surface impoundments with a height of 5 feet or more and a storage volume of 20 acre-feet or more; or the existing CCR surface impoundment has a height of 20 feet or more (§257.73(b)).

1.2 Structural Stability Assessment Applicability

The Burlington Generating Station (BGS) in Burlington, Iowa (Figure 1) has four existing CCR surface impoundments that meet the requirements of §257.73(b)(1) or §257.73(b)(2) of the CCR Rule, which are identified as follows:

- BGS Ash Seal Pond
- BGS Main Ash Pond
- BGS Economizer Pond
- BGS Upper Ash Pond



2 FACILITY DESCRIPTION

The following sub-section provides a summary description of the facility and existing CCR surface impoundments located at BGS.

BGS is located southeast of the City of Burlington, Iowa on the western shore of the Mississippi River in Des Moines County, at 4282 Sullivan Slough Road, Burlington, Iowa (Figure 1). BGS is a fossil-fueled electric generating station consisting of one steam electric generating unit and four combustion turbine units. Sub-bituminous coal is the primary fuel for producing steam, and natural gas is used for the combustion turbines. The burning of coal in the steam electric unit produces CCR. The CCR at BGS is categorized into three types, bottom ash, economizer ash, and precipitator fly ash.

Date of Initial Facility Operations: 1968

NPDES Permit Number: IA29-00-1-01

Facility Title V Operating Permit: 98-TV-023R1-M004

Latitude / Longitude: 40°44'29"N 91°07'04"W

Site Coordinates: Section 29, Township 69 North, Range 02 West

Unit Nameplate Ratings: Unit 1: 212 MW

2.1 BGS Ash Seal Pond

The BGS Ash Seal Pond is located south of the generating plant and east of the BGS Main Ash Pond. The CCR, in 1968, was originally managed by discharging into the BGS Ash Seal Pond for settling. Presently, the BGS Ash Seal Pond only receives storm water runoff from the surrounding area associated with the fly ash storage silo. The BGS Ash Seal Pond also may receive facility process water, such as ash seal water, but only if there is an issue with the ash seal water pumps. At the time of the initial annual inspection on October 26, 2015 this CCR surface impoundment did not contain standing water.

The surface area of the BGS Ash Seal Pond is approximately 5.7 acres and has an embankment height of approximately 12 feet from the crest to the toe of the downstream



slope. The embankment crest is at elevation 534 the same as the adjacent plant site grade and equivalent to the 100 year flood water elevation of the Mississippi River. The interior storage depth of the BGS Ash Seal Pond is approximately 12 feet. If water were present, the total volume of impounded CCR and water within the BGS Ash Seal Pond would be approximately 97,000 cubic yards, which would include general fill that has been added in the northeast corner of the impoundment. The original outfall for the impoundment is sealed to prevent discharge to the Mississippi River and the impoundment normally contains no water. Rainfall that accumulates exfiltrates through the bottom of the impoundment. A manually operated pump is available to lift storm water to the adjacent BGS Main Ash Pond, if necessary.

2.2 BGS Main Ash Pond

The BGS Main Ash Pond is located southwest of the generating plant and west of the BGS Ash Seal Pond. The CCR, prior to being sluiced to the BGS Main Ash Pond, was originally managed in the BGS Ash Seal Pond in 1968. In 1971, BGS managed CCR in the BGS Upper Ash Pond. In 1980, the BGS Main Ash Pond became the primary receiver of CCR, with the BGS Upper Ash Pond becoming a downstream receiver.

Presently, the BGS Main Ash Pond receives bottom ash that is sluiced from the generating plant to the northeast corner of the BGS Main Ash Pond. The sluiced bottom ash discharges into the northeast corner where the majority of the bottom ash settles out. The bottom ash that settles out is recovered for beneficial reuse. Hydrated fly ash is also stored within the BGS Main Ash Pond area prior to being sold as aggregate material for beneficial reuse. Fly ash from the on-site storage silo is no longer added to the embankment.

The water that is used to sluice the bottom ash into the BGS Main Ash Pond is routed towards the west end of the BGS Main Ash Pond. The water is discharged in batch quantities as bottom ash accumulates in the boiler and averages 1 cubic foot per second (cfs) on a daily basis. The water flows to the west along the north side of a road



constructed out of bottom ash through the center of the BGS Main Ash Pond, Figure 2. The water flows along the north side of the road until it reaches the west end where it transitions into a ponded area in the northwest corner of the BGS Main Ash Pond. The water in the northwest corner of the BGS Main Ash Pond flows through two 15 inch diameter corrugated metal culverts with identical invert elevation under the generating plant entrance road. The water discharges into a small channel in the southwest corner of the BGS Upper Ash Pond located north of the generating plant entrance road.

The surface area of the BGS Main Ash Pond is approximately 18.7 acres and has an embankment height of approximately 12 feet from the crest to the toe of the downstream slope. The embankment crest is at elevation 534 the same as the plant site grade and equivalent to the 100 year flood water elevation in the Mississippi River. The interior storage depth of the BGS Main Ash Pond is approximately 8 feet. The total volume of impounded CCR and water within the BGS Main Ash Pond at normal water operation elevation is approximately 240,000 cubic yards. Additional volume of impounded CCR, located in the eastern half of the BGS Main Ash Pond above the crest elevation of the embankment, includes the bottom ash storage area and C-stone embankment (hydrated fly ash). In 2008, the quantity of the additional CCR above the crest elevation of the embankment is approximately 104,000 cubic yards.

2.3 BGS Economizer Pond

The BGS Economizer Pond is located west of the generating plant and north of the BGS Main Ash Pond. In 1986, BGS constructed the BGS Economizer Pond in the southern and eastern portion of the original footprint of the BGS Upper Ash Pond. The impoundment has resulted from economizer ash that has been deposited since 1986, which created the economizer embankment which is higher than the embankments of the BGS Upper Ash Pond at approximately elevation 548.

Presently, the BGS Economizer Pond receives economizer ash. The economizer ash is sluiced from the generating plant to the east end of the BGS Economizer Pond via a 10-



inch diameter polyvinyl chloride pipe at a flow rate of 1.5 cfs (including approximately 10% plant process water). The economizer ash settles out through the water column of the 0.4 acre BGS Economizer Pond while the water flows to the west. The water discharges from the BGS Economizer Pond through an 18-inch diameter high-density polyethylene pipe into a storm water and process water treatment channel located along the south side of the economizer embankment.

The storm water and process water treatment channel receives runoff from 8 acres surrounding the generating plant. The collected storm water drains into a pump vault located at the toe of the downstream slope of the east embankment of the BGS Economizer Pond. Plant process water flows through an oil/water separator and receives influent flows from the plant floor drains and water treatment process water. After the oil/water separator, the process water discharges into the pump vault. The storm water and process water is then pumped from the vault up to the storm water treatment channel. The storm water treatment channel flows to the west along the south side of the economizer embankment until it discharges through an 18-inch diameter high-density polyethylene pipe located in the southwest corner of the economizer embankment. The water from the storm water treatment channel discharges into a small channel in the southwest corner of the BGS Upper Ash Pond located north of the generating plant entrance road.

The total surface area of the BGS Economizer Pond and economizer embankment is approximately 11 acres and has an embankment height of approximately 13 feet from the crest to the toe of slope on the CCR in the BGS Upper Ash Pond. The interior storage depth of the top of the economizer embankment to the bottom of the original footprint of the BGS Upper Ash Pond is approximately 27 feet. Thus, the total volume of impounded CCR and water within the BGS Economizer Pond including CCR already in place when the impoundment was established is approximately 480,000 cubic yards.



2.4 BGS Upper Ash Pond

The BGS Upper Ash Pond is located northwest of the generating plant and north of the BGS Main Ash Pond. In 1971, BGS began managing CCR in the BGS Upper Ash Pond. In 1980, the BGS Main Ash Pond became the primary receiver of CCR and the BGS Upper Ash Pond became a downstream receiver of the BGS Main Ash Pond.

Presently, the BGS Upper Ash Pond receives influent flows from the BGS Main Ash Pond, BGS Economizer Pond, and storm water and process water flow from the generating plant. The influent flows all discharge into a small channel located in the southwest corner of the BGS Upper Ash Pond. The water in the channel routed along the south side of the gravel dike of the BGS Upper Ash Pond until it discharges into the southwest corner of the BGS Upper Ash Pond water body.

The water flows through the BGS Upper Ash Pond water body to the northeast towards a 24-inch wide precast concrete Parshall flume that discharges into a concrete catch basin. The water in the catch basin flows through a 15-inch diameter polyvinyl chloride pipe and discharges into the BGS Lower Pond. Instrumentation associated with the BGS Upper Ash Pond includes a flow meter that monitors the discharges. The discharge from the concrete catch basin enters the Lower Pond. The Lower Pond contains the facility's National Pollution Discharge Elimination System (NPDES) Outfall 001. The water flows through the NPDES Outfall 001 hydraulic structure, which consists of cast in place weir box.

The total surface area of the BGS Upper Ash Pond is approximately 13.3 acres and has an embankment height of approximately 10 feet from the crest to the toe of the downstream slope. The elevation of the embankments is 531 feet, 3 feet lower than the 100 year flood elevation of the Mississippi River. The embankment is armored with cobble size stone on the crest and both outer and inner embankment slopes to prevent erosion of the embankment during overtopping from extreme flood stage of the Mississippi River. The interior storage depth of the BGS Upper Ash Pond is approximately 7 feet. The volume



of impounded CCR and water within the BGS Upper Ash Pond at normal operation water elevation is approximately 150,000 cubic yards.



3 STRUCTURAL STABILITY ASSESSMENT- §257.73(d)

This Report documents the design, construction, operation, and maintenance of the BGS CCR units are consistent with recognized and generally accepted good engineering practices for maximum volume of CCR and CCR wastewater which can be impounded.

3.1 BGS Ash Seal Pond

The BGS Ash Seal Pond receives surface water runoff from an approximate area of 2 acres south of the main generating station complex including the dry fly ash handling silo and truck loading area. The northeast corner of the impoundment (approximately 25% of its original footprint) is filled to plant grade of 534 feet. Rainfall that directly enters the impoundment or enters as surface water is stored in the impoundment without discharge. Because the subsoil below the base of the impoundment is sandy due to its location on the natural river levee deposits, the accumulated rain water exfiltrates into the subsurface.

Soil borings and testing taken for plant construction activities and for determination of embankment properties as illustrated on Figure 3 and presented in Appendices A, B, C and D. The results indicate the embankments are constructed of clay compacted over naturally occurring sand and clay. Strength properties of the soils were measured by Standard Split Spoon Penetration (ASTM D 1586) or Cone Penetrometer testing (ASTM D 5778).

3.1.1 CCR Unit Foundation and Abutments - §257.73(d)(1)(i)

The partial excavation and construction of embankments for the BGS Ash Seal Pond occurred during the original construction of the plant. The south and west sides of the impoundment were constructed embankments and the east and north sides were incised below plant design grade. The embankments consist of a mixture of on-site soils from excavation in the sandy levee deposits and off-site clay imported from higher land west of the site. Deep borings taken for construction in the plant area show that the subsurface soils below elevation 510 feet is medium dense sand. Medium dense sand is a strong



subbase for the impoundment embankments. Soil between elevation 510 and the bottom of the impoundment at elevation 520 is generally loose sand and silty sand that remained in place and is partially below the normal water elevation of the Mississippi River elevation 518. The foundations and abutments for the BGS Ash Seal Pond are adequate to support the impoundment infrastructure and contents as demonstrated in the Safety Factor Assessment Report.

3.1.2 Slope Protection - §257.73(d)(1)(ii)

The BGS Ash Seal Pond is incised on the east, north and west sides. The south side faces the condenser discharge channel for the generating station where non-contact cooling water is released in a channel back to the Mississippi River. The crest of the south embankment is approximately 12 feet wide and the downstream slope of the exposed embankment is a 2:1 vegetated slope. Well established and managed vegetation will minimize erosion on both the upstream and downstream slopes. Additionally, storm water runoff is limited to the crest and downstream slope of the embankment, which limits the erosive force. Therefore the impoundment configuration protects against surface erosion.

Wave erosion potential is reduced because the downstream slope is protected within the condenser discharge channel. Wave action is unlikely to produce erosive forces that would affect the BGS Ash Seal Pond embankment.

Sudden drawdown is addressed in Section 3.1.7.

3.1.3 CCR Embankment Density- §257.73(d)(1)(iii)

In 2011, soil borings and penetration tests were taken in the south embankment of the BGS Ash Seal Pond. The results indicate the embankment is low plasticity silty clay (CL) with some layers of loose to medium dense sand. The in place embankment densities identified within the Safety Factor Assessment Report are sufficient to withstand the range of loading conditions that were analyzed.



3.1.4 Vegetation Management - §257.73(d)(1)(iv)

Historically vegetation management has been conducted on a periodic basis. At the time of the initial Annual Inspection in October 2015, the bottom half of the downstream slope could not be properly inspected due to the presence of dense/tall grassy vegetation. During the Spring of 2016, the facility reduced the height of the vegetation to facilitate effective inspections. The facility plans to either continue maintaining the vegetation in a manner that facilitates effective inspection or to armor the slope.

3.1.5 Spillway Management - §257.73(d)(1)(v)

The BGS Ash Seal Pond is currently a zero discharge impoundment. The former spillway, which consisted of a 18-inch PVC pipe, is permanently sealed with hydraulic cement. If rainwater accumulates faster than it exfiltrates, a pump is used to send water to the BGS Main Ash Pond adjacent to the west side of the BGS Ash Seal Pond, Figure 2.

This impoundment currently has a hazard potential classification of “Significant,” which in turn requires an evaluation of the impacts of a 1,000 year rainfall event. The Inflow Flood Control Plan, which is a separate document developed to comply with §257.82, shows that the precipitation from this event will be contained within the limits of the impoundment without overtopping the embankments. The freeboard at peak flow will be approximately 7-inches.

3.1.6 Hydraulic Structures - §257.73(d)(1)(vi)

No active hydraulic structures are associated with this BGS Ash Seal Pond. The abandoned discharge pipe is completely filled with concrete and the June 20, 2016 pipe inspection showed no signs of deterioration, deformation, or distortion.

3.1.7 Sudden Drawdown - §257.73(d)(1)(vii)

A Mississippi River flood of 100 year elevation will rise to the crest elevation of the south embankment. Rise of the flood on the Mississippi River is often rapid, but drawdown is slower. In the event of drawdown, drainage would occur through the sandy base of the dam, but not through the dam embankment that is mainly clay. Some sand intervals in the embankment shown on the borings in Appendix B were sealed in 2007 by the



construction of a soil bentonite wall through the embankment to prevent seepage through the sand seams.

There are no factors that would result in slumping of the embankment toe as the flood recedes and the embankment has been exposed to multiple cycles of drawdown since construction that have not impacted the downstream slope.

3.2 BGS Main Ash Pond

The BGS Main Ash Pond was constructed in 1972 to replace the BGS Upper Ash Pond as the main receiver of CCR at the BGS. The impoundment was constructed on soft clay deposits in the backwater areas between the plant site and high ground to the west. The embankments are constructed of imported clay from a borrow site just west of the BGS. Borings and penetration tests taken in 2011 and presented in Appendices B, C, and D indicate that the embankment is low plasticity silty clay (CL). The underlying foundation of the embankment is a soft clay deposited in backwater flooding of the Mississippi. Beneath the soft clay is a medium dense sand layer common to the Mississippi River valley.

3.2.1 CCR Unit Foundation and Abutments - §257.73(d)(1)(i)

The foundation soils for the embankments are soft clay that is surcharged by the weight of the embankment soil. Below the clay is a medium dense sand layer that is typical of the Mississippi River valley. The embankment foundation is adequate to support the embankment and the contents of the CCR impoundment. The test results in Appendix D indicate that the foundation soils are low plasticity clay that is not subject to liquefaction during earthquake events. The foundation soils are adequate to support the embankments and the CCR as indicated in the Safety Factor Assessment Report.

3.2.2 Slope Protection - §257.73(d)(1)(ii)

The impoundment is incised on the north and east sides. The toe of the west embankment drains south and into the wetland area. The south embankment faces a large wetland classified by the U.S. Fish and Wildlife Service National Wetlands Inventory as a



“Freshwater Forested/Shrub Wetland” with Classification Codes: PF01A (135 acres) and PF01C (559 acres). The wetland area is nearly flat, where drainage flows east and ultimately ends up in the discharge channel for the facility where non-contact cooling water is released in a channel back to the Mississippi River. The crest of the embankments is approximately 12 feet wide and the downstream slope of the embankment varies between a 3:1 and 2:1 vegetated slope. Well established and managed vegetation will minimize surface erosion on both the upstream and downstream slopes. Additionally, storm water runoff is limited to the crest and downstream slope of the embankment, which limits the erosive force. Therefore the impoundment configuration protects against surface erosion.

Erosion due to wave action will have minimal impacts to the embankments as the 25 year flood event or greater of the Mississippi River will cause backwater to approach the embankments.

Sudden drawdown is addressed in Section 3.2.7.

3.2.3 CCR Embankment Density- §257.73(d)(1)(iii)

The embankment soil is silty clay typical of the surrounding uplands and as shown by the data in Appendix C and has adequate density to support the pressures from the CCR contents of the impoundments.

3.2.4 Vegetation Management - §257.73(d)(1)(iv)

Historically vegetation management has been conducted on a periodic basis. At the time of the initial Annual Inspection in October 2015, the upstream and downstream slopes of could not be properly inspected due to the presence of dense/tall brush and woody vegetation along the entire slope. Since the Annual Inspection, the facility has removed woody vegetation, including mature trees, from the embankment and has managed the remaining grassy vegetation to facilitate effective inspections. The facility plans to continue managing the grassy vegetation on the embankments at a height that facilitates effective inspections.



3.2.5 Spillway Management - §257.73(d)(1)(v)

The BGS Main Ash Pond is equipped with two 15 inch diameter corrugated steel culverts to drain process water and storm water under the plant access road at the northwest corner of the impoundment, Figure 2. The culverts are constructed of non-erodible material and designed to carry sustained flows.

The culverts are checked for malfunction (e.g., blockages, deformations) during the weekly inspections by the facility personnel.

This impoundment currently has a hazard potential classification of “Significant,” which in turn requires an evaluation of the impacts of a 1,000 year rainfall event. The Inflow Flood Control Plan, which is a separate document developed to comply with §257.82, shows that the precipitation from this event will drain through the culverts without overtopping the embankments of the impoundment. The freeboard at peak flow will be approximately 8 inches.

3.2.6 Hydraulic Structures - §257.73(d)(1)(vi)

The discharge structures from the BGS Main Ash Pond are comprised of two 15-inch diameter corrugated metal culverts with identical invert elevation under the generating plant entrance road. On June 20, 2016 the pipes were inspected using remote camera video inspection. The inspection showed that there was minimal deterioration, deformation, distortion, sedimentation, debris, and no bedding deficiencies were observed.

3.2.7 Sudden Drawdown - §257.73(d)(1)(vii)

The south embankment of the BGS Main Ash Pond is subject to the rise and fall of flood water from the Mississippi River as high as the crest of the embankment. These water elevations have occurred during major floods of the Mississippi River at least four times since construction of the impoundment¹ and many smaller river floods have created sudden drawdown conditions on the embankment.

¹ Records of the United States Army Corps of Engineers for Pool 19 of Mississippi River.
Interstate Power and Light Company – Burlington Generating Station
Structural Stability Assessment
August 25, 2016



The embankments and the subsurface are both soft to medium stiff low plasticity clay and there no rapid drawdown impacts to the embankment outer slopes.

3.3 BGS Economizer Pond

The BGS Economizer Pond is constructed on top of the southern part of the BGS Upper Ash Pond. It was constructed by raising the clay embankment of the BGS Upper Ash Pond on the south and east sides of the impoundment and by building a clay embankment on top of the CCR in the BGS Upper Ash Pond on the west side and the western end of the north side of the impoundment. On the eastern end of the north side of the impoundment, the embankment on top of the CCR in the BGS Upper Ash Pond is constructed entirely of CCR.

The BGS Economizer Pond has received both economizer ash and fly ash, but is presently used only for settling and recovery of economizer ash. The impoundment is actually a piled CCR embankment with surface water only on the southern edge of the impoundment where there is a clay embankment. The northern slope of the embankment has a toe that sits on CCR in the BGS Upper Ash Pond and was regraded in 2011 to have a flat slope of 5 horizontal to 1 vertical to limit the effects of poor embankment foundation soils.

Soil borings, penetration tests and laboratory tests on the impoundment embankments or slopes are shown in Appendices B, C and D. The boring locations are shown on Figure 3. The results indicate clay embankments and native clays that are classified as soft to medium stiff low plasticity clay (CL) and CCR with friction angles from 30 to 34 degrees. The CCR is very loose to medium dense cohesionless soil. The layer density varies in the unsaturated parts of the embankment (likely from cementation). The bottom ten feet of the CCR is saturated by the water in the BGS Upper Ash Pond and is very loose to loose.

3.3.1 CCR Unit Foundation and Abutments - §257.73(d)(1)(i)

The saturated very loose CCR in the north embankment of the BGS Upper Ash Pond is potentially an unstable foundation under earthquake loading conditions. The native clay



soils are a stable foundation where present. The analysis completed in the Safety Factor Assessment Report, §257.73(b), indicates that the foundation soils would likely liquefy during the design earthquake with a 2500 year return period.

In the event of liquefaction, the foundation soils would allow the embankment to slump and spread north into the BGS Upper Ash Pond during the strong motion part of the earthquake that would last approximately 30 seconds. At the end of the shaking, the residual strength of the foundation would be adequate to arrest further movement. Since the only water in the impoundment is far south of the slope, the release of water across the slope to the north instead of through the designed discharge at the west end of the impoundment is unlikely.

3.3.2 Slope Protection - §257.73(d)(1)(ii)

The economizer embankment is approximately 13 feet above the surrounding grade. The side slopes are vegetated and vary from 2:1 to 5:1. Well established and managed vegetation will minimize erosion on both the upstream and downstream slopes. Additionally, the storm water runoff is limited to the crest and downstream slope of the embankment, which limits the erosive force. Therefore the impoundment configuration protects against surface erosion.

The economizer embankment is located where the embankments will likely not be inundated by water which eliminates the potential for wave erosion.

Sudden drawdown is addressed in Section 3.3.7.

3.3.3 CCR Embankment Density- §257.73(d)(1)(iii)

The constructed clay embankments are soft to medium stiff low plasticity clay and have adequate strength to contain the CCR contents. The dry parts of the embankment constructed of CCR is loose to medium dense and cemented in certain layers. It will not move unless the foundation layers below the water table displace as described in 3.3.1. The strength of the embankments are acceptable as shown in the Safety Factor Assessment Report.



3.3.4 Vegetation Management - §257.73(d)(1)(iv)

Historically vegetation management has been conducted on a periodic basis. At the time of the initial Annual Inspection in October 2015, the downstream slope of the west embankment of the BGS Economizer Pond could not be properly inspected due to the presence of dense/tall grassy vegetation along the bottom third (1/3) of the slope. The rest of the embankments were found to have adequately managed vegetation. Since the Annual Inspection, the facility has maintained the vegetation to facilitate effective inspections. The facility intends to continue maintaining the vegetation in a manner that facilitates effective inspections.

3.3.5 Spillway Management - §257.73(d)(1)(v)

The impoundment receives approximately 1.5 cfs of process water flow from the BGS and storm water from the BGS plant site. Both sources of water are pumped to the top of the embankment. The pumped storm water is limited by the capacity of the pumps and if the water is not lifted to the embankment it will accumulate on the plant site and under emergency conditions will surface drain to the east end of the BGS Upper Ash Pond.

The process water that is pumped to the top of the embankment passes through a small settling impoundment to remove the economizer ash and then by an open channel to an 18 -inch diameter HDPE discharge pipe at the west end of the embankment. Storm water is discharged directly to the open channel and passes through the same discharge pipe. During storms where both storm water pumps are running, the primary discharge pipe flows full and an emergency 12-inch diameter steel discharge pipe will pass a part of the remaining flow. Therefore, in extreme events where two pumps run for an extended time, the water could overflow the embankment at the west end where the embankment height is one foot lower, which would act as an emergency spillway. The HDPE and steel pipes are constructed of non-erodible materials and designed to carry sustained flows.

This impoundment currently has a hazard potential classification of "Significant," which in turn requires an evaluation of the impacts of a 1,000 year rainfall event of 10.3 inches.

The Inflow Flood Control Plan, which is a separate document developed to comply with



§257.82, shows that the 1,000 year event would cause both the primary and secondary spillway pipes to flow at capacity and that that water would overflow down the embankment emergency spillway. The duration of the emergency spillway flow would be approximately 1 hour at a discharge total of 0.33 acre-foot.

During the duration of the overflow, it is likely that the non-erosive velocities would be exceeded. Maintenance of the spillway would likely be required after the event to restore erosion of the spillway. Flow over the emergency spillway that erodes or transports CCR would likely be contained within the BGS Upper Ash Pond.

The pipes are checked for malfunction (e.g., blockages, deformations) during the weekly inspections by the facility personnel.

3.3.6 Hydraulic Structures - §257.73(d)(1)(vi)

The discharge structures from the BGS Economizer Pond are comprised of two 18-inch HDPE pipes and one 12-inch steel pipe. On June 20, 2016 the pipes were inspected using remote camera video inspection. The inspection showed that there was minimal deterioration, deformation, distortion, sedimentation, debris, and no bedding deficiencies were observed.

3.3.7 Sudden Drawdown - §257.73(d)(1)(vii)

The BGS Economizer Pond is not subject to flood rise and fall on the toe of the embankment. The only variation is the change in ground water elevation in the embankment as the BGS Upper Ash Pond rises from its normal operation elevation of 528 to 530.5 feet during flood flow conditions. Therefore the outer embankments slopes are not subject to rapid drawdown conditions.

3.4 BGS Upper Ash Pond

The BGS Upper Ash Pond was constructed of imported clay embankment placed over natural clay and sand deposited by the Mississippi River. Test borings locations on the BGS Upper Ash Pond are shown on Figure 3. The boring results and laboratory test results are presented in Appendices B, C, and D.



The embankment soil is a low plasticity clay (CL) of medium stiff consistency. The native clay under the embankment is soft and the sand below the clay is medium dense.

Water enters the impoundment in the southwest corner and exits at an overflow flume at the northeast corner. The flume discharges into a manhole with a 15 inch diameter PVC discharge pipe which carries the water to the Lower Pond. The impoundment also contains a 14-inch diameter steel secondary overflow pipe that has a manual valve at the discharge end of the pipe.

3.4.1 CCR Unit Foundation and Abutments - §257.73(d)(1)(i)

The foundation soils are clays and sands deposited by the Mississippi River. The clay and sand strength is adequate to support the embankment, as discussed in the Safety Factor Assessment.

3.4.2 Slope Protection - §257.73(d)(1)(ii)

Both the upstream and downstream slopes of the embankment and the crest are covered with gravel and rip-rap to allow overtopping of the embankment by flood waters of the Mississippi River. The crest elevation of 531 feet on the embankment creates overtopping whenever the Mississippi River flood elevation exceeds the 25 year return event. Additionally, storm water runoff is limited to the crest and downstream slope of the embankment, which limits the erosive force. Therefore the impoundment configuration protects against surface erosion.

The BGS Upper Pond rip-rap protects against erosion from wave action.

Sudden drawdown is addressed in Section 3.4.7.

3.4.3 CCR Embankment Density- §257.73(d)(1)(iii)

The clay embankment is medium stiff clay and is stronger than the foundation soils. The strength of the embankments are acceptable as shown in the Safety Factor Assessment Report.



3.4.4 Vegetation Management - §257.73(d)(1)(iv)

Vegetation management is not required on the north embankment of the impoundment as the upstream and downstream slopes of the embankment are covered with gravel and rip-rap. At the time of the initial Annual Inspection in October 2015, the upstream and downstream slope of the south end of the west embankment of the BGS Upper Ash Pond could not be properly inspected due to the presence of dense grassy vegetation. Since the Annual Inspection, the facility has managed the vegetation to facilitate effective inspections, and the facility intends to continue managing the vegetation to facilitate effective inspections.

3.4.5 Spillway Management - §257.73(d)(1)(v)

The BGS Upper Pond discharge structure is equipped with a 24-inch wide precast concrete Parshall flume that discharges into a concrete catch basin. The water in the catch basin flows through a 15-inch diameter polyvinyl chloride pipe and discharges into the BGS Lower Pond. The pipes are constructed of non-erodible materials and designed to carry sustained flows.

The pipes are checked for malfunction (e.g., blockages, deformations) during the weekly inspections by the facility personnel.

This impoundment currently has a hazard potential classification of "Significant," which in turn requires an evaluation of the impacts of a 1,000 year rainfall event. The Inflow Flood Control Plan, which is a separate document developed to comply with §257.82, shows that the precipitation from this event will drain through the Parshall flume without overtopping the embankments of the impoundment. The freeboard at peak flow will be approximately 9 inches. The Inflow Flood Control Plan indicates a peak flow of 9.2 cfs with a storage of 30 acre feet during the flood.

3.4.6 Hydraulic Structures - §257.73(d)(1)(vi)

The discharge structure from the BGS Upper Ash Pond are comprised of one 15-inch PVC pipes and one 15-inch emergency overflow pipe. On June 20, 2016 the pipes were inspected using remote camera video inspection. The inspection showed that there was



minimal deterioration, deformation, distortion, sedimentation, debris, and no bedding deficiencies were observed.

3.4.7 Sudden Drawdown - §257.73(d)(1)(vii)

The embankment and its foundation is constructed of clay and is not subject to rapid drawdown impacts on the outside toe. The embankment is flooded at the toe on numerous occasions each year without detrimental effect.



4 QUALIFIED PROFESSIONAL ENGINEER CERTIFICATION

To meet the requirements of 40 CFR 257.73(d)(3), I Mark W. Loerop hereby certify that I am a licensed professional engineer in the State of Iowa; and that, to the best of my knowledge, all information contained in this document is correct and the document was prepared in compliance with all applicable requirements in 40 CFR 257.73(b) and 40 CFR 257.73(d).



By: 

Name: MARK LOEROP

Date: 8-25-2016



FIGURES


Alliant Energy
Interstate Power and Light Company
Burlington Generating Station
Burlington, Iowa

Structural Stability Assessment





Historical Topo Map

2012, 2013



This report includes information from the following map sheet(s).




TP, Lomax, 2012, 7.5-minute
 NE, Burlington, 2013, 7.5-minute
 SW, Dallas City, 2012, 7.5-minute
 NW, West Burlington, 2013, 7.5-minute


SITE NAME: Burlington Generating Station
 ADDRESS: 4282 Sullivan Slough Road
 Burlington, IA 52601
 CLIENT: Environmental Site Assessors




Historical Aerial Photo 6/12/2014




----- Approximate Property Boundary



LEGEND:
 PROCESS TRANSPORT WATER, PLANT AREA RUNOFF, AND DIRECT RAINFALL FLOW DIRECTION

SOURCE:
 2008 TOPOGRAPHY WITH 2011 TOPOGRAPHY FOR ECONOMIZER POND.



NOTICE
 THIS DRAWING IS THE PROPERTY OF HARD HAT SERVICES AND IS NOT TO BE REPRODUCED, CHANGED, OR COPIED IN ANY FORM OR MANNER WITHOUT PRIOR WRITTEN PERMISSION. ALL RIGHTS RESERVED.

REV	DATE	BY	DESCRIPTION

SCALE: AS SHOWN DATE: 5-13-16
 DRAWN BY: JFD CHECKED BY: TJH APPROVED BY: MWL




HARD HAT SERVICES[™]
 Engineering, Construction and Management Solutions

CLIENT / LOCATION
 ALLIANT ENERGY
 BURLINGTON GENERATING STATION
 BURLINGTON, IOWA

DRAWING DESCRIPTION
 Structural Stability Analysis
 SITE PLAN

JOB 154.018.012.001
 SHT. FIGURE 1
 DWG. 154.018.012.001-D1



NOTICE
THIS DRAWING IS THE PROPERTY
OF HARD HAT SERVICES AND IS
NOT TO BE REPRODUCED,
CHANGED, OR COPIED IN ANY FORM
OR MANNER WITHOUT PRIOR
WRITTEN PERMISSION. ALL RIGHTS
RESERVED.

REV	DATE	BY	DESCRIPTION

SCALE: AS SHOWN DATE: 5-13-16
 DRAWN BY: JFD CHECKED BY: TJH APPROVED BY: MWL

HARD HAT SERVICES[™]
 Engineering, Construction and Management Solutions

CLIENT / LOCATION
 ALLIANT ENERGY
 BURLINGTON GENERATING STATION
 BURLINGTON, IOWA

DRAWING DESCRIPTION
 SOIL BORINGS, CPT, AND
 SLOPE STABILITY CROSS SECTION LOCATIONS


JOB 154.018.012.001
 SHT. FIGURE 2
 DWG. 154.018.012.001-02

APPENDIX A – Deep Soil Borings

Alliant Energy
Interstate Power and Light Company
Burlington Generating Station
Burlington, Iowa

Structural Stability Assessment





	No. 1	No. 2	No. 3	No. 4	No. 5	No. 6	No. 7	No. 8	No. 9
105	ELEV. 99.8	ELEV. 97.7	ELEV. 98.4	ELEV. 99.1	ELEV. 98.7	ELEV. 97.4	ELEV. 100.4	ELEV. 98.7	ELEV. 98.1
100	BROWN AND GREY SILT AND CLAY 11 3'0"	GREY 3 0'0"	BROWN SILTY CLAY 3 3'0"	SILT 2 8'0"	GREY 5 0'0"	GREY 2 0'0"	BROWN SILT TRACE CLAY 5 0'0"	BROWN SILTY CLAY 3 3'0"	BROWN SILTY CLAY 2 2'8"
95	BROWN SILTY FINE SAND 2 8'0"	SILT 2 0'0"	GREY SILTY CLAY 4 7'10"	FINE GREY SAND SILTY 5 9'6"	SILT 6 0'0"	SILT 2 0'0"	GREY SILTY CLAY 7 9'0"	GREY & BROWN SILTY CLAY 2 7'8"	GREY & BROWN SILTY CLAY 2 7'0"
90	BROWN & GREY SILTY FINE SAND 4 11'0"	CLAY 2 12'0"	GREY AND BROWN SILTY FINE SAND 4 8'0"	COARSE BRN SAND SILTY SILTY 22 13'0"	CLAY 3 11'6"	CLAY 2 10'6"	BROWN SILTY FINE SAND 11 13'0"	BROWN FINE MEDIUM AND COARSE SAND 11 12'0"	BRN SILTY SAND 2 8'6"
85	GREY FINE AND MEDIUM SAND 4 28'0"	GREY FINE MEDIUM TO COARSE SAND 8 17'0"	BROWN SILTY FINE SAND 11 33'0"	FINE 5 15'0"	GREY FINE 10 3'0"	GREY FINE 5 5'0"	GREY SILTY FINE SAND 11 17'0"	BROWN FINE MEDIUM AND COARSE SAND TRACE SILTY 3 11'6"	SAND MORE DENSE 8 9'0"
80	GREY FINE AND MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 4 33'0"	GREY FINE SAND 7 6 23'6"	GREY AND BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	TO 15 16'0"	TO 15 16'0"	TO 11 11'0"	FINE 7 9'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 6 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
75	SAME 13 33'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	COARSE 13 13'0"	COARSE 13 13'0"	COARSE 10 10'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
70	SAME 11 33'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
65	MOORE 11 33'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
60	DENSE 16 48'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
55	GREY FINE TO MEDIUM SAND 3 48'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
50	GREY FINE TO MEDIUM SAND 3 48'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
45	GREY FINE TO MEDIUM SAND 3 48'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
40	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 55'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
35	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 55'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
30	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 55'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
25	BROWN COARSE SAND TRACE FINE TO MEDIUM SAND 11 88'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
20	BROWN COARSE SAND TRACE FINE TO MEDIUM SAND 11 88'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
15	BROWN COMPACT FINE TO MEDIUM SAND TRACE SMALL GRAVEL 34 84'6"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
10	COMPACT SILTY WITH SMALL GRAVEL 52 88'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
5	SAME 100 88'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
0	MOORE 100 88'0"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"
0	DENSE 100/10 36'10"	GREY FINE SAND 3 27'0"	BROWN FINE MEDIUM TO COARSE SAND TRACE SMALL GRAVEL 6 27'0"	GREY 14 14'0"	GREY 14 14'0"	GREY 5 5'0"	GREY SILTY FINE SAND TRACE MICA 8 32'0"	GREY FINE MEDIUM TO COARSE SAND TRACE SILTY 3 17'6"	GREY SILTY FINE TO MEDIUM SAND TRACE SILTY 3 17'6"

1/25/62 1/27/62 1/31/62 1/10/62 1/15/62 1/22/62 2/1/62 2/2/62 2/5/62

FIGURES IN RIGHT HAND COLUMN SHOWN AS FRACTIONS - NUMERATOR - No. OF BLOWS DENOMINATOR - DEPTH IN INCHES

† INDICATES WASH SAMPLE RECOVERED

CLASSIFICATIONS ARE MADE BY VISUAL INSPECTION. FIGURES IN RIGHT HAND COLUMN INDICATE NUMBER OF BLOWS REQUIRED TO DRIVE 2" O.D. SAMPLING PIPE ONE FOOT, USING 140-LB. WEIGHT FALLING 30 INCHES.

REFERENCES:
 SEE D-461 FOR BORING LOCATIONS.
 TEST BORING REPORT - FEBRUARY 13, 1962.
 RAINING CONCRETE PILE COMPANY, 60th DIVISION, JED. NO. CA-988-100 SHEETS 1 THROUGH 8.

IOWA SOUTHERN UTILITIES CO.
 DENTONVILLE, IOWA

PROPOSED BURLINGTON PLANT SITE
 TEST BORING REPORTS

SCALE 1"=8' DEPTH DATE 3-15-62
 SKETCH BY: DWH TRCD LLCHKO
 D-487 APPROVED



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-2**

LOGGED BY LES

PAGE No. 1 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 534.13
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/11/2008 FINISH 12/12/2008

DEPTH	SAMPLE			BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CONPTTACT	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
				INTERVAL (ft)		0"	6"							
	No.	FROM	TO	6"	12"	18"	24"							
														Frozen ground
5	SS-1	2.0	4.0	2	3	4	4	14.0	0.75	4'3"	529.88	CL	Black and brown mottled SILTY CLAY, little fine to medium sand, medium plasticity, medium stiff, wet	
	SS-2	4.0	6.0	1	6	5	3	17.0					Grey SILT, trace fine sand, medium dense, moist	
	SS-3	6.0	8.0	1	8	15	7	17.5				medium dense		
	SS-4	8.0	10.0	1	6	50/5		18.0				very dense		
10														
15	SS-5	13.0	15.0	1	1	1	1	13.0	49	0.75	13'5"	520.71	CH	Dark brown and black mottled CLAY, trace silt, high plasticity, medium stiff, wet
														soft (LL=52, PI=27)
20									48	0.25 0.50	23'6"	510.63	SP	
25	SS-6	18.0	20.0	2	2	3	3	15.0						
30	SS-7	23.0	25.0	4	5	7	12	20.0						Brown fine to medium SAND, medium dense, wet
														brownish-grey
35	SS-8	28.0	30.0	3	12	17	18	9.0						
40	SS-9	33.0	35.0	8	10	11	12	11.5						
														some coarse sand and wood pieces
	SS-10	38.0	40.0	7	7	10	12	10.0						

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-2**

LOGGED BY LES

PAGE No. 2 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 534.13
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/11/2008 FINISH 12/12/2008

DEPTH	SAMPLE		BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CORRECTION	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
			INTERVAL (ft)		0"	6"							
	No.	FROM	TO	6"	12"	18"	24"						
45	SS-11	43.0	45.0	3	6	12	14	15.5			SP	Brownish-grey fine to medium sand, some coarse sand, medium dense, wet (cont.) 2" of black silt at 44'1"	
50	SS-12	48.0	50.0	6	7	8	12	16.0		46'6"	487.63	SW	Brownish-grey fine to coarse SAND, medium dense, wet
55	SS-13	53.0	55.0	10	11	12	19	21.0					
60	SS-14	58.0	60.0	15	22	32	42	24.0		60'	474.13		medium to coarse sand, trace fine sand and fine gravel, very dense
65													EOB 60' - Sand was causing hole to collapse and would have needed to be cased to 60' to continue.
70													
75													
80													

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry

BORING LOG



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

PROJECT No. 154.002.008.001
 BORING No. BH-B-1 (BH-3)
 LOGGED BY LES
 PAGE No. 1 of 2

PROJECT NAME Alliant Energy - Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa
 DRILLER RDnP Drilling - Chris DATE: START 7/15/2008 FINISH 7/21/2008

DEPTH	SAMPLE		BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CD O E N T T A H C T	USCS SOIL TYPE	SOIL DESCRIPTION		
			INTERVAL		0"	6"							12"	18"
	No.	FROM	TO	6"	12"	18"	24"							
5	SS-1	0.0	2.0	5	10	10	12	12	23		FILL	Brown and black silty clay FILL, medium dense, dry		
	SS-2	2.0	4.0	10	11	11	15	9.5				2.0	Coarse sand and fine gravel FILL, trace grey fines, medium dense, dry	
	SS-3	4.0	6.0	5	10	2	2	10				4.0	some silt	
	SS-4	6.0	8.0	1	10	16	12	22				6.0	Grey-black sand and gravel FILL with silt, medium dense wet.	
	SS-5	8.0	10.0	6	10	22	32	24				24	10.0	
10	SS-6	10.0	12.0	3	8	3	2	14	50		ML	Grey sandy SILT, trace coarse sand, loose, saturated		
	SS-7	12.0	14.0	1	0	1	0	18				50	Grey SILT, little fine sand, very loose, saturated	
15	SS-8	14.0	16.0	Rod Weight				17	33			ML	trace low plasticity clay, trace fine sand	
20	SS-9	18.0	20.0	1	1	1	1	16	22'6"			CL	Dark grey SILTY CLAY, trace fine sand, medium to high plasticity, soft, wet	
25	SS-10	23.0	25.0	1	2	2	1	18	26.5				SP	Grey fine to medium grained SAND, trace coarse sand, very loose, saturated
30	SS-11	28.0	30.0	1	0	0	0	3	18					
35	SS-12	33.0	35.0	5	8	12	14	11	13					
40	SS-13	38.0	40.0	8	10	11	12	11						

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry

BORING LOG



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

PROJECT No. 154.002.008.001
 BORING No. BH-B-1 (BH-3)
 LOGGED BY LES
 PAGE No. 2 of 2

PROJECT NAME Alliant Energy - Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa
 DRILLER RDnP Drilling - Chris DATE: START 7/15/2008 FINISH 7/21/2008

DEPTH	SAMPLE			BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CD OE NT TT AH CT	USCS SOIL TYPE	SOIL DESCRIPTION
	No.	INTERVAL		0"	6"	12"	18"						
		FROM	TO	6"	12"	18"	24"						
45	SS-14	43.0	45.0	5	10	14	22	11	15		SP	Grey fine to medium SAND, trace coarse sand, medium dense, saturated	
50	SS-15	48.0	50.0	9	14	16	16	12					
55	SS-16	53.0	55.0	8	12	14	15	11					
60	SS-17	58.0	60.0	10	11	18	24	10	13		SP	several pieces of coarse grained gravel at 58.5'	
65	SS-18	63.0	65.0	15	24	26	36	10					
70	SS-19	68.0	70.0	32	32	38		12					
75	SS-20	73.0	75.0	32	75/3			4	9		SW	dense	
80	SS-21	78.0	80.0	50	100/3			4					
									8		GP	66.5	Grey fine to coarse SAND and fine grained gravel, very dense, saturated
												76.5	Fine GRAVEL with fine to coarse sand, very dense, saturated
												79.5	Spoon bounced at 79.5'
												EOB at 80'	

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-4**

LOGGED BY LES

PAGE No. 1 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 534.43
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/2/2008 FINISH 12/3/2008

DEPTH	SAMPLE		BLOW COUNTS				REC (in)	WC (%)	qu (TSF)	C O E P T T A H C T	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION		
			INTERVAL (ft)		0"	6"								12"	18"
	No.	FROM	TO	6"	12"	18"	24"								
												Frozen ground			
5	SS-1	2.0	4.0	3	4	5	15	16.0	6'6"	527.93	FILL	Black and brown silty clay FILL, some fine sand, dry			
	SS-2	4.0	6.0	9	8	11	12	17.0				Black and brown fine to coarse sand and fine gravel FILL, trace fines, wet			
	SS-3	6.0	8.0	10	5	12	15	20.0							
	SS-4	8.0	10.0	2	2	3	20	24.0				ML Grey SILT, little fine sand, medium dense, saturated loose 4" fine sand seam at 9'6"			
10										11'6"	522.93	CL	Grey SILTY-CLAY, trace fine sand, medium plasticity, soft, moist to wet		
	SS-5	13.0	15.0	2	2	3	4	14.0					50	2.00	
15										18'4"	516.10	SP	Grey-brown fine to coarse SAND, medium dense, wet		
	SS-6	18.0	20.0	7	9	8	11	15.0						18	
	SS-7	23.0	25.0	10	11	15	15	12.0							
20											36'6"	497.93	SW	trace fine gravel	
	SS-8	28.0	30.0	6	10	12	14	11.0	19						
25									36'6"		497.93	SW	Brown fine to coarse SAND, little fine gravel, trace silt, medium dense, wet		
	SS-9	33.0	35.0	6	7	9	11	11.0							
30															
	SS-10	38.0	40.0	7	9	7	10	10.0							
35															
40															

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-4**

LOGGED BY LES

PAGE No. 2 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 534.43
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/2/2008 FINISH 12/3/2008

DEPTH	SAMPLE		BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CD O E P T T A H	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
			INTERVAL (ft)		0"	6"							
	No.	FROM	TO	6"	12"	18"	24"						
45	SS-11	43.0	45.0	5	6	6	8	11.0	14			(cont.) Brown fine to coarse SAND, little fine gravel, medium dense, wet	
50	SS-12	48.0	50.0	12	12	16	19	10.0					
55	SS-13	53.0	55.0	8	9	11	14	12.0	13		SW		
60	SS-14	58.0	60.0	10	8	10	13	12.0				very dense	
65	SS-15	63.0	65.0	18	21	32	50/5	16.0	11				
70	SS-16	68.0	70.0	21	32	42	44	24.0	+4.5	64'6"	469.93	CL	Grey silty CLAY, trace fine sand, medium plasticity, hard, wet
75	SS-17	73.0	75.0	10	17	22	23	20.0	25	75'	459.43		EOB 75'
80													

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-5**

LOGGED BY LES

PAGE No. 1 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation

BORING LOCATION Burlington, Iowa

SURFACE ELEVATION 534.71

DRILLER RDnP Drilling - Kris Norwick

DATE: START 12/4/2008

FINISH 12/5/2008

DEPTH	SAMPLE		BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CORRECTION	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
			INTERVAL (ft)		0"	6"							
	No.	FROM	TO	6"	12"	18"	24"						
												Frozen ground	
5	SS-1	2.0	4.0	15	19	22	23	12.0				FILL	Black and brown sand and gravel FILL, some fines, wet
	SS-2	4.0	6.0	10	19	34	50/3	16.0					Brown-grey silt with sand FILL
	SS-3	6.0	8.0	32	32	22	8	18.0					6" brown-red fine to coarse sand FILL
	SS-4	8.0	10.0	9	12	23	14	20.0					
10	SS-5	10.0	12.0	1	2	4	1	24.0		10'	524.71	ML	Grey SILT, little fine sand, loose, wet
15	SS-6	13.0	15.0	1	1	2	3	21.0	36	13'	521.71	CL	Mottled green, black, and light grey SILTY CLAY, little fine sand, trace silt and wood pieces, medium stiff, wet
20	SS-7	18.0	20.0	2	2	3	3	13.0	34			CL	
25	SS-8	23.0	25.0	5	7	7	9	14.5		23'2"	511.54	SP	Black and brown fine to medium SAND, trace coarse sand, medium dense, wet 23'7" grey
30	SS-9	28.0	30.0	3	4	6	7	13.0	19			SP	
35	SS-10	33.0	35.0	7	7	9	11	12.0				SP	
40	SS-11	38.0	40.0	7	10	11	14	14.0	22			SP	5" fine sand seam 2" coarse sand and fine gravel seam

Drilled with Dietrich -120

Method: auger and mud rotary

Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-5**

LOGGED BY LES

PAGE No. 2 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 534.71
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/4/2008 FINISH 12/5/2008

DEPTH	SAMPLE		BLOW COUNT				REC (in)	WC (%)	qu (TSF)	C O E P T T A H C T	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
			INTERVAL (ft)		0"	6"							
	No.	FROM	TO	6"	12"	18"	24"						
45	SS-12	43.0	45.0	12	15	22	26	13.5				(cont.) Grey fine to medium SAND, trace coarse sand, wet dense	
50	SS-13	48.0	50.0	10	12	12	15	12	17		SP	medium dense	
55	SS-14	53.0	55.0	5	15	21	15	13				dense, 53'6" - 1" gravel piece	
60	SS-15	58.0	60.0	6	8	11	15	10	12	58'7"	476.13	SP	medium dense
65	SS-16	63.0	65.0	50/0				0				SW	Grey fine to coarse SAND, some fine gravel, very dense (rig was grinding heavily to get from 65' to 68')
70	SS-17	68.0	70.0	50/4				4		70'	464.71		EOB 70'
75													
80													

Drilled with Dietrich -120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. BH-6

LOGGED BY LES

PAGE No. 1 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation

BORING LOCATION Burlington, Iowa

SURFACE ELEVATION 534.33

DRILLER RDnP Drilling - Kris Norwick

DATE: START 12/4/2008

FINISH 12/5/2008

DEPTH	SAMPLE			BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CORRECTION	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
				INTERVAL (ft)		0"	6"							
	No.	FROM	TO	6"	12"	18"	24"							
														Frozen ground
5	SS-1	2.0	4.0	10	11	15	17	17.0					FILL	Brown silty sand FILL, trace medium sand, medium dense (possibly gravel inhibiting sampling)
	SS-2	4.0	6.0	1	3	5	11	13.0						
	SS-3	6.0	8.0	50/5				7.5						
	SS-4	8.0	10.0	41	50/3			5.5						
10	SS-5	10.0	12.0	3	2	1	4	20.0	49		10'	524.33	ML	Brownish-grey SILT, trace fine sand, very loose, saturated loose
	SS-6	13.0	15.0	3	4	4	5	24.0	53					
											16'6"	517.83		Brownish-grey SILTY CLAY, trace fine sand, soft, wet
20	SS-7	18.0	20.0	1	1	1	2	17.0	49	0.50			CL	
25	SS-8	23.0	25.0	1	3	4	5	16.0			24'	510.33	SP	Brown fine to medium SAND, trace coarse sand, medium dense, wet
30	SS-9	28.0	30.0	6	7	9	11	15.5	18				SW	Brown fine to coarse SAND, little fine gravel, medium dense, wet
35	SS-10	33.0	35.0	10	11	14	14	12.0			36'6"	497.83		
40	SS-11	38.0	40.0	6	8	9	12	12.5	9					

Drilled with Dietrich-120

Method: auger and mud rotary

Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-6**

LOGGED BY LES

PAGE No. 2 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 534.33
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/4/2008 FINISH 12/5/2008

DEPTH	SAMPLE		BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CD OE NP TT AH CT	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
			INTERVAL (ft)		0"	6"							
	No.	FROM	TO	6"	12"	18"	24"						
45									42' 6"	491.83	SW	Brown fine to coarse SAND, little fine gravel, medium dense, wet (cont.)	
	SS-12	43.0	45.0	8	10	14	17	12.0					
50									14		SP	little coarse sand	
	SS-13	48.0	50.0	8	9	12	14	12.0					
55									14		CL	Grey SILTY CLAY, little fine to medium sand, medium plasticity, hard, wet 1" fine to medium sand seam at 63'6" 1" gravel piece at 6'8"	
	SS-14	53.0	55.0	10	17	17	15	12.5					
60									14				
	SS-15	58.0	60.0	10	12	14	14	10.0					
65									14	4.5+ 4.5+			
	SS-16	63.0	65.0	17	31	36	42	22.0					
70									4.5+	70'	464.33	EOB 70'	
	SS-17	68.0	70.0	21	50/3			9.0					
75													
80													

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-7**

LOGGED BY LES

PAGE No. 1 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 536.51
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/5/2008 FINISH 12/8/2008

DEPTH	SAMPLE			BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CONPTTACT	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
	No.	INTERVAL (ft)		0"	6"	12"	18"							
		FROM	TO	6"	12"	18"	24"							
														Frozen ground
5	SS-1	2.0	4.0	6	7	10	12	22.5	1.00 0.75	6'	530.51	FILL	Black sand, gravel, and silt FILL 6" alternating brown and black fine sand and silt at 3' 6" grey clay, medium stiff, moist at 4'	
	SS-2	4.0	6.0	1	3	10	14	15.0						
	SS-3	6.0	8.0	10	31	21	33	18.0						
10	SS-4	8.0	10.0	15	21	18	15	17.0	67	16'6"	520.01	ML	Dark grey SILT, some fine sand, very dense, wet trace fine sand loose	
	SS-5	10.0	12.0	10	22	32	44	21.0						
	SS-6	13.0	15.0	3	4	1	5	23.0						
20	SS-7	18.0	20.0	1	2	1	2	24.0	19	23'6"	513.01	CL	Grey SILTY CLAY, trace fine sand, very soft, wet	
	SS-8	23.0	25.0	1	2	4	12	16.0						
	SS-9	28.0	30.0	2	5	8	8	18.0						
35	SS-10	33.0	35.0	8	14	16	15	12.0	17	26'6"	510.01	SP	Grey fine to medium SAND with clay, loose, wet	
	SS-11	38.0	40.0	8	14	10	8	12.0						

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. BH-7

LOGGED BY LES

PAGE No. 2 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 536.51
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/5/2008 FINISH 12/8/2008

DEPTH	SAMPLE			BLOW COUNT				REC (in)	WC (%)	qu (TSF)	C O N T A C T	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
	No.	INTERVAL (ft)		0"	6"	12"	18"							
		FROM	TO	6"	12"	18"	24"							
45	SS-12	43.0	45.0	5	8	10	11	12.0	15					Grey fine to medium SAND, trace coarse sand medium dense, wet
50	SS-13	48.0	50.0	8	10	15	18	14.0					SP	Brown fine to coarse SAND, trace fine gravel, medium dense, wet
55	SS-14	53.0	55.0	10	12	15	16	10.0	15					very dense
60	SS-15	58.0	60.0	8	11	15	17	24.0					SW	EOB 65'
65	SS-16	63.0	65.0	18	23	50/4		10.0	7					
70														
75														
80														

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-8**

LOGGED BY LES

PAGE No. 1 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 534.72
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/15/2008 FINISH 12/17/2008

DEPTH	SAMPLE		BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CD O E P T T A C T	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
			INTERVAL (ft)		0"	6"							
	No.	FROM	TO	6"	12"	18"	24"						
												Frozen ground	
5	SS-1	2.0	4.0	8	12	10	12	18.0				FILL Brown and grey mottled silty clay FILL, little fine to coarse sand, medium dense, frozen fine gravel pieces mixed in clay	
	SS-2	4.0	6.0	3	4	6	6	16.0	1.75				
	SS-3	6.0	8.0	3	5	7	10	10.0					
	SS-4	8.0	10.0	3	4	6	9	15.0	17	2.50			
10	SS-5	10.0	12.0	4	5	7	4	14.0	23	3.00	10'6"	524.22	ML Grey SILT, trace fine sand, medium dense to loose, wet alternating silt and brown silty clay, stiff
	SS-6	13.0	15.0	2	3	3	3	8.0	26				
15													CL Grey SILTY CLAY, medium plasticity, medium stiff, moist to wet (LL=46, PI=24)
	SS-7	18.0	20.0	1	2	3	2	10.0	34	1.25	16'6"	518.22	
20													
25	SS-8	23.0	25.0	5	6	7	7	12.0			23'3"	511.47	SP Brown fine to medium SAND, loose, wet trace coarse sand
	SS-9	28.0	30.0	2	5	4	5	24.0	20				
30													
	SS-10	33.0	35.0	2	3	4	5	12.0					
35													
	SS-11	38.0	40.0	4	5	5	7	11.5	12				
40													

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-8**

LOGGED BY LES

PAGE No. 2 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 534.72
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/15/2008 FINISH 12/17/2008

DEPTH	SAMPLE		BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CD O N P T T A H C T	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
			INTERVAL (ft)		0"	6"							
	No.	FROM	TO	6"	12"	18"	24"						
45	SS-12	43.0	45.0	9	10	11	15	11.0				Brown fine to medium SAND, trace coarse sand, medium dense, wet (cont.)	
50	SS-13	48.0	50.0	14	17	9	7	13.0				SP	
55	SS-14	53.0	55.0	4	8	7	6	13.0		49'6"	485.22	Brown fine to coarse SAND, trace fine gravel, medium dense, wet	
60	SS-15	58.0	60.0	8	15	19	22	15.0				SW dense	
65	SS-16	63.0	65.0	5	15	24	26	17.0				little fine gravel	
70	SS-17	68.0	70.0	48	50/4			13.0		66'6"	468.22	CL Grey sandy SILTY CLAY, hard, moist to wet	
75										70'	464.72	EOB 70'	
80													

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-9**

LOGGED BY LES

PAGE No. 1 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 534.67
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/17/2008 FINISH 12/18/2008

DEPTH	SAMPLE		BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CONPTTACT	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
			INTERVAL (ft)		0"	6"							
	No.	FROM	TO	6"	12"	18"	24"						
												Frozen ground	
5	SS-1	2.0	4.0	3	4	2	2	14.0	8'11"	525.75	FILL	Grey and brown mottled silty clay FILL, some fine to medium sand, very stiff, moist Alternating grey, brown, and orange clay and silt	
	SS-2	4.0	6.0	3	4	6	5	17.0					
	SS-3	6.0	8.0	4	5	5	8	17.0					
	SS-4	8.0	10.0	4	5	10	10	17.0					
10	SS-5	10.0	12.0	5	7	9	12	16.0	13'	521.67	CL	Grey SILTY CLAY, trace fine sand, medium plasticity, very stiff, moist	
	SS-6	13.0	15.0	3	4	6	6	21.0					
20	SS-7	18.0	20.0	3	3	4	5	21.0	24'6"	510.17	CH	Dark grey CLAY, high plasticity, stiff, wet (LL=64, PI=34)	
	SS-8	23.0	25.0	5	6	8	9	0.0					
25									25	510.17	SP	(hole is taking a lot of water) Grey fine to medium SAND, medium dense, wet	
30	SS-9	28.0	30.0	8	10	12	14	10.0	25	510.17	SP	trace coarse sand, dense	
35	SS-10	33.0	35.0	8	15	19	22	16.0	18	510.17	SP	trace coarse sand, dense	
40	SS-11	38.0	40.0	10	16	17	19	11.0	18	510.17	SP	trace coarse sand, dense	

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. BH-9

LOGGED BY LES

PAGE No. 2 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION _____
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/17/2008 FINISH 12/18/2008

DEPTH	SAMPLE		BLOW COUNT				REC (in)	WC (%)	qu (TSF)	C O N T A C T	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION	
			INTERVAL (ft)		0"	6"								12"
	No.	FROM	TO	6"	12"	18"	24"							
45	SS-12	43.0	45.0	10	17	24	29	8.0					Grey fine to medium SAND, trace coarse sand, dense, wet trace fine gravel	
50	SS-13	48.0	50.0	8	16	20	21	12.0	17			SP		
55	SS-14	53.0	55.0	9	11	15	19	13.0						
60	SS-15	58.0	60.0	10	12	18	17	16.0	17	56'6"	478.17		Grey-brown fine to coarse SAND, trace fine gravel, dense, wet	
65	SS-16	63.0	65.0	12	15	24	26	15.0				SW	dense	
70	SS-17	68.0	70.0	37	50/4			10.0		66'6"	468.17		CL	Grey CLAY, little fine to medium sand, medium plasticity, hard, moist to wet
75										70'	464.67			EOB 70'
80														

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. **BH-10**

LOGGED BY LES

PAGE No. 1 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation

BORING LOCATION Burlington, Iowa

SURFACE ELEVATION 531.92

DRILLER RDnP Drilling - Kris Norwick

DATE: START 12/12/2008

FINISH 12/15/2008

DEPTH	SAMPLE			BLOW COUNT				REC (in)	WC (%)	qu (TSF)	CONPTTACT	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
	No.	INTERVAL (ft)		0"	6"	12"	18"							
		FROM	TO	6"	12"	18"	24"							
														Frozen ground
5	SS-1	2.0	4.0	4	5	5	4	13.0	17	2.00				Grey and brown mottled SILTY CLAY, trace fine sand, medium plasticity, stiff, moist little fine to coarse sand, very stiff
	SS-2	4.0	6.0	3	4	5	6	15.0	15	2.50				
	SS-3	6.0	8.0	4	4	5	6	15.0	13	2.50				
10	SS-4	8.0	10.0	3	6	8	8	15.0	24	2.50 1.50				
15	SS-5	13.0	15.0	1	2	3	4	15.0		0.75 1.00	13'	518.92		Dark grey CLAY, high plasticity, medium stiff, wet
20	SS-6	18.0	20.0	4	6	5	7	13.5		1.25				stiff
25	SS-7	23.0	25.0	3	4	5	5	6.0		1.00				
30	SS-8	28.0	30.0	8	9	11	12	0.0			29'	502.92		Grey-brown fine to medium SAND, medium dense, wet
35	SS-9	33.0	35.0	6	8	5	5	10.0						
40	SS-10	38.0	40.0	8	9	11	12	11.0						trace coarse sand

Drilled with Dietrich-120

Method: auger and mud rotary

Hole was backfilled with bentonite slurry



HARD HAT SERVICES™

Engineering, Construction and Management Solutions

BORING LOG

PROJECT No. 154.002.008.001

BORING No. BH-10

LOGGED BY LES

PAGE No. 2 of 2

PROJECT NAME Alliant Energy - December 2008 Baghouse Geotechnical Investigation
 BORING LOCATION Burlington, Iowa SURFACE ELEVATION 531.92
 DRILLER RDnP Drilling - Kris Norwick DATE: START 12/12/2008 FINISH 12/15/2008

DEPTH	SAMPLE			BLOW COUNT				REC (in)	WC (%)	qu (TSF)	C O N T A C T	ELEV. (MSL)	USCS SOIL TYPE	SOIL DESCRIPTION
	No.	INTERVAL (ft)		0"	6"	12"	18"							
		FROM	TO	6"	12"	18"	24"							
														Grey-brown fine to medium SAND, trace coarse sand, medium dense, wet (cont.)
45	SS-11	43.0	45.0	3	6	9	15	15.0						dense
50	SS-12	48.0	50.0	8	15	21	30	15.0						SP (spoon bouncing, possibly on a cobble or boulder)
55	SS-13	53.0	55.0	50/0				0.0						trace fine gravel
60	SS-14	58.0	60.0	14	17	17	15	16.0						
65	SS-15	63.0	65.0	50/1				0.0			64'	467.92		Grey CLAY, little fine sand, hard, moist to wet
70	SS-16	68.0	70.0	32	50/3			10.0	4.5+		70'	461.92		CL (spoon bouncing)
75														EOB 70'
80														

Drilled with Dietrich-120
 Method: auger and mud rotary
 Hole was backfilled with bentonite slurry

APPENDIX B – Geoprobe Soil Borings on CCR Embankments

Alliant Energy
Interstate Power and Light Company
Burlington Generating Station
Burlington, Iowa

Structural Stability Assessment



Boring Log Legend

Sample

No: (Number) Soil samples are numbered consecutively from the ground surface. Core samples are numbered consecutively from the first core run.

Type: A= Auger Cuttings CR= Core Run MS= Modified Spoon PB= Pitcher Barrel
 PT= Piston Tube ST= Shelby Tube SS= Split Spoon (2" O.D.) WC= Wash Cuttings

Interval: The depth of sampling interval in feet below ground surface

Blow Count

The number of blows required to drive a 2-inch O.D. split-spoon sampler with a 140 pound hammer falling 30-inches. When appropriate, the sampler is driven 18 inches and blow counts are reported for each 6-inch interval. The sum of blow counts for the last two 6-inch intervals is designated as the standard penetration resistance (N) expressed as blows per foot.

Recovery in Inches

The length of sample recovered by the sampling device.

U.S.C.S. Soil Type

The Unified Soil Classification System symbol for recovered soil samples determined by visual examination or laboratory tests. Refer to ASTM D2487-69 for a detailed description of procedure and symbols. Underlined symbols denote classifications based on laboratory tests (i.e. ML), all others are based on visual classification only.

Percent Moisture

Natural moisture content of sample expressed as percent of dry weight.

q_u TSF

Unconfined compressive strength in tons per square foot obtained by hand penetrometer. Laboratory compression test values are indicated by underlining.

Contact Depth

The contact depth between soil layers is interpreted from significant changes in recovered samples and observations during drilling. Actual changes between soil layers often occur gradually and the contact depths shown on the boring logs should be considered as approximate.

Soil Description and Remarks

Soil descriptions include consistency or density, color, predominant soil types and modifying constituents.

Cohesive Soils			Cohesionless Soils	
<u>Consistency</u>	<u>q_u (TSF)</u>	<u>Blows/ft.</u>	<u>Density</u>	<u>Blows/ft.</u>
Very Soft	less than 0.25	0-1	Very Loose	4 or less
Soft	0.25 to 0.50	2-4	Loose	5 to 10
Medium Stiff	0.50 to 1.00	5-8	Medium Dense	11 to 30
Stiff	1.00 to 2.00	9-15	Dense	30 to 50
Very Stiff	2.00 to 4.00	15-30	Very Dense	Over 50
Hard	more than 4.00	Over 30		

Particle Size Description

Boulder = Larger than 12 inches
 Cobble = 3 to 12 inches
 Gravel = 0.187 to 3 inches
 Sand = 0.074 to 4.76 mm
 Silt and Clay = smaller than 0.074 mm

Definition of Terms

Trace = 5 to 12 percent by weight
 Some = 12 to 30 percent by weight
 And = Approximately equal fractions
 () = Driller's observation

Piezo.

(Piezometer) Screened interval of the piezometer installation is denoted by cross-hatching.

General Note

The boring log and related information depicted subsurface conditions only at the specified locations and date indicated. Soil conditions and water levels at other locations may differ from conditions occurring at these boring locations. Also the passage of time may result in a change in the conditions at these boring locations.

Soil Test Boring Refusal

Defined as any material causing a blow count greater than 50 blows/6 inches. Such material may include bedrock, "floating" rock slabs, boulders, dense gravel seams, hard pan clay, or cemented soils. Refusal is usually indicated in fractional notation showing number of blows as the numerator and inches of penetration as the denominator.

CLIENT: Aether dbs

COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED


Environmental Field Services, LLC

PROJECT: Burlington, IA

BORING NO.: *SBI (CPT1)*

page 1 of 1

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT2)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Chris Sullivan</i>	DATE BEGAN: <i>05-11-11</i>	DATE FINISHED: <i>05-11-11</i>	GROUND SURFACE ELEVATION:	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------	--------------------------------	-----------------------	---------------	---------	------------------------------	------------------------------	-----------------------------------	-----------------------------	--------------------------------	---------------------------	-------------



CLIENT: Aether dbs

COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED

PROJECT: Burlington, IA


BORING NO.: SB2 (CPT7)

page 1 of 1

Environmental Field Services, LLC

LOGGED BY: John Noyes
 EDITED BY: John Noyes
 CHECKED BY: Chris Sullivan
 DATE BEGAN: 05-11-11
 DATE FINISHED: 05-11-11
 GROUND SURFACE ELEVATION:

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT2)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------	--------------------------------	-----------------------	---------------	---------	-------------



CLIENT: Aether dbs

COORDINATES: N NOT SURVEYED
E NOT SURVEYED

PROJECT: Burlington, IA

BORING NO.: SB3 (CPT10)

page 1 of 1

Environmental Field Services, LLC

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT2)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	LOGGED BY: John Noyes	EDITED BY: John Noyes	CHECKED BY: Chris Sullivan	DATE BEGAN: 05-11-11	DATE FINISHED: 05-11-11	GROUND SURFACE ELEVATION:	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------	--------------------------------	-----------------------	---------------	---------	-----------------------	-----------------------	----------------------------	----------------------	-------------------------	---------------------------	-------------



Bottom of boring @ 40'
Boring advanced w/ Geoprobe Model 6610DT using 60-inch Macrocore sampling system. Boring backfilled to ground surface w/ bentonite chips on 05-11-11.

CLIENT: Aether dbs

COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED


Environmental Field Services, LLC

PROJECT: Burlington, IA


BORING NO.: SB4 (CPT6)

page 1 of 1


DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT2)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Chris Sullivan</i>	DATE BEGAN: <i>05-11-11</i>	DATE FINISHED: <i>05-11-11</i>	GROUND SURFACE ELEVATION:	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------	--------------------------------	-----------------------	---------------	---------	------------------------------	------------------------------	-----------------------------------	-----------------------------	--------------------------------	---------------------------	-------------



DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT2)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Chris Sullivan</i>	DATE BEGAN: <i>05-16-11</i>	DATE FINISHED: <i>05-16-11</i>	GROUND SURFACE ELEVATION:
-------------------------------	---------------------	-----------------	--------------------	--------------------------------	-----------------------	---------------	---------	------------------------------	------------------------------	-----------------------------------	-----------------------------	--------------------------------	---------------------------



DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT2)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Chris Sullivan</i>	DATE BEGAN: <i>05-16-11</i>	DATE FINISHED: <i>05-16-11</i>	GROUND SURFACE ELEVATION:	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------	--------------------------------	-----------------------	---------------	---------	------------------------------	------------------------------	-----------------------------------	-----------------------------	--------------------------------	---------------------------	-------------



CLIENT: Aether dbs

COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED


Environmental Field Services, LLC

PROJECT: Burlington, IA


BORING NO.: SB7 (cpt15)

page 1 of 1

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT2)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Chris Sullivan</i>	DATE BEGAN: <i>05-16-11</i>	DATE FINISHED: <i>05-16-11</i>	GROUND SURFACE ELEVATION:	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------	--------------------------------	-----------------------	---------------	---------	------------------------------	------------------------------	-----------------------------------	-----------------------------	--------------------------------	---------------------------	-------------



DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT2)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Chris Sullivan</i>	DATE BEGAN: <i>05-16-11</i>	DATE FINISHED: <i>05-16-11</i>	GROUND SURFACE ELEVATION:	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------	--------------------------------	-----------------------	---------------	---------	------------------------------	------------------------------	-----------------------------------	-----------------------------	--------------------------------	---------------------------	-------------




CLIENT: Aether dbs

COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED

PROJECT: Burlington, IA

BORING NO.: SB9 (cpt21)

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT ²)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Chris Sullivan</i>	DATE BEGAN: <i>05-16-11</i>	DATE FINISHED: <i>05-16-11</i>	GROUND SURFACE ELEVATION:	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------	---	-----------------------	---------------	---------	------------------------------	------------------------------	-----------------------------------	-----------------------------	--------------------------------	---------------------------	-------------



CLIENT: Aether dbs

COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED


Environmental Field Services, LLC

PROJECT: Burlington, IA

BORING NO.: SB10

page 1 of 1

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT2)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Chris Sullivan</i>	DATE BEGAN: <i>05-16-11</i>	DATE FINISHED: <i>05-16-11</i>	GROUND SURFACE ELEVATION:	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------	--------------------------------	-----------------------	---------------	---------	------------------------------	------------------------------	-----------------------------------	-----------------------------	--------------------------------	---------------------------	-------------



CLIENT: Aether dbs


COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED

PROJECT: Burlington, IA

BORING NO.: SB11

page 1 of 1

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT2)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Chris Sullivan</i>	DATE BEGAN: <i>05-16-11</i>	DATE FINISHED: <i>05-16-11</i>	GROUND SURFACE ELEVATION:	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------	--------------------------------	-----------------------	---------------	---------	------------------------------	------------------------------	-----------------------------------	-----------------------------	--------------------------------	---------------------------	-------------




CLIENT: Aether dbs
PROJECT: Burlington, IA

COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED

BORING NO.: **SB12**
page 1 of 1

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION	POCKET PENETROMETER (TONS/FT2)	CONSISTENCY vs. DEPTH	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Chris Sullivan</i>	DATE BEGAN: <i>05-16-11</i>	DATE FINISHED: <i>05-16-11</i>	GROUND SURFACE ELEVATION:	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------	--------------------------------	-----------------------	---------------	---------	------------------------------	------------------------------	-----------------------------------	-----------------------------	--------------------------------	---------------------------	-------------



APPENDIX C – CPT Soil Probes on CCR Embankments

Alliant Energy
Interstate Power and Light Company
Burlington Generating Station
Burlington, Iowa

Safety Factor Assessment



CONE PENETROMETER TEST (CPT)


CPT I.D.	LOCATION	GROUND ELEVATION (FT)
CPT-1	Economizer Ash Pond	548.78
CPT-2	Economizer Ash Pond	550.34
CPT-3	Economizer Ash Pond	549.91
CPT-4	Economizer Ash Pond	549.65
CPT-5	Economizer Ash Pond	549.74
CPT-6	Economizer Ash Pond	550.57
CPT-7	Economizer Ash Pond	545.78
CPT-8	Economizer Ash Pond	546.26
CPT-9	Economizer Ash Pond	549.48
CPT-10	Economizer Ash Pond	549.42
CPT-11	Economizer Ash Pond	547.86
CPT-12	Economizer Ash Pond	548.25
CPT-13	Ash Seal Water Pond	534.22
CPT-14	Ash Seal Water Pond	533.67
CPT-15	Main Ash Pond	536.75
CPT-16	Main Ash Pond	534.84
CPT-17	Main Ash Pond	534.52
CPT-18	Main Ash Pond	533.89
CPT-19	Main Ash Pond	535.32
CPT-20	Upper Ash Pond	530.47
CPT-21	Upper Ash Pond	530.42



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 09/May/2011
Test ID: cpt1
Project: Alliant




Maximum depth: 43.92 (ft)



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdb
Job Site: Burlington

Date: 09/May/2011
Test ID: cpt2
Project: Alliant




Maximum depth: 45.54 (ft)



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdb
Job Site: Burlington

Date: 09/May/2011
Test ID: cpt3
Project: Alliant




Maximum depth: 42.94 (ft)



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 09/May/2011
Test ID: cpt4
Project: Alliant






Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 10/May/2011
Test ID: cpt5
Project: Alliant




Maximum depth 21.43 (ft)



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 10/May/2011
Test ID: cpt6
Project: Alliant




Maximum depth: 21.96 (ft)



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdb
Job Site: Burlington

Date: 10/May/2011
Test ID: cpt7
Project: Alliant






Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 10/May/2011
Test ID: cpt8
Project: Alliant




Maximum depth: 43.65 (ft)



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdb
Job Site: Burlington

Date: 10/May/2011
Test ID: cpt9
Project: Alliant






Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 10/May/2011
Test ID: cpt10
Project: Alliant




Maximum depth: 42.27 (ft)



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdb
Job Site: Burlington

Date: 10/May/2011
Test ID: cpt11
Project: Alliant






Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 10/May/2011
Test ID: cpt12
Project: Alliant




Maximum depth: 4.06 (ft)



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 10/May/2011
Test ID: cpt13
Project: Alliant




Maximum depth: 29.72 (ft)



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 15/May/2011
Test ID: cpt14
Project: Alliant






Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 15/May/2011
Test ID: cpt15
Project: Alliant






Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 15/May/2011
Test ID: cpt16
Project: Alliant




Maximum depth: 32.02 (ft)



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 15/May/2011
Test ID: cpt17
Project: Alliant




Maximum depth: 27.84 (ft)



Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 15/May/2011
Test ID: cpt18
Project: Alliant






Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 16/May/2011
Test ID: cpt19
Project: Alliant






Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 16/May/2011
Test ID: cpt20
Project: Alliant







Applied Research Associates, Inc.
South Royalton, VT 05068
802-763-8348
cpt@ned.ara.com
www.ara.com

Northing:
Easting:
Elevation:
Client: Aetherdbs
Job Site: Burlington

Date: 16/May/2011
Test ID: cpt21
Project: Alliant





19.5 Empirical correlation between friction angle ϕ' of sands and normalized penetration resistance.

Re: TERZAGHI, PECK & MESRI
 (1996), SOIL MECHANICS IN ENG. PRACTICE,
 3RD ED., JOHN WILEY & SONS, INC.

APPENDIX D – Laboratory Testing on CCR Embankment Soils

Alliant Energy
Interstate Power and Light Company
Burlington Generating Station
Burlington, Iowa

Safety Factor Assessment




Attachment C

Soil Laboratory Results

Burlington Generating Station

Source: Testing Service Corporation, May 2011




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION	SIEVE	% PASS	SOIL CLASSIFICATION				
Broing: SB-1	3 inch	100	Brown ASH				
Sample: Ash	2	100					
	1 1/2	100					
	1	100	%GRAVEL	%SAND	%SILT	%CLAY	
NOTES:	3/4	100	0	44	54	2	
	3/8	100					
	#4	100	MC%		LL	PL	PI
	#10	99	44.0		NP	NP	NP
	#40	89					
	#100	69					
	#200	56					

PROJECT Geotechnical Testing JOB NO. L - 76.757
 LOCATION SB1 DATE May 20, 2011

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILCENR 76757.GPJ TSC ALL.GST 5/20/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-1		3 inch	100	Gray clayey SILT, trace sand (ML)				
Sample: A		2	100					
Depth: 25.0'-26.0'		1 1/2	100					
NOTES:		1	100	%GRAVEL	%SAND	%SILT	%CLAY	
		3/4	100	0	5	87	8	
		3/8	100					
		# 4	100	MC%		LL	PL	PI
		# 10	100	69.4		36	31	5
		# 40	99					
		# 100	98					
		# 200	95					

PROJECT: Geotechnical Testing JOB NO.: L - 76,757
 LOCATION: DATE: May 20, 2011
 SBT

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGENR 75/57.GPJ TSC ALL.GDT 5/20/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION	SIEVE	% PASS	SOIL CLASSIFICATION			
Boring: SB-1	3 inch	100	Gray clayey SILT, trace sand (ML)			
Sample: B	2	100				
Depth: 29.0'-30.0'	1 1/2	100				
	1	100	%GRAVEL	%SAND	%SILT	%CLAY
NOTES:	3/4	100	0	7	89	4
	3/8	100				
	# 4	100	MC%	LL	PL	PI
	# 10	100	58.6	40	37	3
	# 40	99				
	# 100	97				
	# 200	93				

PROJECT Geotechnical Testing JOB NO. L-76,757
 LOCATION SBT DATE May 20, 2011

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGENR 76757.GPJ TSC ALL.GDT E2011




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION	SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-1	3 inch	100	Gray silty CLAY, trace sand (CH)				
Sample: C	2	100					
Depth: 34.0'-35.0'	1 1/2	100					
	1	100	%GRAVEL	%SAND	%SILT	%CLAY	
NOTES:	3/4	100	0	1	69	30	
	3/8	100					
	# 4	100	MC%		LL	PL	PI
	# 10	100	31.3		52	17	35
	# 40	100					
	# 100	100					
	# 200	99					

PROJECT Geotechnical Testing JOB NO. L - 76,757
 LOCATION SB1 DATE May 20, 2011

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGEMR 76757.GPJ TSC ALL.GDT 5/20/11



COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


SPECIMEN IDENTIFICATION	SIEVE	% PASS	SOIL CLASSIFICATION			
Boring: SB-1	3 inch	100	Gray very silty CLAY, some sand (CL)			
Sample: D	2	100				
Depth: 36.0'-37.0'	1 1/2	100				
NOTES:	1	100	%GRAVEL	%SAND	%SILT	%CLAY
	3/4	100	0	22	61	17
	3/8	100				
	# 4	100	MC%	LL	PL	PI
	# 10	100	29.1	36	16	20
	# 40	99				
	# 100	93				
	# 200	78				

PROJECT LOCATION: Geotechnical Testing JOB NO. L - 76.757
 DATE: May 20, 2011

SB1

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOIL GENR 76757.GPJ TSC ALL GDT 5/20/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION	SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-1	3 inch	100	Gray clayey SAND (SC)				
Sample: E	2	100					
Depth: 37.0'-38.0'	1 1/2	100					
	1	100	%GRAVEL	%SAND	%SILT	%CLAY	
NOTES:	3/4	100	0	69	23	8	
	3/8	100					
	#4	100	MC%		LL	PL	PI
	#10	100	30.4		22	14	8
	#40	98					
	#100	43					
	#200	31					

PROJECT Geotechnical Testing JOB NO. L - 76,757
 LOCATION SB1 DATE May 20, 2011

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILCENR 76757.GPJ ISC ALL.GDT 5/20/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION			
Boring: SB-2		3 inch	100	Brownish gray silty CLAY, some sand			
Sample: A		2	100	(CL)			
Depth: 8.0'-9.0'		1 1/2	100				
		1	100	%GRAVEL	%SAND	%SILT	%CLAY
NOTES:		3/4	100	0	28	41	31
		3/8	100				
		# 4	100	MC%	LL	PL	PI
		# 10	99	15.7	46	12	34
		# 40	93				
		# 100	80				
		# 200	72				

PROJECT Geotechnical Testing JOB NO. L - 76,757
 LOCATION SB2 DATE May 20, 2011

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGENR 76357.GPJ TSC ALL.GDT 5/20/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-2		3 inch	100	Dark gray very silty CLAY, trace sand				
Sample: B		2	100	(CL)				
Depth: 28.0'-29.0		1 1/2	100					
		1	100	%GRAVEL	%SAND	%SILT	%CLAY	
NOTES:		3/4	100	0	2	77	21	
		3/8	100					
		#4	100	MC%		LL	PL	PI
		#10	100	35.1		42	18	24
		#40	100					
		#100	100					
		#200	98					

PROJECT: Geotechnical Testing JOB NO.: L-76,757
LOCATION: SB2 DATE: May 20, 2011

SOIL DATA SHEET
Testing Service Corporation
Carol Stream, IL 60188

SOILGENR. 16257.GPJ TSC ALL-GDI 5/20/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-2		3 inch	100	Dark gray silty CLAY, trace sand (CH)				
Sample: C		2	100					
Depth: 32.0'		1 1/2	100					
NOTES:		1	100	%GRAVEL	%SAND	%SILT	%CLAY	
		3/4	100	0	3	70	27	
		3/8	100					
		#4	100	MC%		LL	PL	PI
		#10	100	32.9		51	16	35
		#40	100					
		#100	99					
		#200	97					

PROJECT: Geotechnical Testing JOB NO.: L-76,757
LOCATION: DATE: May 20, 2011

SOILGENR 76757.CPJ TSC ALL.GDT 5/20/11

SOIL DATA SHEET
Testing Service Corporation
Carol Stream, IL 60188




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION	SIEVE	% PASS	SOIL CLASSIFICATION			
Boring: SB-3	3 inch	100	Dark gray very silty CLAY, trace sand			
Sample: A	2	100	(CL)			
Depth: 38.0'	1 1/2	100				
NOTES:	1	100	%GRAVEL	%SAND	%SILT	%CLAY
	3/4	100	0	4	71	25
	3/8	100				
	# 4	100	MC%	LL	PL	PI
	# 10	100	34.4	46	15	31
	# 40	100				
	# 100	99				
	# 200	96				

PROJECT Geotechnical Testing JOB NO. L-76,757
 LOCATION SB3 DATE May 20, 2011

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGEMR 76757.GPJ TSC ALL.GDT 5/20/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION	SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-4	3 inch	100	Dark gray silty CLAY, some sand (CL)				
Sample: A	2	100					
Depth: 34.0'	1 1/2	100					
	1	100	%GRAVEL	%SAND	%SILT	%CLAY	
NOTES:	3/4	100	0	29	50	21	
	3/8	100					
	# 4	100	MC%		LL	PL	PI
	# 10	100	24.1		41	12	29
	# 40	100					
	# 100	89					
	# 200	71					

PROJECT LOCATION: Geotechnical Testing JOB NO. L - 76.757
 DATE: May 20, 2011

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGEAR 76757.GPJ TSC ALL.GDT 5/20/11



COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-5		3 inch	100	Gray very silty CLAY, little sand (CL)				
Sample: A		2	100					
Depth: 34.0'		1 1/2	100					
NOTES:		1	100	%GRAVEL	%SAND	%SILT	%CLAY	
		3/4	100	0	15	60	25	
		3/8	100					
		# 4	100	MC%		LL	PL	PI
		# 10	100	23.3		43	16	27
		# 40	99					
		# 100	93					
		# 200	85					

PROJECT LOCATION: Geotechnical Testing, SB5

JOB NO. L - 76,757
DATE May 23, 2011

SOIL DATA SHEET
Testing Service Corporation
Carol Stream, IL 60188

SOILGENR 76/57 GPJ TSC ALL.GDT 5/23/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION	SIEVE	% PASS	SOIL CLASSIFICATION			
Boring: SB-8	3 inch	100	Gray clayey SAND (SC)			
Sample: A	2	100				
Depth: 16.0'-17.0'	1 1/2	100				
	1	100	%GRAVEL	%SAND	%SILT	%CLAY
NOTES:	3/4	100	0	74	21	5
	3/8	100				
	# 4	100	MC%	LL	PL	PI
	# 10	100	24.6	16	13	3
	# 40	84				
	# 100	32				
	# 200	26				

PROJECT LOCATION: Geotechnical Testing JOB NO. L - 76,757
 DATE: May 23, 2011

SB6
SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILCENR 76757.GPJ TSC ALL GDT 5/23/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION			
Boring: SB-6		3 inch	100	Brownish gray very silty CLAY, trace sand			
Sample: B		2	100	(CL)			
Depth: 28.0'-29.0'		1 1/2	100				
		1	100	%GRAVEL	%SAND	%SILT	%CLAY
NOTES:		3/4	100	0	9	66	25
		3/8	100				
		# 4	100	MC%	LL	PL	PI
		# 10	100	28.3	43	13	30
		# 40	98				
		# 100	96				
		# 200	91				

PROJECT Geotechnical Testing JOB NO. L - 76,757
 LOCATION SB6 DATE May 23, 2011

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGENR 76757 GPJ TSC ALL.GDT \$2311



COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-8		3 inch	100	Gray sandy CLAY (CL)				
Sample: A		2	100					
Depth: 10.0'		1 1/2	100					
		1	100	%GRAVEL	%SAND	%SILT	%CLAY	
NOTES:		3/4	100	0	43	36	21	
		3/8	100					
		# 4	100	MC%		LL	PL	PI
		# 10	99	21.6		35	12	24
		# 40	86					
		# 100	64					
		# 200	57					

PROJECT LOCATION: Geotechnical Testing JOB NO. L-76,757
 DATE: May 23, 2011

SB8

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGENR 76757 GPJ TSC ALL GDT 5/23/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-8		3 inch	100	Gray very silty CLAY, trace sand (CL)				
Sample: B		2	100					
Depth: 20.0'		1 1/2	100					
		1	100	%GRAVEL	%SAND	%SILT	%CLAY	
NOTES:		3/4	100	0	6	59	35	
		3/8	100					
		# 4	100	MC%		LL	PL	PI
		# 10	100	31.1		56	19	37
		# 40	100					
		# 100	98					
		# 200	94					

PROJECT Geotechnical Testing JOB NO. L-76,757
 LOCATION _____ DATE May 23, 2011
 SB8

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGENR 76757.GPJ TSC ALL.GDT 5/23/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-8		3 inch	100	Gray clayey SAND (SC)				
Sample: C		2	100					
Depth: 22.0'		1 1/2'	100					
		1	100	%GRAVEL	%SAND	%SILT	%CLAY	
NOTES:		3/4	100	0	64	28	8	
		3/8	100					
		# 4	100	MC%		LL	PL	PI
		# 10	100	26.9		21	13	8
		# 40	87					
		# 100	47					
		# 200	36					

PROJECT LOCATION: Geotechnical Testing JOB NO. L-76,757
 DATE: May 23, 2011

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGENR 76757.GPJ TSC ALL GOT 5/23/11




COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-9		3 inch	100	Brownish gray sandy CLAY (CL)				
Sample: A		2	100					
Depth: 18.0'		1 1/2	100					
		1	100	%GRAVEL	%SAND	%SILT	%CLAY	
NOTES:		3/4	100	0	37	44	19	
		3/8	100					
		# 4	100	MC%		LL	PL	PI
		# 10	100	34.0		35	13	22
		# 40	95					
		# 100	74					
		# 200	63					

PROJECT Geotechnical Testing JOB NO. L - 76,757
 LOCATION _____ DATE May 23, 2011
 SB9

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGENR 76757.GPJ ISC ALL GOI 5/23/11



COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	


SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION				
Boring: SB-10		3 inch	100	Brownish gray silty CLAY, trace sand				
Sample: A		2	100	(CH)				
Depth: 20.0'		1 1/2	100					
		1	100	%GRAVEL	%SAND	%SILT	%CLAY	
NOTES:		3/4	100	0	1	52	47	
		3/8	100					
		# 4	100	MC%		LL	PL	PI
		# 10	100	26.9		74	15	59
		# 40	100					
		# 100	99					
		# 200	99					

PROJECT Geotechnical Testing
 LOCATION SBTU

JOB NO. L - 76,757
 DATE May 23, 2011

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGENR 76757 G&J TSC ALL.GOT 5/23/11



COBBLES	GRAVEL		SAND			SILT OR CLAY
	coarse	fine	coarse	medium	fine	

SPECIMEN IDENTIFICATION		SIEVE	% PASS	SOIL CLASSIFICATION			
Boring: SB-12		3 inch	100	Gray silty CLAY, some sand, trace gravel			
Sample: A		2	100	(CL)			
Depth: 23.0'-24.0'		1 1/2	100				
NOTES:		1	100	%GRAVEL	%SAND	%SILT	%CLAY
		3/4	100	1	26	50	23
		3/8	99				
		# 4	99	MC%	LL	PL	PI
		# 10	99	35.9	42	16	26
		# 40	95				
		# 100	79				
# 200	73						

PROJECT Geotechnical Testing JOB NO. L - 76,757
 LOCATION SB12 DATE May 23, 2011

SOIL DATA SHEET
 Testing Service Corporation
 Carol Stream, IL 60188

SOILGENR 7/6757.GPJ TSC ALL.GDT 5/23/11