



Alliant Energy  
4902 North Biltmore Lane  
P.O. Box 77007  
Madison, WI 53707-1007

1-800-ALLIANT (800-255-4268)  
alliantenergy.com

February 13, 2019

To: CCR Operating Record

Re: Notification of Groundwater Protection Standard Exceedance pursuant to 40 CFR 257.95

Two constituents in Appendix IV to part 40 CFR 257 were detected at a statistically significant level above the groundwater protection standard (GPS) established under 40 CFR 257.95(h) in monitoring wells located at the Burlington Generating Station. The constituents exceeding the GPS are lithium and molybdenum, as sampled in monitoring wells MW-301 (Mo only), MW-302, MW-303 (Li only), MW-304, MW-306 (Li only), MW-307, and MW-308. This notification has been prepared in accordance with 40 CFR 257.95(g) and 257.105(h)(8).

This notification applies to the following CCR units at this facility:

CCR Surface Impoundments

BGS Ash Seal Pond

BGS Main Ash Pond

BGS Economizer Ash Pond

BGS Upper Ash Pond

Signed,

Print Name Jeff Maxted	Title Lead Environmental Specialist
Phone No. or Email Address (608) 458-3853; jeffreymaxted@alliantenergy.com	