



Alliant Energy  
4902 North Biltmore Lane  
P.O. Box 77007  
Madison, WI 53707-1007

1-800-ALLIANT (800-255-4268)  
alliantenergy.com

January 30, 2026

To: Wisconsin DNR, CCR Operating Record, and Public Website  
Re: Notification of Standard Attainment or Exceedance pursuant to NR 508.06

One or more constituents in Table 1A of NR 507 Appendix I was confirmed to be detected above the applicable Preventative Action Limit (PAL) or Alternative Concentration Limit (ACL) established for Coal Combustion Residual (CCR) monitoring wells at the Wisconsin Power and Light (WPL) Columbia Energy Center. WPL anticipates submitting a False Exceedance Demonstration for Wisconsin Department of Natural Resources (WDNR) Review on or before 60 days following the confirmation of the exceedance in accordance with NR 508.06(1)(c). This notification has been prepared in accordance with NR 508.06(1)(a) and 506.17(3).

This notification applies to the following CCR units: WPL Columbia Dry Ash Disposal Facility (License #3025)

This notification applies to the following constituents at the indicated monitoring well: sulfate (MW-33AR).

Signed,

Print Name Matthew Bizjack	Title Sr. Environmental Specialist
Phone No. or Email Address (608) 458-3197; matthewbizjack@alliantenergy.com	