September 29, 2026
File No. 25226067.00

Mr. Christopher Flowers, Senior Manager of Operations
Columbia Energy Center
W8375 Murray Road
Pardeeville, WI 53954

Subject: Certification of Closure – COL Secondary Pond
Wisconsin Power and Light Company – Columbia Energy Center
Pardeeville, Wisconsin

Dear Mr. Flowers:

The closure of the Columbia Energy Center Secondary Ash Pond has been completed in accordance with the written Closure Plan for CCR Surface Impoundments – Amendment No. 1, dated November 11, 2020.

As of the date of this letter, the closure of the impoundment has been completed and satisfies the requirements of 40 CFR 257.102. The closure has been completed by removal of CCR in accordance with the performance standards of 40 CFR 257.102(c).

Based on the results of the two most recent groundwater sampling events, the former Secondary Ash Pond CCR Unit meets the groundwater performance standard for closure by removal of CCR under 40 CFR 257.102(c)(1)(ii).

If you have any questions regarding this certification, please contact Phil Gearing.

Sincerely,

Phillip E. Gearing, PE
Certifying PE
SCS Engineers

Sherren Clark, PE, PG
Project Director
SCS Engineers

MDB/AJR_REO/TK/SCC

cc: Jeff Maxted, Alliant Energy

10/26/2026 - Classification: Internal - ECRM13835244

PE CERTIFICATION



I, Phillip E. Gearing, hereby certify that the closure of the following CCR impoundment at the Columbia Energy Center has been completed in accordance with Amendment No. 1 to the written closure plan and the requirements of 40 CFR 257.102.

- COL Secondary Ash Pond

This certification is based on my review of the written closure plan posted to Alliant Energy's CCR Rule Compliance Data and Information website and my oversight of the closure of the Secondary Ash Pond. I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed Professional Engineer under the laws of the State of Wisconsin.

September 29, 2026
Phillip E. Gearing, PE (date)

Wisconsin License No. E-45115

My license renewal date is: July 31, 2028

Pages or sheets covered by this seal: Certification of Closure – COL Secondary Ash Pond, dated September 29, 2026.

I:\25226067.00\Deliverables - Working\COL SPond Closure Cert\Certification\2026-09-29_SPond Closure Cert.docx