



Alliant Energy  
4902 North Biltmore Lane  
P.O. Box 77007  
Madison, WI 53707-1007

1-800-ALLIANT (800-255-4268)  
alliantenergy.com

April 5, 2023

To: CCR Operating Record  
Re: Notification of Groundwater Protection Standard Exceedance pursuant to 40 CFR 257.95

A constituent in Appendix IV to part 40 CFR 257 was detected at a statistically significant level above the groundwater protection standard (GPS) established under 40 CFR 257.95(h) in a monitoring well located at the Colombia Energy Center. The constituent exceeding the GPS is arsenic, as sampled in monitoring well MW-303. This notification has been prepared in accordance with 40 CFR 257.95(g) and 257.105(h)(8).

This notification applies to the following CCR units at this facility:

CCR units  
COL Primary Pond

Signed,

Print Name Matt Bizjack	Title Senior Environmental Specialist
Phone No. or Email Address (608) 458-3197; matthewbizjack@alliantenergy.com	