



Alliant Energy  
 4902 North Biltmore Lane  
 P.O. Box 77007  
 Madison, WI 53707-1007

1-800-ALLIANT (800-255-4268)  
 alliantenergy.com

July 26, 2021

To: CCR Operating Record  
 Re: Notification of Groundwater Protection Standard Exceedance pursuant to 40 CFR 257.95

A constituent in Appendix IV to part 40 CFR 257 was detected at a statistically significant level above the groundwater protection standard (GPS) established under 40 CFR 257.95(h) in a monitoring well located at the Lansing Generating Station. The constituent exceeding the GPS is molybdenum, as sampled in monitoring well MW-304A. This is a delineation well installed for assessment monitoring at the site; molybdenum has not been observed at a statistically significant level in monitoring wells installed at the waste boundary of the CCR units listed below. This notification has been prepared in accordance with 40 CFR 257.95(g) and 257.105(h)(8).

This notification applies to the following CCR units at this facility:

CCR units  
 LAN Landfill  
 LAN Upper Ash Pond

Signed,

Print Name Jeff Maxted	Title Manager – Environmental Services
Phone No. or Email Address (608) 458-3853; jeffreymaxted@alliantenergy.com	