



Alliant Energy
Lansing Plant
2320 Power Plant Drive
Lansing, IA 52151-7539

1-800-ALLIANT (1-800-255-4268)
alliantenergy.com

November 03, 2021

To: Alliant Energy Lansing Files

From: Robin Nelson, Environmental & Safety Specialist

Meeting with Allamakee County Emergency Management Coordinator

On November 3rd, 2021, Clint Mohn (Operations Manager) met with Corey Snitker who is part of the Local Emergency Planning Committee (LEPC) for Allamakee County to discuss the current information on the CCR Impoundment since his last site visit on November 17, 2020.

This meeting started at 1:00 p.m. with discussions about the projects, spill response supplies and plant closure date.

He was informed that inspections are still performed. The seven-day inspection requirements were discussed and noted that we generally inspect the pond twice per week and the required annual professional engineer (PE) pond inspection and let him know the results showed no deficiencies.

He was reminded of the Alliant Energy's CCR Website and informed that our emergency action plan is still current.

A handwritten signature in black ink that reads "Robin Nelson".

Robin Nelson
E&S Specialist
Lansing Generating Station