

Selection of Remedy Landfill and Surface Impoundment

Former Lansing Generating Station
Lansing, Iowa

Prepared for:



SCS ENGINEERS

25220082.00 | May 6, 2024

2830 Dairy Drive
Madison, WI 53718-6751
608-224-2830

Table of Contents

Section	Page
Executive Summary.....	iii
PE Certification.....	v
1.0 Introduction and Purpose	1
2.0 Background.....	1
2.1 Site Information and Map.....	1
2.2 Updated Nature and Extent of Groundwater Impacts.....	2
3.0 Corrective Measures and Remedy Selection.....	2
3.1 Applicability of Corrective Measures.....	3
3.2 Minimum Criteria.....	3
3.3 Evaluation Factors.....	3
3.3.1 Long- and Short-Term Effectiveness [257.97(c)(1)]	4
3.3.2 Source Control to Reduce Future Releases [257.97(c)(2)].....	5
3.3.3 Implementation [257.97(c)(3)]	5
3.3.4 Community Acceptance [257.97(c)(4)]......	5
3.4 Selected Remedy.....	5
3.4.1 Remedy Description	5
3.4.2 Satisfying Minimum Criteria.....	6
4.0 Schedule	7
5.0 Conclusion	8
6.0 References.....	8

Tables

- Table 1. Groundwater Monitoring Well Network
Table 2. CCR Rule Groundwater Samples Summary

Figures

- Figure 1. Site Location Map
Figure 2. Site Plan and Monitoring Well Locations

Appendices

- Appendix A Historical Groundwater Quality Data
Appendix B Lansing Landfill and Ash Pond Closure Drawings
Appendix C Estimated Groundwater Corrective Action Schedule

I:\25220082.00\Deliverables\2024 Selection of Remedy\240506_LAN_Selection of Remedy Report.docx

[This page left blank intentionally]

EXECUTIVE SUMMARY


Interstate Power and Light Company (IPL), an Alliant Energy company, operates a dry ash landfill and ash pond at the Lansing Generating Station (LAN). The landfill and pond were used to manage coal combustion residuals (CCR) and wastewater from the power plant, which burned coal to generate electricity until December 31, 2022. The power plant at the LAN facility has been decommissioned, and the landfill has been closed. Construction to consolidate the remaining CCR in the ash pond and cap is complete.

IPL samples and tests the groundwater in the area of the landfill and pond to comply with U.S. Environmental Protection Agency (U.S. EPA) standards for the Disposal of CCR from Electric Utilities, or the “CCR Rule” (Rule). Groundwater monitoring is also conducted under an Iowa Department of Natural Resources (IDNR) sanitary disposal project permit for the landfill.

Groundwater samples from one of the wells installed under the Rule to monitor the landfill and pond contain arsenic at levels higher than the Groundwater Protection Standards (GPS) defined in the Rule. Arsenic occurs naturally and can be present in coal and CCR.

IPL has prepared this Selection of Remedy Report in accordance with the requirements of the CCR Rule. The information in this report builds on the Assessment of Corrective Measures (ACM) Report issued in September 2019, ACM Addendum No. 1 issued in November 2020, and ACM Addendum No. 2 issued in June 2023. The ACM and ACM Addendums were prepared in response to the groundwater sampling results at the LAN facility.

The Selection of Remedy process is one step in a series of steps defined in the Rule and shown below.



Prior to developing the Selection of Remedy Report, the nature and extent of groundwater impacts at the LAN facility were discussed in the ACM and ACM Addendums No. 1 and No. 2. Through the development of the ACM and subsequent addendums, IPL worked to understand the following:

- Types of soil and rock deposits in the area of the LAN facility.
- Depth of groundwater.
- Direction that groundwater is moving.
- Potential sources of the arsenic in groundwater.
- The area where arsenic levels are higher than the U.S. EPA standards.
- The people, plants, and animals that may be affected by levels of arsenic in groundwater that are above the GPS.

IPL has identified appropriate options, or Corrective Measures, to bring the levels of arsenic in groundwater below U.S. EPA standards. In addition to stopping landfill disposal of CCR and the discharge of CCR and LAN wastewater to the pond, these corrective measures include:

- No Action
- Cap CCR in Place with Monitored Natural Attenuation (MNA)
- Consolidate CCR and Cap with MNA
- Excavate and Dispose CCR on Site with MNA
- Excavate and Dispose CCR in Off-site Landfill with MNA
- Consolidate and Cap with Chemical Amendment
- Consolidate and Cap with Groundwater Collection
- Consolidate and Cap with Barrier Wall

Because the time allowed by the Rule to prepare the ACM was limited, IPL worked to improve the understanding of the items listed above and issued ACM Addendum No. 1 in November 2020 and ACM Addendum No. 2 in June 2023.

Based on the assessment of the nature and extent of arsenic, current data indicates that the source of the arsenic GPS exceedances is unrelated to the dry ash landfill and ash pond.

Arsenic occurs naturally in air, water, soil, and rock. Arsenic is also commonly present in coal and CCR. The LAN CCR Units do not appear to be the source of the arsenic GPS exceedances. Lines of evidence that indicate the arsenic GPS exceedances are not from the CCR Units are:

- Low arsenic concentrations have repeatedly been reported in laboratory tests of groundwater samples from a monitoring well nest installed between the CCR Units and the well where arsenic concentrations exceed the GPS.
- The arsenic concentration in a sample collected from the Upper Ash Pond outfall was below the arsenic GPS. The outfall sample included the flow from a groundwater interceptor drain installed between the Upper Ash Pond and the well where arsenic concentrations exceed the GPS.

Lines of evidence that support an alternate source of arsenic GPS exceedances are:

- Anoxic reducing conditions that can result in increased arsenic concentrations are present in a localized area near the well with arsenic GPS exceedances.
- Anoxic conditions, resulting in potential higher arsenic concentrations, may be caused by the organic material described in the boring log of the well with arsenic GPS exceedances. The organic material is absent in other site monitoring wells.

IPL held a public meeting on October 12, 2020, to discuss the contents of the September 2019 ACM with interested and affected parties. IPL held an additional public meeting on January 11, 2022, to discuss the ACM Addendum No. 1. IPL held a public meeting with interested and affected parties to discuss Addendum No. 2 on June 12, 2023.

For more information on Alliant Energy, view the Alliant Energy Corporate Responsibility Report at <https://poweringwhatsnext.alliantenergy.com/crr/>.

PE CERTIFICATION

 The seal is circular with a dotted outer edge. The words "LICENSED PROFESSIONAL ENGINEER" are written along the top inner curve. In the center, it says "ERIC J. NELSON" above the number "23136". Below the name and number is a blue ink signature of "Eric J. Nelson". At the bottom of the seal, there are two small five-pointed stars flanking the word "IOWA".	I, Eric J. Nelson, hereby certify that the selected groundwater remedy described herein meets the requirements of 40 CFR 257.97. This Selection of Remedy report was prepared by me or under my direct supervision, and that I am a duly licensed Professional Engineer under the laws of the State of Iowa.	
		5/6/2024
	(signature)	(date)
	Eric J. Nelson	
	(printed or typed name)	
	License number <u>23136</u>	
	My license renewal date is December 31, 2024.	
Pages or sheets covered by this seal:		
Selection of Remedy Report, Lansing Generating Station		
May 6, 2024		

[This page left blank intentionally]

1.0 INTRODUCTION AND PURPOSE

This Selection of Remedy Report was prepared to support compliance with the groundwater monitoring requirements of the “Coal Combustion Residuals (CCR) Final Rule” published by the U.S. Environmental Protection Agency (U.S. EPA) in the *Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residual from Electric Utilities; Final Rule*, date April 17, 2015 (U.S. EPA, 2015), and subsequent amendments. Specifically, this report was prepared to fulfill the requirements of a final report identified in 40 CFR 257.97(a) and identify the remedy selected to address the arsenic Groundwater Protection Standard (GPS) exceedances observed in groundwater samples from detection monitoring wells for the former Lansing Generating Station (LAN) Upper Ash Pond and now closed LAN Landfill. These GPS exceedances for arsenic were initially identified in the Notification of GPS Exceedance dated February 13, 2019.

Although IPL has concluded that the source of the arsenic GPS exceedance is not associated with the CCR units at the former LAN facility and no further action is required, this Selection of Remedy report was prepared to address the requirements in 40 CFR 257.97(a). This Selection of Remedy report includes a description of the selected remedy and how it meets the requirements of 40 CFR 257.97(b), which are described in **Section 3.1**.

The situation encountered at the LAN facility where further investigation of the nature and extent of GPS exceedances during corrective action reveals a potential source other than the CCR unit is not specifically addressed in the CCR Rule. This Selection of Remedy report was developed to meet the corrective action requirements of the CCR Rule and the content is based on guidance from other relevant U.S. EPA programs, such as the Superfund program (U.S. EPA 1999), that contemplate similar circumstances.

2.0 BACKGROUND

2.1 SITE INFORMATION AND MAP

LAN is located along the west bank of the Mississippi River, south of the City of Lansing, in Allamakee County, Iowa. The address of the former plant is 2320 Power Plant Drive in Lansing, Iowa (**Figure 1**). The coal-fired generating plant at LAN ceased coal-fired electric generating activities at the end of 2022 and has been decommissioned. The facility also includes a CCR landfill and a CCR settling pond. The LAN facility was originally constructed in 1948, with additional units added in 1957 and 1976.

The groundwater monitoring system at LAN is a multi-unit system monitoring two existing CCR Units that are contiguous:

- LAN Landfill (existing landfill)
- LAN Upper Ash Pond (existing surface impoundment)

The LAN Landfill has been closed under a sanitary disposal project closure permit (Permit #03 SDP-05-01C) administered by the Iowa Department of Natural Resources (IDNR). A separate groundwater monitoring system has been established to monitor the landfill for the state permit. The landfill was closed in 2023 by installing a state-permitted final cover that meets the CCR Rule minimum design requirements in 40 CFR 257.102(d)(3).

The LAN Upper Ash Pond was operated until disposal activities ended on July 27, 2023. The LAN Upper Ash Pond was operated with discharges regulated under individual National Pollutant Discharge Elimination System (NPDES) Permit Number IA0300100. The LAN Upper Ash Pond will close in accordance with the CCR Closure Plan and the Notification of Intent to Close issued on August 14, 2023. The ash pond will be closed by installing a state-permitted final cover that meets the CCR Rule minimum design requirements in 40 CFR 257.102(d)(3). The consolidation of CCR and construction of the final cover was completed in 2023 under a sanitary disposal project closure permit (Permit #03-SDP-13-23C) administered by the IDNR.

A map showing the CCR Units and all background (or upgradient) and downgradient monitoring wells with identification numbers for the CCR groundwater monitoring program is provided as **Figure 2**. Monitoring wells installed for the state monitoring program for the CCR landfill are also shown on **Figure 2**. The monitoring wells and their location and role in the monitoring network are included in **Table 1**. A summary of the monitoring event dates are included in **Table 2**.

2.2 UPDATED NATURE AND EXTENT OF GROUNDWATER IMPACTS

The potential sources of the arsenic impacts in groundwater have been under evaluation since the initiation of the ACM that was issued in September 2019. Based on the data obtained to date, the LAN Upper Ash Pond and LAN Landfill are no longer considered the likely source of the statistically significant levels (SSLs) above the GPS for arsenic at monitoring well MW-302. Instead, arsenic impacts in groundwater in the area of MW-302 are likely due to in-situ geochemical processes in organic-rich sediments present near MW-302. These processes and the source of arsenic in groundwater at MW-302 were described in ACM Addendum No. 2 (SCS, 2023).

Since ACM Addendum No. 2 was issued in June 2023, IPL has continued groundwater assessment monitoring. Current groundwater monitoring results were summarized in the 2023 Annual Groundwater Monitoring and Corrective Action Report issued for the LAN Landfill and LAN Upper Ash Pond on January 31, 2024.

3.0 CORRECTIVE MEASURES AND REMEDY SELECTION

Several corrective measure options were presented in detail in ACM Addendum No. 2, dated June 5, 2023.

This report identified the following corrective measure alternatives for the arsenic impacts to groundwater associated with the closed LAN Landfill and the LAN Upper Ash Pond where closure construction is complete:

- Alternative 1 (A1) – No Additional Action
- Alternative 2 (A2) – Close and Cap in Place with MNA
- Alternative 3 (A3) – Consolidate and Cap with MNA
- Alternative 4 (A4) – Excavate CCR and Dispose On Site with MNA
- Alternative 5 (A5) – Excavate CCR and Dispose Off Site with MNA
- Alternative 6 (A6) – Consolidate and Cap with Chemical Amendment
- Alternative 7 (A7) – Consolidate and Cap with Groundwater Collection
- Alternative 8 (A8) – Consolidate and Cap with Barrier Wall

The following sections present:

- A comparison to the minimum criteria set forth in 40 CFR 257.97(b).
- A discussion of the evaluating criteria in 40 CFR 257.97(c).
- A summary of the selected remedy.

3.1 APPLICABILITY OF CORRECTIVE MEASURES

A1

IPL is committed to implementing corrective measures as required under the Rule, and the No Additional Action alternative was included in ACM Addendum No. 2 as a viable alternative based on the available data indicating the CCR Units are not the source of groundwater impacts above the GPS at LAN. Under this alternative the closure of the LAN Upper Ash Pond will proceed as described in the Closure Plan for Existing CCR Surface Impoundment (currently Amendment No. 2 [SCS, 2020]) and in accordance with the requirements of 40 CFR 257.102(d), the closed LAN Landfill will be monitored in accordance with an existing State of Iowa sanitary disposal project closure permit, and groundwater monitoring will continue in accordance with 40 CFR 257.94.

A2 through A8

Based on the updated nature and extent of the groundwater impacts at LAN and the conclusion that the CCR units are not the source of arsenic in groundwater at concentrations exceeding the GPS in samples from MW-302, the arsenic detected in groundwater samples from MW-302 is no longer a matter of CCR Rule compliance. Therefore, corrective actions to address GPS exceedances via Alternatives 2 through 8 are no longer necessary and they have been eliminated from further consideration.

3.2 MINIMUM CRITERIA

The selected remedy must meet the minimum criteria set forth in 40 CFR 257.97(b). It is our opinion that Alternative 1 can meet the requirements in 40 CFR 257.97(b)(1) through (5) based on the information currently available and that no other alternatives are necessary since the arsenic GPS exceedances at MW-302 are not attributable to the CCR units at the LAN facility.

3.3 EVALUATION FACTORS

Each remaining alternative remedy was evaluated based on the criteria set forth in 257.97(c). Since the only remaining alternative is A1, the remedies were not compared with each other. However, to be responsive to the requirements in the CCR Rule, an evaluation of A1 based on the following evaluation criteria is provided in the sections that follow:

- **Long- and Short-Term Effectiveness [257.97(c)(1)]**
 - Magnitude of reduction of existing risks.
 - Magnitude of residual risks in terms of likelihood of further releases due to CCR remaining following implementation of a remedy.
 - The type and degree of long-term management required, including monitoring, operation, and maintenance.
 - Short-term risks to human health and the environment associated with:
 - Excavation
 - Transportation

- Re-disposal
- Time until full protection is achieved.
- Potential for exposure for humans and environmental receptors to remaining wastes, considering the potential threat to human health and the environment associated with excavation, transportation, re-disposal, or containment.
- Long-term reliability of the engineering and institutional controls.
- Potential need for replacement of the remedy.
- **Source Control to Reduce Future Releases [257.97(c)(2)]**
 - The extent to which containment practices will reduce further releases.
 - The extent to which treatment technologies may be used.
- **Ease or Difficulty of Implementation [257.97(c)(3)]**
 - Degree of difficulty associated with constructing the technology.
 - Expected operation reliability of the technologies.
 - Need to coordinate with and obtain necessary approvals and permits from other agencies.
 - Availability of necessary equipment and specialists.
 - Available capacity and location of needed treatment, storage, and disposal.
- **Community Acceptance [257.97(c)(4)]**
 - The degree to which community concerns are addressed by a potential remedy.

3.3.1 Long- and Short-Term Effectiveness [257.97(c)(1)]

Based on the discussion of potential receptors and pathways provided in ACM Addendum No. 2, the existing long- and short-term risks associated with the arsenic GPS exceedances at MW-302 are minimal.

- A1 provides a suitable reduction in existing risk.
- The magnitude of residual risks in terms of the likelihood of further releases due to CCR remaining at the LAN facility are adequately addressed by A1 and will be monitored during the post-closure period in accordance with the requirements of 40 CFR 257.104.
- The long-term monitoring, operation, and maintenance under A1 is defined by the post-closure care requirements in 40 CFR 257.104.
- There are no remaining short-term risks to human health and the environment associated with excavation, transportation, or re-disposal of CCR with A1 since all closure construction for the LAN Landfill and LAN Upper Ash Pond were completed in 2023.
- Full protection as required by the CCR Rule will be achieved with A1 once the certification of closure of the LAN Upper Ash Pond is completed, which is expected to occur in 2024.
- The potential for exposure for humans and environmental receptors to remaining wastes with A1 has been minimized by the closure construction completed to date.
- The long-term reliability of the engineering and institutional controls provided by A1 is good as they meet or exceed the requirements for final cover in 40 CFR 257.102(d)(3).

There is significant industry experience with the methods used in the construction of the final cover over CCR in the LAN Landfill and LAN Upper Ash Pond. Capping is a common practice and the industry standard for closure in place for remediation and solid waste management.

- The potential need to replace A1 is likely low. The success of this alternative will be evaluated during the post-closure care required by 40 CFR 257.104.

3.3.2 Source Control to Reduce Future Releases [257.97(c)(2)]

Based on investigations performed at the LAN facility to date, the LAN Landfill and LAN Upper Ash Pond are not the source of the SSLs above the GPS for arsenic at monitoring well MW-302. The additional information presented in ACM Addendum No. 2 indicates that there has not been a release from the CCR units at the LAN facility. Therefore, A1 provides suitable source control to reduce future releases.

3.3.3 Implementation [257.97(c)(3)]

The most difficult stages of implementing A1 have been completed with the design, permitting, and closure construction that concluded in 2023.

3.3.4 Community Acceptance [257.97(c)(4)]

No comments were received during the initial public meeting held on October 12, 2020, presenting the ACM. Additionally, no comments related to the ACM Addendum No. 1 were received during the public meeting held on January 11, 2022, presenting the November 2020 addendum to the ACM, nor were comments related to the ACM Addendum No. 2 during the public meeting on June 12, 2023.

In addition, the IDNR issued Sanitary Disposal Project Closure Permits #03-SDP-05-01C and #03-SDP-13-23C for the construction of the final cover at the LAN Landfill and the LAN Upper Ash Pond. The closure permits also regulate post-closure care of the consolidated and capped CCR at LAN that is part of A1.

3.4 SELECTED REMEDY

3.4.1 Remedy Description

A1 – No Additional Action has been selected based on the evaluation of factors defined in 257.97(c), presented above, and is the selected remedy.

IPL is committed to implementing corrective measures as required under the Rule, and the No Additional Action alternative is a viable alternative based on the available data, which indicates the CCR Units are not the source of groundwater impacts above the GPS at LAN. This alternative was presented in ACM Addendum No. 2 under the presumption that the closure of the LAN Upper Ash Pond would proceed as described in the Closure Plan for Existing CCR Surface Impoundment (currently Amendment No. 2 [SCS, 2020]) and in accordance with the requirements of 40 CFR 257.102(d), the LAN Landfill would close in accordance with the CCR Rule and existing State of Iowa sanitary disposal project permit, and groundwater monitoring will continue in accordance with 40 CFR 257.94. The presumed activities are underway or completed and A1 is an appropriate remedy.

3.4.2 Satisfying Minimum Criteria

The selected remedy is expected to meet the minimum criteria established in 257.97(b) and described in **Section 3.2**. Each requirement is discussed below. The selected remedy was evaluated considering the factors in 40 CFR 257.97(c), which are discussed in **Section 3.3**.

257.97(b)(1) – Be protective of human health and the environment:

Based on the currently available information for this site the CCR units are not the source of groundwater impacts. Thus, restoration under the federal CCR Rule corrective action process is not required.

257.97(b)(2) – Attain the GPS as specified pursuant to §257.95(h):

Currently there are no GPS exceedances pursuant to 257.95(h) that are attributable to the LAN Landfill or LAN Upper Ash Pond. No additional action (A1) is appropriate considering the lack of groundwater impacts related to the CCR Units at LAN.

257.97(b)(3) – Control the source(s) of releases so as to reduce or eliminate, to the maximum extent feasible, further releases of constituents in appendix IV to this part into the environment:

Although no release has occurred, the closure of the LAN Landfill and the LAN Upper Ash Pond in accordance with the written closure plans under A1 will minimize the potential for future releases from the CCR remaining in the LAN Landfill and LAN Upper Ash Pond.

257.97(b)(4) – Remove from the environment as much of the contaminated material that was released from the CCR unit as is feasible, taking into account factors such as avoiding inappropriate disturbance of sensitive ecosystems:

No releases of CCR from the LAN Landfill or the LAN Upper Ash Pond or groundwater impacts attributable to these CCR Units have been identified.

257.97(b)(5) – Comply with standards for management of wastes as specified in § 257.98(d):

All CCR or other waste generated during closure construction for the LAN Landfill and LAN Upper Ash Pond were managed in accordance with applicable Resource Conservation and Recovery Act (RCRA) requirements. The selected remedy will comply with the standards for the management of wastes described in 40 CFR 257.98(d) by monitoring the generation, transportation, treatment, storage, and disposal of wastes subject to RCRA requirements. IPL will work with project management, corporate and on-site environmental staff, consultants, contractors, and vendors to identify the materials generated during future construction, operation, and maintenance of the selected remedy. The management of wastes subject to RCRA will be documented through appropriate recordkeeping, reporting, labeling, exportation, and containerization to uphold the RCRA program's principal objectives as described by U.S. EPA (U.S. EPA, 2023):

- Protect human health and the environment from potential adverse effects of improper solid waste management.
- Conserve material and energy resources through waste recycling and recovery.
- Reduce or eliminate the generation of waste as expeditiously as possible.

It is our opinion that Alternative 1 can meet the requirements in 40 CFR 257.97(b)(1) through (5) based on the information currently available and that no other alternatives are necessary since the arsenic GPS exceedances at MW-302 are not attributable to the CCR units at the LAN facility.

4.0 SCHEDULE

An estimated schedule for the implementation of the selected groundwater corrective action is provided in **Appendix C**. The estimated schedule for the groundwater collection system builds on the estimated ash pond closure schedule provided in the latest written closure plan for the LAN Upper Ash Pond (SCS, 2020).

The schedule provided in **Appendix C** is based on the LAN Landfill closure completed in 2023 and assumes the closure certification for the LAN Upper Ash Pond will occur in 2024 and post-closure care for both units will continue in accordance with 40 CFR 257.104. The schedule only shows the first year of post-closure care. The full duration and final completion of the post-closure care period for the CCR Units at LAN are not represented on the enclosed Gantt chart schedule.

The schedule described above and provided in **Appendix C** is based on the following considerations, as described in 257.97(d) and discussed below.

257.97(d)(1) – Extent and nature of contamination, as determined by the characterization required under §257.95(g):

Investigations of the nature and extent of arsenic in groundwater attributed to the CCR Units at LAN are complete, and no GPS exceedances attributable to the CCR Units were identified. Given the lack of CCR Unit-related GPS exceedances and human and ecological receptors, ongoing monitoring and the remedy schedule enclosed should be protective of human health and the environment. Groundwater monitoring will continue as the selected remedy is implemented, and, unless significant changes in the nature of the impacts are observed, the schedule described above will not be impacted.

257.97(d)(2) – Reasonable probabilities of remedial technologies in achieving compliance with the GPS's established under §257.95(h) and other objectives of the remedy:

The selected alternative (A1) does not require remedial technologies to achieve compliance with the arsenic GPS established under §257.95(h) or other objectives of the remedy, and remedial technologies did not impact the schedule provided in **Appendix C**.

257.97(d)(3) – Availability of treatment or disposal capacity for CCR managed during implementation of the remedy:

The availability of treatment or disposal capacity is not a factor for the selected remedy schedule. The capacity to manage CCR from the LAN CCR Units was available on-site within the current footprint of the units in accordance with the written closure plans and 257.102(d).

257.97(d)(4) – Potential risks to human health and the environment from exposure to contamination prior to completion of the remedy:

Based on the discussion of potential receptors and exposure pathways provided in ACM Addendum No. 2 (SCS 2023), the potential risks to human health and the environment from exposure to arsenic in groundwater near MW-302 are minimal.

257.97(d)(5) – Resource value of the aquifer:

The aquifer in the area of arsenic impacts is not currently used as a water supply for human or animal consumption or irrigation. However, the uppermost aquifer is a regional water supply source. The two nearest active water supply wells are onsite wells operated by IPL that were recently abandoned as part of the plant decommissioning. The next closest water supply well in the area is located upgradient across County Highway X52. As discussed in ACM Addendum No. 2, this well is over 400 feet deep and arsenic was not detected in the most recent sample from this well. IPL and SCS Engineers (SCS) are not aware of any additional samples from this well since. The value of the aquifer in this area is unlikely to change significantly over the time required to implement the selected remedy. It is also unlikely that the resource value of the aquifer will change over the 30-year post-closure period for the CCR units. If needed, the area of impact could be protected further using institutional controls such as a deed notice or restriction.

257.97(d)(6) – Other relevant factors:

Because the No Further Action alternative has been selected, the schedule provided in **Appendix C** reflects the LAN CCR unit closure construction activities completed to date, and only an estimated closure date for the LAN Upper Ash Pond. The remaining scheduled activities focus on post-closure care requirements in 40 CFR 257.104.

5.0 CONCLUSION

The Selection of Remedy Report was prepared to fulfill the requirements of the final report identified in 40 CFR 257.97(a) and identify the remedy selected to address the arsenic GPS exceedances at LAN. Based on the site information currently available, A1 – No Additional Action has been selected as the remedy that meets the requirements of 40 CFR 257.97(b) based on the evaluation factors described in 257.97(c).

A schedule for the implementation and completion of the selected remedy was established under 40 CFR 257.97(d) that describes how IPL will initiate remedial activities within 90 days of this Selection of Remedy Report as required in 40 CFR 257.98(a). Remedial activities will begin with the post-closure care of the LAN Landfill and LAN Upper Ash Pond under 40 CFR 257.104.

6.0 REFERENCES

U.S. Environmental Protection Agency, 2015, in the Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residual from Electric Utilities; Final Rule, date April 17, 2015

United States Environmental Protection Agency, 1999, “A Guide to Preparing Superfund Proposed Plans, Records of Decision, and Other Remedy Selection Decision Documents.” July 1999

SCS Engineers, 2023, Addendum No. 2 Assessment of Corrective Measures Landfill and Surface Impoundment, June 5, 2023.

SCS Engineers, 2020, Closure Plan for Existing CCR Surface Impoundment – Amendment No. 2 Upper Ash Pond, November 13, 2020.

U.S. Environmental Protection Agency, 2023, Resource Conservation and Recovery Act, Basics of RCRA (URL <https://www.epa.gov/fedfacts/resource-conservation-and-recovery-act-rcra#Basics>) March, 2023

Tables

- 1 Groundwater Monitoring Well Network
- 2 CCR Rule Groundwater Samples Summary

Table 1. Groundwater Monitoring Well Network
Lansing Generating Station / SCS Engineers Project #25220082.00

Monitoring Well	Location in Monitoring Network	Role in Monitoring Network
MW-6	Upgradient	Background
MW-301	Downgradient	Compliance
MW-302	Downgradient	Compliance
MW-302A	Downgradient, deeper	Delineation
MW-303	Downgradient	Compliance
MW-304	Downgradient	Delineation
MW-304A	Downgradient, deeper	Delineation
MW-305	Downgradient	Delineation
MW-306	Downgradient	Delineation
MW-306A	Downgradient, deeper	Delineation
MW-307	Downgradient	Delineation
MW-307A	Downgradient, deeper	Delineation
MW-308	Downgradient	Groundwater Elevation Only
MW-309	Downgradient	Groundwater Elevation Only

Created by: RM
 Last revision by: NLB
 Checked by: RM

Date: 12/14/2020
 Date: 12/27/2023
 Date: 1/3/2024

Table 2. CCR Rule Groundwater Samples Summary
Lansing Generating Station / SCS Engineers Project #25220082.00

Sample Dates	Background Well	Downgradient Wells													
		MW-6	MW-301	MW-302	MW-302A	MW-303	MW-304	MW304A	MW-305	MW-306	MW-306A	MW-307	MW-307A	MW-308	MW-309
10/2/2019	A	A	A	NI	A	A	NI	A	A	NI	NI	NI	NI	NI	NI
12/5/2019	--	--	--	NI	--	--	NI	--	Add.	NI	NI	NI	NI	NI	NI
2/5/2020	--	--	--	--	--	--	--	--	Add.	--	NI	NI	NI	NI	NI
5/20/2020	A	A	A	A	A	A	A	A	A	NI	NI	NI	NI	NI	NI
7/6/2020	--	--	--	A	--	--	A	--	--	A	NI	NI	NI	NI	NI
8/18/2020	Add.	Add.	Add.	Add.	Add.	Add.	Add.	Add.	Add.	Add.	NI	NI	NI	NI	NI
10/19-20/2020	A	A	A	A	A	A	A	A	A	A	NI	NI	NI	NI	NI
2/23/2021	--	--	--	--	--	--	Add.	--	Add.	--	NI	NI	NI	NI	NI
4/7-9/2021	A	A	A	A	A	A	A	A	A	NI	NI	NI	NI	NI	NI
7/12/2021	--	--	--	--	--	--	Add.	--	Add.	--	A	A	--	--	--
8/13/2021	--	--	--	--	--	--	--	--	--	--	A	A	--	--	--
10/25-27/2021	A	A	A	A	A	A	A	A	A	A	A	A	--	--	--
4/4-6/2022	A	A	A	A	A	A	A	A	A	A	A	A	WL	WL	WL
10/17-19/2022	A	A	A	A	A	A	A	A	A	A	A	A	WL	WL	WL
4/10-11/2023	A	A	A	A	DRY	A	A	A	A	A	A	A	WL	WL	WL
10/30-31/2023	A	A	A	A	DRY	A	A	A	A	A	A	A	WL	WL	WL
Total Samples	10	10	10	10	10	10	12	10	14	10	7	7	N/A	N/A	

Abbreviations:

A = Samples analyzed for assessment monitoring parameters
Add. = Additional sampling event for selected parameters

-- = Not Sampled
NI = Not Installed

N/A= not applicable
WL = Water level measurement only

Notes:

Monitoring wells MW-308 and MW-309 were installed for horizontal groundwater flow and sample collection is not currently planned for these two wells.

Created by: NDK Date: 2/19/2020
Last revision by: RM Date: 4/8/2024
Checked by: NLB Date: 4/8/2024

Figures

- 1 Site Location Map
- 2 Site Plan and Monitoring Well Locations




LANSING QUADRANGLE
IOWA—ALLAMAKEE CO.
7.5 MINUTE SERIES (TOPOGRAPHIC)
2018
SCALE: 1" = 2,000'



CLIENT	INTERSTATE POWER AND LIGHT 2320 POWER PLANT DRIVE LANSING, IA 52151-9733	SITE	ALLIANT ENERGY LANSING GENERATING STATION LANSING, IOWA	SITE LOCATION MAP	
PROJECT NO.	25219070.00	DRAWN BY:	BSS	ENGINEER	FIGURE
DRAWN:	11/27/2019	CHECKED BY:	MDB	SCS ENGINEERS	
REVISED:	11/27/2019	APPROVED BY:	TK 01/30/2020	2830 DAIRY DRIVE MADISON, WI 53718-6751 PHONE: (608) 224-2830	1

I:\25219070.00\Drawings\CCR 2019 Annual Report\Site Location Map.dwg, 1/30/2020 3:31:40 PM



Appendix A

Historical Groundwater Quality Data

Single Location

Name: IPL - Lansing

Location ID: MW-6		Number of Sampling Dates: 24																							
Parameter Name	Units	12/10/2015	4/29/2016	7/20/2016	10/27/2016	1/18/2017	4/19/2017	6/19/2017	8/15/2017	10/16/2017	4/16/2018	4/26/2018	8/7/2018	10/8/2018	4/15/2019	10/2/2019	5/20/2020	8/19/2020	10/20/2020	4/7/2021	10/26/2021	4/6/2022	10/18/2022	4/11/2023	10/30/2023
Boron	ug/L	25.7	<50	<50	<50	<50	31.9	42.1	40	41.2	--	29.8	42.9	40.2	<110	<110	<73	--	<80	<58	64	<58	<58	<76	<76
Calcium	mg/L	64	72.6	68.9	68.6	68.6	67.8	64.6	68.2	66.9	--	72.7	66.5	69.6	67	70	72	--	69	71	72	71	70	79	73
Chloride	mg/L	7.5	7.6	8.1	6.8	6.5	6.3	6.2	6.5	6.5	--	6.5	7.3	6.6	6.7	6.9	7.7	6.8	5.6	7	6.8	5.3	5.1	6.5	5.5
Fluoride	mg/L	0.094	0.15	0.082	0.12	0.092	<0.1	0.1	0.12	0.14	--	0.084	0.12	<0.19	0.63	<0.23	<0.23	--	<0.23	0.34	<0.28	<0.22	<0.22	<0.38	<0.38
Field pH	Std. Units	7.44	7.64	7.25	7.56	7.62	7.48	7.4	7.48	7.03	--	7.34	7.18	7.06	7.59	7.46	7.34	7.98	7.42	7.39	7.7	7.32	7.4	7.15	7.38
Sulfate	mg/L	23	22.2	22.5	25.2	24.8	25.5	27.4	26.9	25.8	--	26.4	24.8	25.5	26	24	27	25	25	23	25	25	21	21	22
Total Dissolved Solids	mg/L	382	328	352	337	324	350	337	333	318	--	343	351	319	340	280	580	--	300	290	240	280	250	350	280
Antimony	ug/L	0.18	<0.058	<0.058	<0.058	<0.058	<0.026	0.027	0.037	--	--	<0.026	<0.15	<0.078	<0.53	--	<0.58	--	--	<1.1	<1.1	<0.69	<0.69	<1	<1
Arsenic	ug/L	<4.5	0.28	0.26	0.19	0.23	0.28	0.18	0.28	--	--	0.23	0.26	0.24	<0.75	<0.75	<0.88	--	<0.88	<0.75	<0.75	<0.75	<0.53	<0.53	<0.53
Barium	ug/L	45.5	45.6	43.8	44.6	46.5	45.4	41.9	44	--	--	44.1	43.1	43	43	46	46	--	45	49	47	48	49	49	46
Beryllium	ug/L	<0.17	<0.08	<0.08	<0.08	<0.08	<0.012	<0.012	<0.012	--	--	<0.012	<0.12	<0.089	<0.27	--	<0.27	--	--	<0.27	<0.27	<0.27	<0.27	<0.33	<0.33
Cadmium	ug/L	<0.56	<0.029	<0.029	<0.029	<0.029	<0.018	<0.018	<0.018	--	--	<0.018	--	<0.033	<0.077	--	<0.039	--	<0.049	<0.051	<0.051	<0.055	<0.055	<0.1	<0.1
Chromium	ug/L	<0.96	0.82	0.81	0.81	1.1	0.76	0.68	0.71	--	--	0.66	0.97	0.73	<0.98	<0.98	<1.1	--	<1.1	<1.1	<1.1	<1.1	<1.1	<1.1	<1.1
Cobalt	ug/L	<0.1	<0.5	<0.5	<0.5	<0.5	0.034	0.021	<0.014	--	--	<0.014	<0.15	<0.062	<0.091	<0.091	<0.091	--	<0.091	<0.091	<0.19	<0.19	<0.19	<0.17	<0.17
Lead	ug/L	<1.9	<0.19	<0.19	<0.19	<0.19	<0.19	0.13	<0.033	0.065	--	--	<0.033	<0.12	<0.13	<0.27	<0.27	<0.27	--	<0.11	<0.21	<0.21	<0.24	<0.24	<0.24
Lithium	ug/L	<2.5	<4.9	<4.9	<4.9	<4.9	<2.9	<2.9	3	--	--	<4.6	--	<4.6	<2.7	<2.7	<2.3	--	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5
Mercury	ug/L	<0.012	<0.039	<0.039	<0.039	<0.039	<0.046	<0.046	<0.046	--	--	<0.09	<0.09	<0.09	<0.1	--	<0.1	--	--	<0.15	<0.15	<0.11	--	<0.14	<0.14
Molybdenum	ug/L	<1.5	0.25	0.24	0.31	0.21	0.25	0.26	0.31	--	--	0.26	0.28	<0.57	<1.1	<1.1	<1.1	<1.1	<1.1	<1.3	<1.3	<1.2	<1.2	<0.91	<0.91
Selenium	ug/L	<5.8	0.57	0.46	0.54	0.36	0.5	0.36	0.52	--	--	0.47	0.5	0.46	<1	--	<1	--	<1	<0.96	<0.96	<0.96	<0.96	<1.4	<1.4
Thallium	ug/L	0.18	<0.5	<0.5	<0.5	<0.5	0.11	<0.036	0.29	--	--	<0.036	--	<0.099	<0.27	--	<0.26	--	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26
Total Radium	pCi/L	1.51	0.458	0.724	0.6	0.397	0.0972	1.06	0.826	--	1.35	--	0.974	1.37	--	0.495	--	--	0.644	0.359	0.779	0.0823	1.29	0.0554	<0.643
Radium-226	pCi/L	0.599	0.232	0.0668	0.126	0	-0.07	0.457	0.633	--	0	--	0.547	0.705	--	0.237	--	--	0.0266	0.109	0.232	0.0404	0.109	0.0554	<0.286
Radium-228	pCi/L	0.913	0.226	0.657	0.474	0.397	0.0972	0.606	0.193	--	1.35	--	0.427	0.668	--	0.259	--	--	0.618	0.249	0.547	0.0419	1.18	<0.629	<0.643
pH at 25 Degrees C	Std. Units	8	7.7	7.4	7.7	8.1	7.8	7.2	7.5	7.5	--	7.7	7.5	7.4	7.5	7.5	7.5	--	7.4	7.5	7.5	7.6	7.6	7.6	7.5
Field Oxidation Potential	mV	166.8	243.7	45.8	122	163	321	251	142	282	--	34.6	233	119	274	88.9	119.6	113.9	68.5	186.2	136.2	197.7	47.3	141.4	-12.3
Field Specific Conductance	umhos/cm	606.4	596.2	582.4	590	589	589	580	588	591	--	569.1	609	587	618	590	597	597	575.5	599	601	599	552.6	595.6	565.2
Field Temperature	deg C	9.6	9.7	9.9	10	8	10.3	11.2	11.4	10.2	--	11.1	10.5	11.5	10	10	10	9.8	9.7	10	9.9	8.9	9.7	9.9	9.7
Groundwater Elevation	feet	662.28	662.08	663.21	670.82	666.28	669.82	670.65	670.61	669.58	--	667.96	668.13	664.71	672.78	675.54	674.47	674.64	673.37	671.08	668.14	667.14	665.34	664.79	663.59
Oxygen, Dissolved	mg/L	9.44	7.7	4.98	8.6	9.8	7.1	3.7	5.8	8.8	--	3.46	7.4	9.1	8.7	10.29	9.2	9.45	8.23	9.06	9.34	8.92	8.16	8.38	7.94
Turbidity	NTU	--	0.41	0.01	2.1	0	1.71	1.35	0	0	--	0.81	1.77	0.01	0.75	0.7	0.01	0	0	0	0	0	0.6	0.97	0
Total Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	290	300	310	380	330	300	--	--
Iron, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<50	<50	49	<36	<36	<36	<36	--	
Manganese, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	6.6	25	5.1	<4.4	14	<3.6	--	--	
Calcium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	74000	--	--	--	--	--	--	
Iron, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<0.05	<50	<36	<36	<36	<36	<36	<36	
Magnesium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	37000	36000	35000	35000	32000	--	--	
Manganese, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<0.004	<4	<4.4	<4.4	<4.4	<3.6	<3.6	--	
Potassium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	1100	1100	1100	1100	930	--	--	
Sodium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	4500	4600	4500	4500	4100	--	--	
Bicarbonate Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	290	300	310	380	330	300	--	--
Carbonate Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<3.8	<3.8	<3.8	<4.4	<4.6	<4.6	<4.6	--	
Arsenic, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	2.8	--	--	<0.75	--	--	--	--	
Molybdenum, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	4.7	--	--	--	--	--	--	--	

Single Location

Name: IPL - Lansing

Location ID: MW-301		Number of Sampling Dates: 24																								
Parameter Name	Units	12/10/2015	4/29/2016	7/20/2016	10/26/2016	1/17/2017	4/19/2017	6/19/2017	8/15/2017	10/16/2017	4/16/2018	6/4/2018	8/7/2018	10/8/2018	4/15/2019	10/2/2019	5/19/2020	8/18/2020	10/19/2020	4/8/2021	10/26/2021	4/5/2022	10/17/2022	4/10/2023	10/31/2023	
Boron	ug/L	739	436	417	554	471	405	333	365	436	198	--	279	357	250	360	150	--	260	160	260	220	260	440	650	
Calcium	mg/L	41	39.1	45.1	55.5	56.4	61.7	59.5	66.4	65.9	64.5	--	65.1	72.5	73	68	56	--	57	58	68	69	67	48	83	
Chloride	mg/L	25.5	18.5	18.2	15.8	16	18.3	18	16.2	17.3	20.2	--	17.7	15.9	17	14	17	15	15	18	17	22	15	23	29	
Fluoride	mg/L	0.3	0.32	0.25	0.26	0.21	0.19	0.23	0.26	0.24	0.24	--	0.23	0.27	0.9	0.23	0.56	--	<0.23	0.38	<0.28	<0.22	<0.22	<0.38	<0.38	
Field pH	Std. Units	7.96	8.23	7.86	8.1	8.37	8.5	8.25	8.19	7.66	8.39	8.1	8.08	8.16	8.47	8.11	7.85	8.33	8.06	8.04	8.11	8.3	8.1	8.05	7.71	
Sulfate	mg/L	62.2	38.8	37.5	45.7	55.6	48.7	44.7	49.4	52.7	49.3	--	53.2	64.4	51	56	34	44	48	27	49	86	63	38	58	
Total Dissolved Solids	mg/L	280	176	218	246	271	289	278	285	289	--	300	326	320	350	310	480	--	280	240	210	260	280	180	340	
Antimony	ug/L	0.078	0.086	<0.058	<0.058	0.088	<0.026	0.08	0.079	--	0.071	--	0.16	0.085	<0.53	--	<0.58	--	--	<1.1	<1.1	<0.69	<0.69	<1	<1	
Arsenic	ug/L	<4.5	2.3	2.8	3.5	3.8	3.1	3	3.8	--	3.9	--	4.4	5.4	5.4	5.6	3.8	--	6	5	7.1	4.9	5	3.7	2.9	
Barium	ug/L	146	139	182	220	227	182	175	196	--	163	--	156	155	160	180	140	--	150	140	160	130	160	73	160	
Beryllium	ug/L	<0.17	<0.08	<0.08	<0.08	<0.08	<0.012	<0.012	<0.012	--	<0.012	--	<0.12	<0.089	<0.27	--	<0.27	--	--	<0.27	<0.27	<0.27	<0.27	<0.33	<0.33	
Cadmium	ug/L	<0.56	<0.029	<0.029	<0.029	<0.029	0.021	<0.018	<0.018	--	<0.018	--	<0.033	<0.077	--	<0.039	--	<0.049	0.06	<0.051	<0.055	<0.055	<0.1	<0.1		
Chromium	ug/L	<0.96	<0.34	<0.34	0.35	0.49	0.97	0.21	0.23	--	1.1	--	<0.19	0.09	<0.98	<0.98	<1.1	--	<1.1	<1.1	<1.1	<1.1	<1.1	<1.1		
Cobalt	ug/L	0.13	<0.5	<0.5	<0.5	<0.5	0.098	0.074	0.07	--	0.086	--	0.16	0.11	0.11	0.11	0.11	--	0.11	0.11	0.23	<0.19	<0.19	<0.17		
Lead	ug/L	<1.9	<0.19	0.23	<0.19	0.23	0.36	0.041	<0.033	--	0.037	--	<0.12	<0.13	<0.27	<0.27	<0.27	--	<0.11	<0.21	0.37	<0.24	<0.24	<0.24		
Lithium	ug/L	5	5.3	5	6.4	<4.9	<2.9	4.2	7.3	--	<4.6	--	--	9.1	8.7	8	7	--	7.9	7.1	6.7	7.3	8.7	5.8	8.1	
Mercury	ug/L	<0.012	<0.039	<0.039	<0.039	<0.039	<0.046	<0.046	<0.046	--	0.31	--	<0.09	<0.09	<0.1	--	<0.1	--	--	<0.15	<0.15	<0.11	--	<0.14	<0.14	
Molybdenum	ug/L	2.5	5.5	5	8.1	9.3	6.9	5.5	6.8	--	4.4	--	5.6	10.3	11	10	8.1	5.8	7.5	6.8	6.2	7.6	12	14	11	
Selenium	ug/L	<5.8	<0.18	<0.18	<0.18	<0.18	<0.18	0.12	0.1	0.13	--	<0.086	--	0.22	0.18	<1	--	<1	--	<1	<0.96	<0.96	<0.96	<0.96	1.9	<1.4
Thallium	ug/L	0.064	<0.5	<0.5	<0.5	<0.5	0.14	0.05	0.31	--	<0.036	--	--	<0.099	<0.27	--	<0.26	--	--	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	
Total Radium	pCi/L	0.436	0.525	0.126	1.03	0.647	0.752	0.453	1.86	--	0.689	--	1.66	0.556	--	0.488	--	--	0.889	0.244	0.814	0.103	0.83	0.521	0.324	
Radium-226	pCi/L	0.349	0.111	0.126	0.236	0.334	0.374	0.0591	1.03	--	0	--	0.692	0.115	--	0.372	--	--	0.339	0.0913	0.259	0.103	0.296	0.043	0.288	
Radium-228	pCi/L	0.087	0.414	-0.0306	0.791	0.313	0.378	0.394	0.826	--	0.689	--	0.972	0.441	--	0.116	--	--	0.55	0.153	0.555	-0.168	0.534	0.478	0.0367	
pH at 25 Degrees C	Std. Units	7.8	8	7.8	7.8	7.8	7.8	7.8	8.1	7.9	8	--	8.1	8	7.9	8.1	8.1	--	8.1	8	8.1	8.2	8.2	7.8		
Field Oxidation Potential	mV	-94.9	-134.2	-166.3	-156	-98	-181	-230	-178	-221	-40	-145.5	-149	-180	-171	-156.8	-77.6	-115.3	-97	-10.1	-159.7	200	-185.1	-149.6	-96	
Field Specific Conductance	umhos/cm	431.4	355.2	377.4	456	491	471	468	498	497	505	507	524	545	539	501.8	474	476	488.8	461	534	554	526	352.2	639.4	
Field Temperature	deg C	13.6	8.9	13.3	15.4	12.3	10.6	12.2	14.7	17	9.5	12.2	14.6	17.4	11.3	15.6	11.3	15	14.7	11.5	16.1	8.7	12.5	10.3	12.4	
Groundwater Elevation	feet	623.54	622.19	624.76	624.97	624.09	624.7	624.89	624.09	625.7	624.29	624.62	624.51	625.73	629.19	626.54	624.46	625.02	624.42	624.02	627	630.67	630.79	623.4	622.2	
Oxygen, Dissolved	mg/L	1.08	0.34	0.16	0	1.6	0.3	0	0	0	1	0.89	0.2	0.3	0.2	0.13	0.75	0.16	0.42	0.27	0.1	0.15	0.08	0.19	0.62	
Turbidity	NTU	--	1.9	2	6.79	4.27	3.04	0.2	4.87	0.05	8.31	2.72	5.5	9.19	9.33	1.36	1.39	1.65	0.75	0	0.81	0	1.31	0	0.49	
Total Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	200	160	220	260	200	230	--	
Iron, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	330	110	320	430	280	410	250	
Manganese, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	810	530	650	530	570	590	--	
Calcium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	62000	--	--	--	--	--		
Iron, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	500	740	640	620	--	250		
Magnesium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	18000	19000	18000	21000	18000	--		
Manganese, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	560	670	530	590	640	--		
Potassium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	3600	2600	3700	3000	3200	--		
Sodium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	11000	13000	13000	16000	14000	--		
Bicarbonate Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	200	160	220	260	200	230	--	
Carbonate Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<3.8	<3.8	<4.6	<4.6	<4.6	--		
Arsenic, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	4.5	--	--	6.8	--	--		
Molybdenum, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	6.1	--	--	--	--	--		

Single Location

Name: IPL - Lansing

Location ID: MW-302		Number of Sampling Dates: 24																							
Parameter Name	Units	12/10/2015	4/29/2016	7/20/2016	10/26/2016	1/17/2017	4/19/2017	6/19/2017	8/15/2017	10/16/2017	4/16/2018	6/4/2018	8/7/2018	10/8/2018	4/15/2019	10/2/2019	5/20/2020	8/19/2020	10/19/2020	4/9/2021	10/27/2021	4/5/2022	10/19/2022	4/11/2023	10/30/2023
Boron	ug/L	564	468	579	673	576	527	558	645	708	489	--	648	694	690	690	480	--	640	460	630	540	780	480	590
Calcium	mg/L	95.1	96.5	97.8	110	116	112	118	116	120	--	116	122	130	130	120	--	110	120	120	110	130	130	130	
Chloride	mg/L	17	14.9	15.1	15.5	15.7	12.9	14.4	15	13.9	13	--	13.9	13.5	13	12	14	12	11	11	14	12	11	15	16
Fluoride	mg/L	0.26	0.28	0.22	0.26	0.21	0.22	0.25	0.25	0.28	0.24	--	0.23	0.27	0.79	0.24	0.25	--	<0.23	0.31	1.3	<0.22	<0.22	0.66	<0.38
Field pH	Std. Units	7.15	7.41	6.86	7.12	7.25	7.25	7.03	6.96	7.1	7.26	6.97	6.92	6.93	7.66	7.15	6.93	7.18	7.06	7.08	6.89	6.92	6.87	7.19	7.21
Sulfate	mg/L	9.8	0.72	0.29	0.32	<0.15	<0.5	<0.5	<0.5	<0.5	<0.24	--	<0.24	<0.24	<1.8	<1.8	<3.6	<3.6	<3.6	<2.5	<2.5	<2	<2	<2.1	<2.1
Total Dissolved Solids	mg/L	503	422	438	499	497	503	512	517	507	--	535	562	518	450	480	710	--	490	470	450	490	520	530	520
Antimony	ug/L	0.091	<0.058	<0.058	<0.058	0.14	<0.026	0.048	0.069	--	0.035	--	<0.15	<0.078	<0.53	--	<0.58	--	--	<1.1	<1.1	<0.69	<0.69	<1	<1
Arsenic	ug/L	33.9	30.4	41	50.2	45	31.7	36.7	47.3	--	30.8	--	47.6	50.4	37	53	33	--	48	33	51	40	51	42	64
Barium	ug/L	483	479	540	648	706	559	597	660	--	789	--	661	603	690	740	610	--	630	630	680	690	790	800	830
Beryllium	ug/L	<0.17	<0.08	<0.08	<0.08	0.1	0.016	<0.012	0.012	--	<0.012	--	<0.12	<0.089	<0.27	--	<0.27	--	--	<0.27	<0.27	<0.27	<0.27	<0.33	<0.33
Cadmium	ug/L	<0.56	<0.029	<0.029	<0.029	0.074	<0.018	<0.018	<0.018	--	<0.018	--	<0.033	<0.077	--	<0.039	--	<0.049	0.06	0.076	<0.055	<0.055	<0.1	<0.1	
Chromium	ug/L	<0.96	0.56	0.39	0.56	3.5	1	0.51	0.44	--	0.35	--	0.49	0.39	<0.98	<0.98	<1.1	--	<1.1	<1.1	<1.1	<1.1	<1.1	<1.1	<1.1
Cobalt	ug/L	1.6	1.1	1.2	1.1	3.2	1.1	1.2	1.2	--	1.1	--	1.1	1.1	1.5	1.3	1	--	0.86	1	1.1	1.5	1.2	1.3	1.3
Lead	ug/L	<1.9	<0.19	0.32	<0.19	3.3	0.36	0.14	0.075	--	0.084	--	0.23	<0.13	<0.27	<0.27	<0.27	--	<0.11	<0.21	1	<0.24	0.39	<0.24	<0.24
Lithium	ug/L	<2.5	<4.9	<4.9	<4.9	<4.9	<2.9	<2.9	<2.9	--	<4.6	--	--	<4.6	<2.7	<2.7	<2.3	--	<2.5	<2.5	<2.5	<2.5	<2.5	<2.5	
Mercury	ug/L	<0.012	<0.039	<0.039	<0.039	<0.039	<0.046	<0.046	<0.046	--	0.35	--	<0.09	<0.09	<0.1	--	<0.1	--	--	<0.15	<0.15	<0.11	--	<0.14	<0.14
Molybdenum	ug/L	<1.5	0.81	0.98	1.2	1.1	0.87	0.91	1.2	--	0.91	--	1.2	1.5	<1.1	1.4	<1.1	<1.1	<1.1	1.7	1.4	<1.2	1.2	1.9	1.4
Selenium	ug/L	<5.8	0.2	0.22	0.28	0.36	0.25	0.19	0.31	--	<0.086	--	0.3	0.26	<1	--	<1	--	<1	1.2	<0.96	<0.96	<0.96	2.9	<1.4
Thallium	ug/L	0.25	<0.5	<0.5	<0.5	<0.5	0.042	<0.036	0.14	--	<0.036	--	--	<0.099	<0.27	--	<0.26	--	--	2.5	0.31	<0.26	<0.26	<0.26	0.34
Total Radium	pCi/L	1.46	2.14	2.07	1.73	1.49	1.25	2.75	1.68	--	1.96	--	2.09	3.52	--	1.48	--	--	1.41	1.57	1.59	1.35	4.33	1.07	2.68
Radium-226	pCi/L	0.415	0.985	0.969	0.539	0.514	0.672	1.36	0.619	--	0.776	--	1.23	1.67	--	0.807	--	--	0.531	0.747	0.907	0.804	0.888	0.964	0.714
Radium-228	pCi/L	1.04	1.15	1.1	1.19	0.978	0.576	1.39	1.06	--	1.18	--	0.858	1.85	--	0.675	--	--	0.88	0.819	0.68	0.744	3.44	0.11	1.96
pH at 25 Degrees C	Std. Units	7.3	7.2	7	7	6.9	7.2	7.2	7	--	7	7.3	--	7	6.9	7	7	7	--	7.1	7	7	7	7	7
Field Oxidation Potential	mV	-150.3	-163.3	-141.5	-171	-154	-172	-189	-181	-179	-152	-179.3	-164	-43.9	-159	-160	-161.5	-173	-182.5	-171.2	-128.1	202.8	-186.2	-181.4	-177.4
Field Specific Conductance	umhos/cm	918	875	891	1004	1036	971	1017	1053	1045	1098	1068	1095	1039	1089	1049	1070	1039	1074	1043	1075	1151	1045	871	1185
Field Temperature	deg C	12.7	7.8	14.2	15.6	9.3	7.6	11.4	15.7	16.2	6	10.8	15.3	16.99	7.1	15.9	8.7	16.2	14.4	7.5	15.7	6.3	14.5	6.9	13.4
Groundwater Elevation	feet	627.88	626.93	628.6	628.35	627.32	628.98	627.75	627.28	628.75	628.98	628.27	627.62	628.59	629.99	630.04	627.68	627.53	627.14	627.87	628.86	623.29	629.51	628.61	627.05
Oxygen, Dissolved	mg/L	0.08	0.1	0.03	0	0.2	0	0	0	0	0.8	0.12	0.1	0.48	0.2	0.11	0.19	0.05	0.1	0.03	1.07	0.13	0.03	0.29	0.26
Turbidity	NTU	--	4.98	2.6	11.14	93.1	3.36	4.61	4.28	3.96	5.25	1.46	11.23	5.92	18.39	4.71	4.16	4	2.96	3.15	3.35	3.21	23.33	4.54	0.82
Total Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	530	540	550	620	540	--	--
Iron, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	32000	30000	33000	33000	44000	40000	47000
Manganese, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	2800	2500	2400	2600	3000	2500	--
Calcium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	130000	--	--	--	--	--	
Iron, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	33000	36000	35000	45000	43000	--	45000
Magnesium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	42000	41000	39000	49000	42000	--	--
Manganese, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	2700	2500	2700	3000	2300	--	--
Potassium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	4300	3200	4300	3900	3900	--	--
Sodium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	17000	16000	18000	21000	19000	--	--
Bicarbonate Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	530	540	550	620	540	--	--
Carbonate Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<7.6	<3.8	<4.6	<4.6	<4.6	--	--
Arsenic, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	46	44	33	48	38	50	--
Molybdenum, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	1.4	--	--	--	--	--	

Single Location

Name: IPL - Lansing

MW-302A											
Number of Sampling Dates: 10											
Parameter Name	Units	5/20/2020	7/6/2020	8/19/2020	10/19/2020	4/9/2021	10/27/2021	4/5/2022	10/17/2022	4/11/2023	10/31/2023
Boron	ug/L	190	250	--	160	170	140	170	190	--	--
Calcium	mg/L	79	78	--	72	75	75	73	74	--	--
Chloride	mg/L	7.8	6.9	7.1	6	6.7	6.9	5.6	5.2	--	--
Fluoride	mg/L	<0.23	<0.23	--	<0.23	<0.28	<0.28	<0.22	<0.22	--	--
Field pH	Std. Units	7.27	7.22	7.41	7.33	7.25	7.15	7.34	7.28	7.38	7.34
Sulfate	mg/L	53	47	49	47	45	50	52	44	--	--
Total Dissolved Solids	mg/L	520	350	--	350	330	280	300	310	--	--
Antimony	ug/L	<0.58	<0.51	--	--	<1.1	<1.1	<0.69	<0.69	--	--
Arsenic	ug/L	<0.88	<0.88	--	<0.88	<0.75	<0.75	<0.75	<0.75	<0.53	<0.53
Barium	ug/L	51	47	--	46	51	48	49	50	--	--
Beryllium	ug/L	<0.27	<0.27	--	--	<0.27	<0.27	<0.27	<0.27	--	--
Cadmium	ug/L	<0.039	<0.049	--	<0.049	<0.051	<0.051	<0.055	<0.055	--	--
Chromium	ug/L	<1.1	<1.1	--	1.2	<1.1	<1.1	<1.1	<1.1	--	--
Cobalt	ug/L	0.41	0.098	--	<0.091	<0.091	<0.19	0.45	<0.19	--	--
Lead	ug/L	0.48	0.14	--	<0.11	<0.21	0.22	<0.24	<0.24	--	--
Lithium	ug/L	<2.3	<2.5	--	<2.5	<2.5	<2.5	<2.5	<2.5	--	--
Mercury	ug/L	<0.1	<0.1	--	--	<0.15	<0.15	<0.11	--	--	--
Molybdenum	ug/L	<1.1	<1.1	<1.1	<1.1	<1.3	<1.3	<1.2	<1.2	<0.91	--
Selenium	ug/L	1.3	1.1	--	<1	1.2	1	1.3	<0.96	--	--
Thallium	ug/L	<0.26	<0.26	--	--	<0.26	<0.26	<0.26	<0.26	--	--
Total Radium	pCi/L	--	0.0963	--	0.732	0.714	1.01	0.402	0.371	--	--
Radium-226	pCi/L	--	0.0963	--	0.229	0.076	0.233	0.196	0.0611	--	--
Radium-228	pCi/L	--	-0.00723	--	0.503	0.638	0.778	0.206	0.31	--	--
pH at 25 Degrees C	Std. Units	7.4	7.6	--	7.4	7.4	7.6	7.4	7.5	--	--
Field Oxidation Potential	mV	126.9	47	74.1	125.4	104.7	159.1	199.7	105.7	98.5	36.1
Field Specific Conductance	umhos/cm	644	641	638	650.1	597	627	630	619.9	458.5	616.4
Field Temperature	deg C	11.7	11.7	11.8	11.4	11.1	12	10.2	11.6	11.2	11.4
Groundwater Elevation	feet	623.19	624.2	623.52	623.03	623.12	623.1	623.71	622.97	621.32	622.91
Oxygen, Dissolved	mg/L	6.55	6.6	6.23	6.46	7.88	7.27	6.49	6.27	3.72	5.16
Turbidity	NTU	11.9	4.68	0.19	0.58	0.86	0	0	1.39	0	0
Total Alkalinity as CaCO ₃	mg/L	--	--	290	300	300	300	330	290	--	--
Iron, dissolved	ug/L	--	--	330	56	440	38	<36	55	37	--
Manganese, dissolved	ug/L	--	--	38	10	59	<4.4	8.3	5.4	--	--
Calcium, total	ug/L	--	--	--	81000	--	--	--	--	--	--
Iron, total	ug/L	--	--	--	<50	47	41	<36	<36	--	<36
Magnesium, total	ug/L	--	--	--	38000	37000	35000	37000	32000	--	--
Manganese, total	ug/L	--	--	--	<4	4.5	<4.4	<3.6	<3.6	--	--
Potassium, total	ug/L	--	--	--	1000	1000	1000	1100	900	--	--
Sodium, total	ug/L	--	--	--	6700	7000	6300	7400	6800	--	--
Bicarbonate Alkalinity as CaCO ₃	mg/L	--	--	290	300	300	300	330	290	--	--
Carbonate Alkalinity as CaCO ₃	mg/L	--	--	<3.8	<3.8	<4.2	<4.6	<4.6	<4.6	--	--
Arsenic, dissolved	ug/L	--	--	<0.88	--	--	<0.75	--	--	--	--
Molybdenum, dissolved	ug/L	--	--	<1.1	--	--	--	--	--	--	--

Single Location

Name: IPL - Lansing

Location ID: MW-303		Number of Sampling Dates: 22																					
Parameter Name	Units	12/10/2015	4/29/2016	7/20/2016	10/26/2016	1/17/2017	4/19/2017	6/20/2017	8/15/2017	10/16/2017	4/16/2018	6/4/2018	8/7/2018	10/8/2018	4/15/2019	10/2/2019	5/19/2020	8/18/2020	10/19/2020	4/8/2021	10/26/2021	4/5/2022	10/17/2022
Boron	ug/L	178	178	405	235	133	177	390	386	592	144	--	675	474	150	520	150	--	370	120	170	110	590
Calcium	mg/L	38.2	48.6	64.5	67.1	72.5	60.1	62.2	42	84.7	54.6	--	46	35.3	49	46	54	--	34	47	49	48	42
Chloride	mg/L	18.7	16.8	18.1	17.7	21.9	16.1	17.3	18.4	17.2	24.1	--	14.6	16.3	18	16	15	16	15	21	25	23	17
Fluoride	mg/L	0.43	0.32	0.37	0.31	0.22	0.24	0.36	0.48	0.25	0.32	--	0.47	0.72	1	0.42	0.38	--	<0.23	0.52	<0.28	0.33	<0.22
Field pH	Std. Units	8.03	8.07	7.12	7.93	8.16	8.19	7.93	7.78	7.2	8	7.59	7.66	7.91	7.95	7.83	7.67	7.65	7.77	8	7.45	8.07	7.66
Sulfate	mg/L	30.8	35.8	56	62.2	67.9	43.7	71.9	43.4	69.9	43.5	--	52.5	29.1	35	39	42	33	20	25	28	54	58
Total Dissolved Solids	mg/L	240	200	317	340	350	317	346	219	379	--	256	262	181	280	210	450	--	180	210	150	180	200
Antimony	ug/L	0.22	0.27	0.55	0.25	0.19	0.26	0.34	0.26	--	0.16	--	0.34	0.19	<0.53	--	<0.58	--	--	<1.1	<1.1	<0.69	<0.69
Arsenic	ug/L	<4.5	1.4	1.4	1.8	1.8	2.4	2.5	2.5	--	1.2	--	2.3	2.3	1.4	2.5	1.4	--	3.2	1.5	2.2	1.3	1.9
Barium	ug/L	102	122	178	169	174	159	214	147	--	173	--	194	121	160	220	210	--	190	170	240	200	230
Beryllium	ug/L	<0.17	<0.08	<0.08	<0.08	<0.08	<0.012	<0.012	<0.012	--	0.046	--	<0.12	<0.089	<0.27	--	<0.27	--	--	<0.27	<0.27	<0.27	<0.27
Cadmium	ug/L	<0.56	<0.029	<0.029	<0.029	0.042	0.018	<0.018	<0.018	--	<0.018	--	--	<0.033	<0.077	--	<0.039	--	<0.049	<0.051	<0.051	<0.055	<0.055
Chromium	ug/L	<0.96	0.52	<0.34	<0.34	0.81	0.71	0.36	0.36	--	0.51	--	0.44	0.089	<0.98	<0.98	<1.1	--	<1.1	<1.1	<1.1	<1.1	<1.1
Cobalt	ug/L	0.14	<0.5	<0.5	<0.5	<0.5	0.09	0.22	0.14	--	0.14	--	0.36	0.21	<0.091	0.12	<0.091	--	0.098	<0.091	<0.19	<0.19	<0.19
Lead	ug/L	<1.9	<0.19	0.2	<0.19	0.24	0.078	0.085	<0.033	--	<0.033	--	0.24	<0.13	<0.27	<0.27	<0.27	--	<0.11	<0.21	<0.21	<0.24	<0.24
Lithium	ug/L	5.1	6.2	13.9	10.4	5.9	4.7	10.4	16.1	--	<4.6	--	--	8.1	3.3	9.1	4.2	--	9.5	3.5	11	5.4	10
Mercury	ug/L	<0.012	<0.039	<0.039	<0.039	<0.039	<0.046	<0.046	<0.046	--	<0.09	--	<0.09	<0.09	<0.1	--	<0.1	--	--	<0.15	<0.15	<0.11	--
Molybdenum	ug/L	<1.5	5	16.8	16.1	10.7	7.6	15.9	11.8	--	7.3	--	21.6	12	6.2	9.8	3.1	23	10	4.8	7.1	9.2	22
Selenium	ug/L	<5.8	1.2	0.9	0.6	1.9	0.63	0.67	0.59	--	3.3	--	0.38	0.39	<1	--	1.4	--	<1	1.1	<0.96	<0.96	<0.96
Thallium	ug/L	0.14	<0.5	<0.5	<0.5	<0.5	<0.036	<0.036	0.17	--	<0.036	--	--	<0.099	<0.27	--	<0.26	--	--	<0.26	<0.26	<0.26	<0.26
Total Radium	pCi/L	0.926	0.73	0.768	1.24	0.416	0.339	0.639	0.477	--	0.787	--	0.929	1.87	--	0.463	--	--	0.27	0.243	0.359	0.533	0.512
Radium-226	pCi/L	-0.132	0.18	0.372	0.653	-0.077	0.339	0.217	0.155	--	0.359	--	0.929	0.664	--	0.444	--	--	0.217	0.125	0.278	0.296	0.2
Radium-228	pCi/L	0.926	0.555	0.396	0.582	0.416	-0.167	0.422	0.322	--	0.428	--	-0.073	1.21	--	0.0185	--	--	0.0528	0.118	0.0804	0.236	0.312
pH at 25 Degrees C	Std. Units	8	8	7.6	7.8	7.7	8.1	7.7	7.9	7.4	8	--	8	7.9	8	8	7.9	--	7.9	8	7.7	8.1	7.4
Field Oxidation Potential	mV	84.2	133.2	-27.2	10	221	81	9	-75	49	53	68	-71	139	-76	156	28.9	25.8	38.4	78.4	125.8	202.1	25.5
Field Specific Conductance	umhos/cm	375.2	409	535	776	614	520	567	423	687	552	431	425	328	448	409	464	468	340.3	425	452	452.4	397.1
Field Temperature	deg C	8.5	6.7	30.4	22.1	6.3	10.5	24.8	31.7	25.2	4.1	17	31.5	28.5	4.2	25.2	6.3	30.4	23.5	3.7	24.8	4.6	23.1
Groundwater Elevation	feet	638.79	638.07	639.33	638.65	638.1	639.2	638.77	637.86	638.79	638.62	638.81	637.85	637.32	638.22	638.03	637.98	638.22	636.96	638.07	638.68	641.69	639.39
Oxygen, Dissolved	mg/L	2.38	2.63	0.15	8.1	3	1.4	0	0	1.9	3.5	0.36	0.4	0.4	1.4	0.27	1.29	0.15	0.58	2.03	0.17	1.17	0.11
Turbidity	NTU	--	2.13	0.39	3.02	2.53	0	0	0	0	0.4	1.08	4.51	2.62	6.6	0.58	0	1.62	0	0	0.65	0	2.07
Total Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	190	120	170	220	120
Iron, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<50	<50	320	69	<36	46
Manganese, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	120	160	66	38	60	110
Calcium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	35000	--	--	--	--	--
Iron, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<0.05	<50	<36	38	<36	<36	
Magnesium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	13000	18000	16000	20000	13000	
Manganese, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	180	30	39	89	220	
Potassium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	2200	1500	2800	1900	3100	
Sodium, total	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	12000	13000	15000	16000	15000	
Bicarbonate Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	190	120	170	220	210	120
Carbonate Alkalinity as CaCO3	mg/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<3.8	<3.8	<3.8	<3.8	<4.6	<4.6	
Arsenic, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	2.1	--	--	2.2	--	--
Molybdenum, dissolved	ug/L	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	23	--	--	--	--	--

Single Location

Name: IPL - Lansing

MW-304												
Number of Sampling Dates: 11												
Parameter Name	Units	6/20/2019	10/2/2019	5/20/2020	8/19/2020	10/19/2020	4/9/2021	10/26/2021	4/5/2022	10/17/2022	4/10/2023	10/30/2023
Boron	ug/L	<110	<110	<73	--	<80	64	<58	71	78	--	--
Calcium	mg/L	82	72	70	--	66	69	71	70	79	--	--
Chloride	mg/L	5.9	7	6.2	7.7	6.2	6.5	6.9	5.3	8.6	--	--
Fluoride	mg/L	<0.23	<0.23	<0.23	--	<0.23	<0.28	<0.28	<0.22	<0.22	--	--
Field pH	Std. Units	7.01	7.16	7.32	7.55	7.16	7.27	7.29	7.25	7.17	7.27	7.17
Sulfate	mg/L	20	17	17	15	16	15	18	20	14	--	--
Total Dissolved Solids	mg/L	350	300	470	--	270	290	200	240	290	--	--
Antimony	ug/L	<0.53	--	<0.58	--	--	<1.1	<1.1	<0.69	<0.69	--	--
Arsenic	ug/L	<0.75	<0.75	<0.88	--	<0.88	<0.75	<0.75	<0.75	<0.75	<0.53	<0.53
Barium	ug/L	54	47	42	--	42	43	44	42	49	--	--
Beryllium	ug/L	<0.27	--	<0.27	--	--	<0.27	<0.27	<0.27	<0.27	--	--
Cadmium	ug/L	<0.077	--	<0.039	--	<0.049	<0.051	<0.051	<0.055	<0.055	--	--
Chromium	ug/L	1.6	1	8.2	--	<1.1	<1.1	<1.1	<1.1	<1.1	--	--
Cobalt	ug/L	1.1	0.19	0.22	--	<0.091	<0.091	0.22	<0.19	<0.19	--	--
Lead	ug/L	1.2	0.35	<0.27	--	<0.11	<0.21	0.23	<0.24	<0.24	--	--
Lithium	ug/L	<2.7	<2.7	<2.3	--	<2.5	<2.5	<2.5	<2.5	<2.5	--	--
Mercury	ug/L	<0.1	--	<0.1	--	--	<0.15	<0.15	<0.11	--	--	--
Molybdenum	ug/L	<1.1	<1.1	<1.1	1.2	<1.1	<1.3	<1.3	2.7	2.1	2.5	--
Selenium	ug/L	<1	--	<1	--	<1	<0.96	<0.96	<0.96	<0.96	--	--
Thallium	ug/L	<0.27	--	<0.26	--	--	<0.26	<0.26	<0.26	<0.26	--	--
Total Radium	pCi/L	0.356	0.9	--	--	0.139	0.497	0.87	0.143	0.0692	--	--
Radium-226	pCi/L	0.217	0.246	--	--	-0.0496	0.0825	0.331	0.143	0.0692	--	--
Radium-228	pCi/L	0.139	0.653	--	--	0.139	0.415	0.539	-0.0479	-0.288	--	--
pH at 25 Degrees C	Std. Units	7.4	7	7.3	--	7.3	7.4	7.4	7.5	7.4	--	--
Field Oxidation Potential	mV	41	107.3	104.9	109.6	155.6	160.3	171.3	201.4	169.2	195.5	-29.7
Field Specific Conductance	umhos/cm	593	578.4	574	583	601.9	520	562.3	571.8	643.3	481.6	575.6
Field Temperature	deg C	10.6	12.4	9	11.8	11.8	8.8	12.1	8.2	11.9	8.9	12
Groundwater Elevation	feet	0	623.79	621.57	621.75	621.4	621.46	621.29	621.72	621.21	622.31	621.21
Oxygen, Dissolved	mg/L	6.2	7.51	7.78	6.76	6.84	8.69	8.32	7.2	6.97	7.75	7.54
Turbidity	NTU	104	3.51	3.72	1.06	0.42	0	0	0	0.01	0	0
Total Alkalinity as CaCO3	mg/L	280	--	--	300	310	300	370	320	330	--	--
Iron, dissolved	ug/L	--	--	--	<50	<50	<36	67	<36	<36	50	--
Manganese, dissolved	ug/L	--	--	--	6.9	4.1	10	<4.4	<3.6	<3.6	--	--
Calcium, total	ug/L	--	--	--	--	75000	--	--	--	--	--	--
Iron, total	ug/L	--	--	--	51	<50	37	<36	<36	<36	--	290
Magnesium, total	ug/L	--	--	--	--	35000	33000	32000	33000	34000	--	--
Manganese, total	ug/L	--	--	--	--	6	5.9	<4.4	<3.6	<3.6	--	--
Potassium, total	ug/L	--	--	--	--	1300	1200	1300	1300	1400	--	--
Sodium, total	ug/L	--	--	--	--	6100	4900	4000	5900	6300	--	--
Bicarbonate Alkalinity as CaCO3	mg/L	--	--	--	300	310	300	370	320	330	--	--
Carbonate Alkalinity as CaCO3	mg/L	--	--	--	<3.8	<3.8	<4.2	<4.6	<4.6	<4.6	--	--
Arsenic, dissolved	ug/L	--	--	--	<0.88	--	--	<0.75	--	--	--	--
Molybdenum, dissolved	ug/L	--	--	--	--	1.6	--	--	--	--	--	--

Single Location

Name: IPL - Lansing

MW-304A													
Number of Sampling Dates: 12													
Parameter Name	Units	5/20/2020	7/6/2020	8/19/2020	10/19/2020	2/23/2021	4/9/2021	7/12/2021	10/26/2021	4/5/2022	10/17/2022	4/10/2023	10/30/2023
Boron	ug/L	1800	1700	--	1700	--	1400	--	1300	1500	1600	--	--
Calcium	mg/L	54	41	--	35	--	43	--	35	38	37	--	--
Chloride	mg/L	15	13	13	12	--	13	--	15	16	16	--	--
Fluoride	mg/L	0.57	0.42	--	<0.23	--	0.53	--	<0.28	0.32	<0.22	--	--
Field pH	Std. Units	8.04	7.9	8.48	7.89	8.01	7.78	8.09	7.94	7.97	7.81	7.74	7.93
Sulfate	mg/L	83	77	76	76	--	77	--	91	87	69	--	--
Total Dissolved Solids	mg/L	680	330	--	310	--	300	--	240	270	270	--	--
Antimony	ug/L	<0.58	<0.51	--	--	<1.1	--	<1.1	<0.69	<0.69	--	--	--
Arsenic	ug/L	1.3	<0.88	--	<0.88	--	0.78	--	<0.75	<0.75	<0.75	0.63	0.76
Barium	ug/L	67	34	--	28	--	36	--	26	30	29	--	--
Beryllium	ug/L	<0.27	<0.27	--	--	<0.27	--	<0.27	<0.27	<0.27	--	--	--
Cadmium	ug/L	0.19	0.098	--	0.073	--	0.096	--	<0.051	0.074	0.076	--	--
Chromium	ug/L	2.2	1.1	--	<1.1	--	1.6	--	<1.1	<1.1	<1.1	--	--
Cobalt	ug/L	3.2	0.83	--	0.43	--	0.88	--	<0.19	0.48	0.88	--	--
Lead	ug/L	4.3	1.2	--	0.48	--	1.1	--	0.37	0.81	1.1	--	--
Lithium	ug/L	2.7	<2.5	--	<2.5	--	<2.5	--	<2.5	<2.5	<2.5	--	--
Mercury	ug/L	<0.1	<0.1	--	--	<0.15	--	<0.15	<0.11	--	--	--	--
Molybdenum	ug/L	110	140	140	130	120	110	100	120	120	130	150	--
Selenium	ug/L	<1	<1	--	<1	--	<0.96	--	<0.96	<0.96	<0.96	--	--
Thallium	ug/L	<0.26	<0.26	--	--	<0.26	--	<0.26	<0.26	<0.26	--	--	--
Total Radium	pCi/L	--	0.573	--	0.157	--	0.468	--	0.698	0.51	0.296	--	--
Radium-226	pCi/L	--	0.221	--	0.117	--	0.0845	--	0.245	-0.00262	0.207	--	--
Radium-228	pCi/L	--	0.352	--	0.0402	--	0.384	--	0.454	0.51	0.0889	--	--
pH at 25 Degrees C	Std. Units	8	8	--	8	--	8	--	8.1	8	8	--	--
Field Oxidation Potential	mV	61.8	-15.8	50.5	162.7	44.9	151.6	80.3	157.1	198.1	-24.7	115.7	-120.7
Field Specific Conductance	umhos/cm	529	541	533	547.4	534	533	543.1	526.8	520.9	480.6	422.5	472.9
Field Temperature	deg C	12.6	19.1	14	10.1	9.1	10.1	13.8	13.4	9.4	10.6	10.6	10.9
Groundwater Elevation	feet	624.88	625.76	0	624.41	625.04	624.31	623.87	623.87	619	623.56	623.95	623.57
Oxygen, Dissolved	mg/L	0.48	0.3	0.27	0.78	0.39	0.41	0.48	2.53	0.19	0.13	0.21	0.18
Turbidity	NTU	585.9	181.9	236.2	90.29	116.6	165.2	36.09	2.78	42.65	77.88	28.82	23.95
Total Alkalinity as CaCO3	mg/L	--	--	190	190	--	180	--	210	210	180	--	--
Iron, dissolved	ug/L	--	--	<50	55	--	<36	--	<36	<36	<36	390	--
Manganese, dissolved	ug/L	--	--	16	7.3	--	6.2	--	<4.4	6.8	<3.6	--	--
Calcium, total	ug/L	--	--	--	35000	--	--	--	--	--	--	--	--
Iron, total	ug/L	--	--	--	270	--	580	--	<36	240	380	--	160
Magnesium, total	ug/L	--	--	--	16000	--	18000	--	15000	16000	14000	--	--
Manganese, total	ug/L	--	--	--	26	--	54	--	<4.4	25	31	--	--
Potassium, total	ug/L	--	--	--	680	--	710	--	650	740	540	--	--
Sodium, total	ug/L	--	--	--	63000	--	58000	--	55000	58000	49000	--	--
Bicarbonate Alkalinity as CaCO3	mg/L	--	--	190	190	--	180	--	210	210	180	--	--
Carbonate Alkalinity as CaCO3	mg/L	--	--	<7.6	<3.8	--	<4.6	--	<4.6	<4.6	<4.6	--	--
Arsenic, dissolved	ug/L	--	--	<0.88	--	--	--	--	<0.75	--	--	--	--
Molybdenum, dissolved	ug/L	--	--	--	160	140	140	120	--	120	130	140	--

Single Location

Name: IPL - Lansing

MW-305												
Number of Sampling Dates: 11												
Parameter Name	Units	6/20/2019	10/2/2019	5/19/2020	8/18/2020	10/20/2020	4/9/2021	10/27/2021	4/4/2022	10/18/2022	4/11/2023	10/31/2023
Boron	ug/L	180	190	210	--	220	140	200	110	240	--	--
Calcium	mg/L	92	97	82	--	76	79	79	78	80	--	--
Chloride	mg/L	6.8	3.2	7.5	6.9	6	4.8	6.6	3.5	5.5	--	--
Fluoride	mg/L	<0.23	<0.23	0.23	--	<0.23	<0.28	<0.28	<0.22	<0.22	--	--
Field pH	Std. Units	7.19	7.03	6.9	7.23	7.24	7.17	7.29	6.94	7.32	7.44	7.17
Sulfate	mg/L	24	26	<3.6	<3.6	<3.6	29	14	42	3.6	--	--
Total Dissolved Solids	mg/L	440	380	540	--	320	300	260	270	300	--	--
Antimony	ug/L	<0.53	--	<0.58	--	--	<1.1	<1.1	<0.69	<0.69	--	--
Arsenic	ug/L	2.2	3.4	3.6	--	5.6	1.7	3.9	0.89	4.7	0.93	1.8
Barium	ug/L	170	190	220	--	200	150	200	97	230	--	--
Beryllium	ug/L	<0.27	--	<0.27	--	--	<0.27	<0.27	<0.27	<0.27	--	--
Cadmium	ug/L	<0.077	--	<0.039	--	<0.049	<0.051	<0.051	<0.055	<0.055	--	--
Chromium	ug/L	<0.98	<0.98	<1.1	--	<1.1	<1.1	<1.1	<1.1	<1.1	--	--
Cobalt	ug/L	0.52	0.27	0.32	--	0.12	0.29	<0.19	<0.19	<0.19	--	--
Lead	ug/L	<0.27	<0.27	<0.27	--	<0.11	<0.21	0.29	<0.24	<0.24	--	--
Lithium	ug/L	3.4	4.6	<2.3	--	<2.5	<2.5	<2.5	2.6	<2.5	--	--
Mercury	ug/L	<0.1	--	<0.1	--	--	<0.15	<0.15	<0.11	--	--	--
Molybdenum	ug/L	1.7	1.6	<1.1	1.8	<1.1	<1.3	<1.3	<1.2	<1.2	1.1	--
Selenium	ug/L	<1	--	<1	--	<1	1.4	<0.96	1.7	<0.96	--	--
Thallium	ug/L	<0.27	--	<0.26	--	--	<0.26	<0.26	<0.26	<0.26	--	--
Total Radium	pCi/L	0.553	0.557	--	--	0.377	0.474	1.43	0.249	1.2	--	--
Radium-226	pCi/L	0.181	0.38	--	--	0.296	0.301	0.55	0.145	0.331	--	--
Radium-228	pCi/L	0.372	0.178	--	--	0.0809	0.173	0.879	0.104	0.871	--	--
pH at 25 Degrees C	Std. Units	7.2	7.2	7.2	--	7.2	7.3	7.3	7.4	7.4	--	--
Field Oxidation Potential	mV	27	-105.6	-138	-162.9	-145.4	-25.8	-128.5	198.9	-186.6	-92.1	-153.3
Field Specific Conductance	umhos/cm	638	635	684	654	634	574	643	545	607.2	396.9	745
Field Temperature	deg C	15.5	19	9.8	19	15.6	7.1	16.3	4.4	15.7	6.2	15.1
Groundwater Elevation	feet	0	629.77	627.24	626.98	626.54	627.02	626.41	627.17	626.36	624.54	628.89
Oxygen, Dissolved	mg/L	0.2	0.21	0.48	0.07	0.22	2.1	0.08	4.06	0.06	3.18	0.71
Turbidity	NTU	9.6	8.87	20.44	27.27	3.65	14.88	0.27	4.57	8.17	1.71	4.18
Total Alkalinity as CaCO3	mg/L	290	--	--	340	340	280	330	290	360	--	--
Iron, dissolved	ug/L	--	--	--	11000	10000	3700	6900	830	7400	3300	--
Manganese, dissolved	ug/L	--	--	--	2000	1800	1100	1400	520	1400	--	--
Calcium, total	ug/L	--	--	--	--	87000	--	--	--	--	--	--
Iron, total	ug/L	--	--	--	--	12000	5900	7300	1500	8500	--	6700
Magnesium, total	ug/L	--	--	--	--	32000	25000	30000	23000	30000	--	--
Manganese, total	ug/L	--	--	--	--	1800	1200	1500	560	1300	--	--
Potassium, total	ug/L	--	--	--	--	1800	1300	1600	1500	1500	--	--
Sodium, total	ug/L	--	--	--	--	7700	5900	6700	5500	7000	--	--
Bicarbonate Alkalinity as CaCO3	mg/L	--	--	--	340	340	280	330	290	360	--	--
Carbonate Alkalinity as CaCO3	mg/L	--	--	--	<7.6	<3.8	<4.6	<2.3	<4.6	<4.6	--	--
Arsenic, dissolved	ug/L	--	--	--	6.4	--	--	3.7	--	--	--	--
Molybdenum, dissolved	ug/L	--	--	--	2.8	--	--	--	--	--	--	--

Single Location

Name: IPL - Lansing

MW-306																
Number of Sampling Dates: 15																
Parameter Name	Units	6/20/2019	10/2/2019	12/5/2019	2/5/2020	5/19/2020	8/18/2020	10/20/2020	2/23/2021	4/9/2021	7/12/2021	10/27/2021	4/4/2022	10/19/2022	4/11/2023	10/30/2023
Boron	ug/L	860	660	--	--	720	--	720	--	650	--	580	550	600	--	--
Calcium	mg/L	240	260	--	--	340	--	260	--	290	--	210	200	280	--	--
Chloride	mg/L	24	40	--	--	32	28	27	--	33	--	34	41	32	--	--
Fluoride	mg/L	<0.23	<0.23	--	--	<0.23	--	<0.23	--	<0.28	--	<0.28	<0.22	<0.22	--	--
Field pH	Std. Units	6.87	9	6.76	6.95	6.66	7.12	6.88	6.87	6.85	7.51	6.86	6.86	6.8	7.13	7.05
Sulfate	mg/L	280	140	--	--	430	260	220	--	240	--	95	100	500	--	--
Total Dissolved Solids	mg/L	1200	1300	--	--	3400	--	1100	--	1300	--	960	1100	1500	--	--
Antimony	ug/L	<0.53	--	--	--	<0.58	--	--	--	<1.1	--	<1.1	<0.69	<0.69	--	--
Arsenic	ug/L	8.6	12	9.3	9.4	8.5	--	10	9	8	8.2	8.6	7.7	7.1	7	9.5
Barium	ug/L	280	540	--	--	260	--	250	--	280	--	320	350	390	--	--
Beryllium	ug/L	<0.27	--	--	--	<0.27	--	--	--	<0.27	--	<0.27	<0.27	<0.27	--	--
Cadmium	ug/L	<0.077	--	--	--	<0.039	--	<0.049	--	<0.051	--	<0.051	<0.055	<0.055	--	--
Chromium	ug/L	<0.98	<0.98	--	--	<1.1	--	<1.1	--	1.3	--	<1.1	<1.1	<1.1	--	--
Cobalt	ug/L	1	0.98	--	--	0.53	--	0.24	--	0.35	--	0.3	0.49	0.3	--	--
Lead	ug/L	0.52	<0.27	--	--	<0.27	--	<0.11	--	<0.21	--	1.1	<0.24	<0.24	--	--
Lithium	ug/L	19	25	--	--	25	--	26	--	24	--	22	23	27	--	--
Mercury	ug/L	<0.1	--	--	--	<0.1	--	--	--	<0.15	--	<0.15	<0.11	--	--	--
Molybdenum	ug/L	<1.1	<1.1	--	--	<1.1	<1.1	<1.1	--	<1.3	--	<1.3	<1.2	<1.2	<0.91	--
Selenium	ug/L	<1	--	--	--	<1	--	<1	--	<0.96	--	<0.96	<0.96	<0.96	--	--
Thallium	ug/L	<0.27	--	--	--	<0.26	--	--	--	<0.26	--	<0.26	<0.26	<0.26	--	--
Total Radium	pCi/L	0.897	1.79	--	--	--	--	1.16	--	1.09	--	2.1	0.757	0.693	--	--
Radium-226	pCi/L	0.432	0.902	--	--	--	--	0.459	--	0.436	--	0.814	0.464	0.431	--	--
Radium-228	pCi/L	0.465	0.889	--	--	--	--	0.696	--	0.659	--	1.29	0.292	0.262	--	--
pH at 25 Degrees C	Std. Units	6.9	7.2	--	--	6.9	--	6.8	--	7.2	--	7	7	7	--	--
Field Oxidation Potential	mV	22	-1205	-127	-127.7	-137	-139.1	-142.3	-127.2	-134.2	-128.3	-126.3	196.3	-173.1	-165.5	-158.8
Field Specific Conductance	umhos/cm	1632	1998	2196	2477	2332	1911	1832	2055	1994	2006	1778	1839	2120	1682	2071
Field Temperature	deg C	13.8	16.33	16.3	13.7	12.7	15	16.2	13.6	12.6	14.4	16.6	12	15.4	12	16.3
Groundwater Elevation	feet	0	622.47	620.6	620.83	620.43	620.37	619.92	619.76	620.03	619.83	619.91	620.42	619.79	622.07	620.41
Oxygen, Dissolved	mg/L	1	0.27	0.9	0.23	0.3	0.1	0.26	0.12	0.05	0.37	0.11	0.26	0.07	0.27	0.2
Turbidity	NTU	25.9	3.67	10.26	4.43	2.63	0.16	3.08	3.11	0.09	0.13	2.72	0	0.98	4.12	33.15
Total Alkalinity as CaCO ₃	mg/L	620	--	--	--	--	850	800	--	880	--	880	940	800	--	--
Iron, dissolved	ug/L	--	--	--	--	--	44000	39000	--	41000	--	33000	32000	41000	50000	--
Manganese, dissolved	ug/L	--	--	--	--	--	5100	4800	--	5300	--	4100	4500	7000	--	--
Calcium, total	ug/L	--	--	--	--	--	--	280000	--	--	--	--	--	--	--	--
Iron, total	ug/L	--	--	--	--	--	--	40000	--	44000	--	33000	33000	42000	--	53000
Magnesium, total	ug/L	--	--	--	--	--	--	46000	--	50000	--	36000	41000	46000	--	--
Manganese, total	ug/L	--	--	--	--	--	--	4800	--	5500	--	4100	4400	5500	--	--
Potassium, total	ug/L	--	--	--	--	--	--	7100	--	6100	--	6200	7000	8300	--	--
Sodium, total	ug/L	--	--	--	--	--	--	110000	--	98000	--	140000	160000	140000	--	--
Bicarbonate Alkalinity as CaCO ₃	mg/L	--	--	--	--	--	850	800	--	880	--	880	940	800	--	--
Carbonate Alkalinity as CaCO ₃	mg/L	--	--	--	--	--	<7.6	<3.8	--	<4.6	--	<4.6	<4.6	<12	--	--
Arsenic, dissolved	ug/L	--	--	--	--	--	9.4	--	8.8	7.8	--	8.4	7.8	7	--	--
Molybdenum, dissolved	ug/L	--	--	--	--	--	<1.1	--	--	--	--	--	--	--	--	--

Single Location

Name: IPL - Lansing

Location ID: MW-306A		Number of Sampling Dates: 10									
Parameter Name	Units	5/19/2020	7/6/2020	8/18/2020	10/20/2020	4/9/2021	10/27/2021	4/4/2022	10/19/2022	4/11/2023	10/30/2023
Boron	ug/L	290	340	--	280	280	240	260	290	--	--
Calcium	mg/L	83	82	--	76	78	80	78	77	--	--
Chloride	mg/L	7.8	7.1	7.4	7.2	7.2	7.7	6.3	5.8	--	--
Fluoride	mg/L	<0.23	<0.23	--	<0.23	<0.28	<0.28	<0.22	<0.22	--	--
Field pH	Std. Units	6.99	7.04	7.38	7.18	7.21	7.34	7.19	7.25	7.43	7.43
Sulfate	mg/L	44	40	41	41	39	42	43	34	--	--
Total Dissolved Solids	mg/L	610	360	--	350	350	280	330	350	--	--
Antimony	ug/L	<0.58	<0.51	--	--	<1.1	<1.1	<0.69	<0.69	--	--
Arsenic	ug/L	<0.88	<0.88	--	<0.88	<0.75	<0.75	<0.75	<0.75	<0.53	<0.53
Barium	ug/L	61	58	--	58	62	59	61	62	--	--
Beryllium	ug/L	<0.27	<0.27	--	--	<0.27	<0.27	<0.27	<0.27	--	--
Cadmium	ug/L	<0.039	<0.049	--	<0.049	<0.051	<0.051	<0.055	<0.055	--	--
Chromium	ug/L	<1.1	<1.1	--	<1.1	<1.1	<1.1	<1.1	<1.1	--	--
Cobalt	ug/L	0.33	0.18	--	0.22	0.17	0.21	0.19	<0.19	--	--
Lead	ug/L	<0.27	<0.11	--	<0.11	<0.21	0.32	<0.24	<0.24	--	--
Lithium	ug/L	<2.3	<2.5	--	<2.5	<2.5	<2.5	<2.5	<2.5	--	--
Mercury	ug/L	<0.1	<0.1	--	--	<0.15	<0.15	<0.11	--	--	--
Molybdenum	ug/L	<1.1	<1.1	<1.1	<1.1	<1.3	<1.3	<1.2	<1.2	<0.91	--
Selenium	ug/L	<1	<1	--	<1	<0.96	0.99	<0.96	<0.96	--	--
Thallium	ug/L	<0.26	<0.26	--	--	<0.26	<0.26	<0.26	<0.26	--	--
Total Radium	pCi/L	--	0.525	--	0.124	0.408	0.682	0.198	1.18	--	--
Radium-226	pCi/L	--	0.0377	--	-0.201	0.12	0.279	0.00526	0.193	--	--
Radium-228	pCi/L	--	0.487	--	0.124	0.288	0.403	0.192	0.99	--	--
pH at 25 Degrees C	Std. Units	7.4	7.5	--	7.4	7.4	7.4	7.4	7.5	--	--
Field Oxidation Potential	mV	-21.7	-55.8	21.2	-38.5	-8.5	78.8	192.7	-91.1	-93.3	-84.3
Field Specific Conductance	umhos/cm	697	683	654	681	669	663	669	624.3	486.3	650
Field Temperature	deg C	14.6	15.3	15.5	14.4	14.2	14.6	13	14	13.7	14.2
Groundwater Elevation	feet	620.4	621.66	620.63	620.17	620.14	620.17	620.61	620.05	622.68	621.02
Oxygen, Dissolved	mg/L	1.18	1.24	1.16	1.3	1.68	1.23	1.13	1.3	0.67	1.25
Turbidity	NTU	4.15	1.4	2.71	1.56	0.01	0.59	0	3.21	0.83	0
Total Alkalinity as CaCO ₃	mg/L	--	--	330	320	320	330	350	350	--	--
Iron, dissolved	ug/L	--	--	1900	1600	1600	1500	1500	1400	1400	--
Manganese, dissolved	ug/L	--	--	1200	1100	1100	1000	1000	1000	--	--
Calcium, total	ug/L	--	--	--	85000	--	--	--	--	--	--
Iron, total	ug/L	--	--	--	1900	1800	1800	1700	1500	--	1700
Magnesium, total	ug/L	--	--	--	37000	35000	33000	36000	32000	--	--
Manganese, total	ug/L	--	--	--	1100	1100	1000	1000	940	--	--
Potassium, total	ug/L	--	--	--	1200	1200	1200	1300	1000	--	--
Sodium, total	ug/L	--	--	--	11000	10000	9800	10000	9100	--	--
Bicarbonate Alkalinity as CaCO ₃	mg/L	--	--	330	320	320	330	350	350	--	--
Carbonate Alkalinity as CaCO ₃	mg/L	--	--	<7.6	<1.9	<4.6	<4.6	<4.6	<4.6	--	--
Arsenic, dissolved	ug/L	--	--	<0.88	--	--	<0.75	--	--	--	--
Molybdenum, dissolved	ug/L	--	--	<1.1	--	--	--	--	--	--	--

Single Location

Name: IPL - Lansing

MW-307								
Number of Sampling Dates: 7								
Parameter Name	Units	7/12/2021	8/13/2021	10/27/2021	4/5/2022	10/18/2022	4/10/2023	10/30/2023
Boron	ug/L	220	250	280	400	1100	1200	920
Calcium	mg/L	55	47	38	50	39	38	56
Chloride	mg/L	15	16	17	22	18	23	20
Fluoride	mg/L	<0.28	<0.28	<0.28	<0.22	<0.22	<0.38	<0.38
Field pH	Std. Units	8.25	7.86	8.11	8.34	8.44	8.36	8.32
Sulfate	mg/L	44	42	70	76	120	45	36
Total Dissolved Solids	mg/L	210	230	130	210	900	160	250
Antimony	ug/L	<1.1	<1.1	<1.1	<0.69	<0.69	<1	<1
Arsenic	ug/L	2.1	2.4	2.5	1.8	2.7	2.5	2.3
Barium	ug/L	310	300	240	290	280	230	340
Beryllium	ug/L	<0.27	<0.27	<0.27	<0.27	<0.27	<0.33	<0.33
Cadmium	ug/L	<0.051	<0.051	<0.051	<0.055	<0.055	<0.1	<0.1
Chromium	ug/L	<1.1	<1.1	<1.1	<1.1	<1.1	<1.1	<1.1
Cobalt	ug/L	0.15	0.15	<0.19	<0.19	0.19	<0.17	<0.17
Lead	ug/L	<0.21	<0.21	<0.21	<0.24	<0.24	<0.24	<0.24
Lithium	ug/L	13	13	12	10	13	11	16
Mercury	ug/L	<0.15	<0.15	<0.15	<0.11	--	<0.14	<0.14
Molybdenum	ug/L	5.5	7.2	12	16	25	7.8	5.5
Selenium	ug/L	<0.96	<0.96	<0.96	<0.96	<0.96	<1.4	<1.4
Thallium	ug/L	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26	<0.26
Total Radium	pCi/L	0.499	1.91	0.743	0.183	1.51	0.165	1.95
Radium-226	pCi/L	0.171	0.289	0.421	0.0893	0.166	0.165	0.203
Radium-228	pCi/L	0.328	1.62	0.322	0.0932	1.34	-0.128	1.74
pH at 25 Degrees C	Std. Units	8.2	8.1	8.2	8.2	8.1	8.6	8.2
Field Oxidation Potential	mV	-40.6	-17.5	-123.4	198.2	-175.6	-150.4	-102.1
Field Specific Conductance	umhos/cm	449.6	437	361.2	460	399.6	312.4	489.7
Field Temperature	deg C	15.2	17.4	16.4	6.9	15.7	8	13.5
Groundwater Elevation	feet	630.95	630.01	634.9	639.74	639.23	629.13	628.65
Oxygen, Dissolved	mg/L	0.47	0.17	0.93	0.08	0.16	0.28	0.19
Turbidity	NTU	0	0	0	0	4.34	0	0
Total Alkalinity as CaCO ₃	mg/L	170	--	86	130	100	--	--
Iron, dissolved	ug/L	110	--	110	87	90	68	--
Manganese, dissolved	ug/L	300	--	240	560	450	--	--
Iron, total	ug/L	140	--	95	78	110	--	56
Magnesium, total	ug/L	17000	--	12000	17000	11000	--	--
Manganese, total	ug/L	310	--	230	590	430	--	--
Potassium, total	ug/L	3600	--	2600	2400	2900	--	--
Sodium, total	ug/L	13000	--	11000	16000	24000	--	--
Bicarbonate Alkalinity as CaCO ₃	mg/L	170	--	86	130	100	--	--
Carbonate Alkalinity as CaCO ₃	mg/L	<4.1	--	<2.3	<4.6	<4.6	--	--
Arsenic, dissolved	ug/L	2	--	2.6	--	--	--	--
Molybdenum, dissolved	ug/L	5.2	--	--	--	--	--	--

Single Location

Name: IPL - Lansing


Parameter Name	Units	7/12/2021	8/13/2021	10/27/2021	4/5/2022	10/18/2022	4/10/2023	10/30/2023
Boron	ug/L	370	380	300	430	680	--	--
Calcium	mg/L	67	62	70	58	52	--	--
Chloride	mg/L	6.8	7.2	8.1	13	11	--	--
Fluoride	mg/L	<0.28	<0.28	<0.28	<0.22	<0.22	--	--
Field pH	Std. Units	7.83	7.35	7.29	7.48	7.59	7.33	7.71
Sulfate	mg/L	30	32	33	28	27	--	--
Total Dissolved Solids	mg/L	280	290	230	250	270	--	--
Antimony	ug/L	<1.1	<1.1	<1.1	<0.69	<0.69	--	--
Arsenic	ug/L	<0.75	0.76	1.3	2.1	1.9	0.65	1
Barium	ug/L	120	120	130	110	100	--	--
Beryllium	ug/L	<0.27	<0.27	<0.27	<0.27	<0.27	--	--
Cadmium	ug/L	<0.051	<0.051	<0.051	<0.055	<0.055	--	--
Chromium	ug/L	<1.1	<1.1	<1.1	<1.1	<1.1	--	--
Cobalt	ug/L	0.54	0.57	0.77	0.68	0.65	--	--
Lead	ug/L	<0.21	<0.21	0.21	<0.24	<0.24	--	--
Lithium	ug/L	<2.5	<2.5	<2.5	<2.5	<2.5	--	--
Mercury	ug/L	<0.15	<0.15	<0.15	<0.11	--	--	--
Molybdenum	ug/L	6.8	6.6	6.3	5.7	6.6	7.6	--
Selenium	ug/L	<0.96	<0.96	<0.96	<0.96	<0.96	--	--
Thallium	ug/L	<0.26	<0.26	<0.26	<0.26	<0.26	--	--
Total Radium	pCi/L	0.509	0.258	0.957	0.0954	0.683	--	--
Radium-226	pCi/L	0.265	0.163	0.412	0.0954	0.0963	--	--
Radium-228	pCi/L	0.245	0.0954	0.545	-0.076	0.587	--	--
pH at 25 Degrees C	Std. Units	7.5	7.6	7.6	8.1	7.7	--	--
Field Oxidation Potential	mV	73.1	54.3	47.7	199.8	-99.4	-13.8	-52.4
Field Specific Conductance	umhos/cm	615.6	612.3	625.4	563	518.7	521.2	609.6
Field Temperature	deg C	13.2	12.5	12.9	10.8	11.4	11.6	11.9
Groundwater Elevation	feet	625.27	625.48	626.25	626.72	625.77	617.75	625.01
Oxygen, Dissolved	mg/L	0.27	0.17	1.39	0.09	0.1	0.15	0.49
Turbidity	NTU	0	0	0	0	2.57	0	0
Total Alkalinity as CaCO ₃	mg/L	310	--	310	330	270	--	--
Iron, dissolved	ug/L	<36	--	170	280	300	36	--
Manganese, dissolved	ug/L	600	--	720	700	640	--	--
Iron, total	ug/L	<36	--	160	370	330	--	200
Magnesium, total	ug/L	33000	--	33000	27000	24000	--	--
Manganese, total	ug/L	620	--	720	710	610	--	--
Potassium, total	ug/L	3000	--	2500	2100	2000	--	--
Sodium, total	ug/L	16000	--	14000	22000	28000	--	--
Bicarbonate Alkalinity as CaCO ₃	mg/L	310	--	310	330	270	--	--
Carbonate Alkalinity as CaCO ₃	mg/L	<4.2	--	<4.6	<4.6	<4.6	--	--
Arsenic, dissolved	ug/L	<0.75	--	1.4	--	--	--	--
Molybdenum, dissolved	ug/L	7.3	--	--	--	--	--	--

Appendix B

Lansing Landfill and Ash Pond Closure Drawings

ASH POND CLOSURE CONSTRUCTION DOCUMENTATION

LANSING GENERATING STATION LANSING, IOWA





PROFESSIONAL ENGINEER	MARK HUBER 15325	BSS/KP BSS/MRH	11/10/2023
Mark R. Huber IOWA			
PROJECT NO.	25222150.00	DRAWN BY:	
DRAWN:	10/26/2023	CHECKED BY:	
REVISED:	10/26/2023	APPROVED BY:	
INTERSTATE POWER AND LIGHT CO. 2320 POWER PLANT DRIVE LANSING, IA 52215-6751			
CLIENT			
SCS ENGINEERS	INTERSTATE POWER AND LIGHT CO. 2320 POWER PLANT DRIVE LANSING, IA 52215-6751		
ENGINEER	2830 DARY DRIVE MADISON, WI 53718-6751 PHONE: (608) 224-2830		
SITE	ASH POND CLOSURE CONSTRUCTION DOCUMENTATION LANSING GENERATING STATION LANSING, IOWA		
TITLE SHEET			
SHEET NUMBER	SHEET TITLE		

PREPARED FOR: INTERSTATE POWER AND LIGHT CO.
2320 POWER PLANT DRIVE
LANSING, IOWA


PREPARED BY: SCS ENGINEERS
MADISON, WISCONSIN

DATE: NOVEMBER 2023



INDEX

SHEET NUMBER	SHEET TITLE
1	TITLE SHEET
2	OVERALL SITE PLAN
3	PRE-CONSTRUCTION CONDITIONS
4	SITE PREPARATION AND DEMOLITION PLAN
5	IN-SITU STABILIZATION WALL OVERVIEW
6	IN-SITU STABILIZATION WALL AUGER LAYOUT
7	GEOTEXTILE TUBE SCOUR PROTECTION LAYER
8	NORTH POND CLOSURE AREA EXCAVATION GRADES
9	SOUTH POND CLOSURE AREA TOP OF CCR-COAL IMPACTED MATERIAL
10	SOUTH POND CLOSURE AREA TOP OF LOW PERMEABILITY LAYER
11	SOUTH POND CLOSURE AREA FINAL GRADES
12	CLOSURE AREA RESTORATION
13	COAL YARD EXCAVATION GRADES
14	COAL YARD FINAL GRADES AND RESTORATION
15	CROSS SECTIONS A AND B
16	CROSS SECTIONS C AND D
17	CROSS SECTIONS E AND F
18	DETAILS
19	DETAILS



SCS ENGINEERS
2830 DARY DRIVE MADISON, WI 53718-6751
PHONE: (608) 234-2830

PROJECT NO. 25222150.0 DRAWN BY: BSS/KP
DRAWN: 10/05/2023 CHECKED BY: BSS/MRH
REVISED: 11/03/2023 APPROVED BY: MRS 11/09/2023


CLIENT
INTERSTATE POWER AND LIGHT CO.
2320 POWER PLANT DRIVE
LANSING, IA 50115-9735


ENGINEER


ASH POND CLOSURE
CONSTRUCTION DOCUMENTATION
LANSING GENERATING STATION
LANSING, IOWA


OVERALL SITE PLAN

SHEET
2 of 19









BSS/KP
BSS/MRH
MRS 11/09/2023



DRAWN BY:
CHECKED BY:
APPROVED BY:

PROJECT NO. 25222150-0 DRAWN: 10/05/2023
REVISED: 10/26/2023

CLIENT: INTERSTATE POWER AND LIGHT CO.
230 DARY DRIVE MADISON, WI 53718-6751
PHONE: (608) 234-2830

ENGINEER: SCS ENGINEERS

2830 DARY DRIVE MADISON, WI 53718-6751
PHONE: (608) 234-2830



ASH POND CLOSURE CONSTRUCTION DOCUMENTATION
LANSING GENERATING STATION
LANSING, IOWA

SITE


CONSTRUCTION DOCUMENTATION
LANSING GENERATING STATION
LANSING, IOWA


SCHEMATIC


IN-SITU STABILIZATION WALL
AUGER LAYOUT


SECTION


6 or 19

















LEGEND

- - - - - 1000 — - 2008 EXISTING GRADE (10' CONTOUR)
- - - - - 660 — - 2008 EXISTING GRADE (2' CONTOUR)
- - - - - 656 — - 2015/2020/2022 EXISTING GRADE (10' CONTOUR)
- - - - - 652 — - 2015/2020/2022 EXISTING GRADE (2' CONTOUR)
- - - - - 630 — - GRAVEL ROAD
- x — x — - FENCE
- ||||| — - RAILROAD TRACKS
- E — - BURIED ELECTRIC
- OH — - OVERHEAD UTILITY
- T — - TELEPHONE
- ST — - STORM DRAINAGE PIPE
- W — - WATER
- W — - ABANDONED WATER
- P — - PROCESS WATER PIPE
- ST — - UPPER ASH POND OUTFALL REROUTE PIPING
- Utility pole and guy wire — - UTILITY POLE AND GUY WIRE
- Light pole — - LIGHT POLE
- ▲ 16002 — - SURVEY CONTROL POINT
- MW17 — - MONITORING WELL
- MW17P — - ABANDONED MONITORING WELL
- MW12P — - PIEZOMETER
- MW12P — - ABANDONED PIEZOMETER
- PZ18 — - ABANDONED SHALLOW PIEZOMETER
- CYB1 — - SOIL BORING
- ✖ SED1 — - SEDIMENT PROBE
- ✖ TP1 — - TEST PIT
- Wetland — - WETLAND
- Oil water separator manhole — - OIL WATER SEPARATOR MANHOLE
- - - - - COAL YARD LEASED AREA
- - - - - EXCAVATION GRADE (10' CONTOUR)
- - - - - EXCAVATION GRADE (2' CONTOUR)
- - - - - SILT FENCE/FILTER SOCK
- - - - - LIMITS OF COAL YARD EXCAVATION

NOTES:

1. SEE SHEET 2 AND 3 FOR ADDITIONAL BASE MAP LEGEND ITEMS AND NOTES.
2. GRADES IN COAL YARD REPRESENT BOTTOM OF COAL IMPACTED MATERIAL REMOVAL BASED ON SURVEYS PERFORMED BY AMES DURING CONSTRUCTION.
3. STRUCTURES AND UTILITIES IN THE COAL YARD AND GENERATING STATION AREA ARE APPROXIMATE AND BASED ON 2007 LANSING POWER STATION - PLOT PLAN (EIO NO. 92-2686) AND NOVEMBER 5, 2014 COAL YARD FIRE PROTECTION SITE PLAN (DRAWING NO. 17692-LAN-M-001 AND 17692-LAN-M-002) PROVIDED BY IPL.
4. COAL YARD LEASE AREA LIMITS BY MOHN SURVEYING, INC. BASED ON LEASE INFORMATION PROVIDED BY IPL.
5. COAL AND COAL IMPACTED MATERIAL FROM THE COAL YARD AND COAL YARD RUNOFF POND DISPOSED UNDER THE FINAL COVER IN THE POND CLOSURE AREA OR ASH DISPOSAL LANDFILL.
6. COAL YARD CONVEYORS, STRUCTURES, AND EQUIPMENT DEMOLISHED/ABANDONED/REMOVED BY OTHERS. UTILITY AND STRUCTURE LOCATIONS ARE APPROXIMATE.

SCALE: 1" = 80'

SCS ENGINEERS
INTERSTATE POWER AND LIGHT CO.
2320 POWER PLANT DRIVE
LANSING, IA 50123-6751
PHONE: (608) 254-2830

ENGINEER

ASH POND CLOSURE
CONSTRUCTION DOCUMENTS
LANSING GENERATING STATION
LANSING, IOWA

SITE


COAL YARD EXCAVATION GRADES


SHEET
13 of 19

PROJECT NO. 2522150.0 DRAWN BY: BSS/KP
DRAWN: 10/05/2023 CHECKED BY: BSS/MRH
REVISED: 11/03/2023 APPROVED BY: MRS 11/09/2023

2830 DAIRY DRIVE MADISON, WI 53718-6751
PHONE: (608) 254-2830

05/29/2024 Classification: Internal - ECRM13301492







NOTES:


1. SEE SHEET 2 AND SHEET 3 FOR ADDITIONAL BASE MAP NOTES.
2. DOCUMENTED GRADES FOR THE SCOUR PROTECTION LAYER SURVEYED BY MOHN SURVEYING, INC.
3. EXCAVATION GRADES BASED ON GROUND AND DRONE SURVEYS COMPLETED BY AMES THROUGHOUT CONSTRUCTION.
4. TOP OF LOW PERMEABILITY SOIL GRADES BASED ON GROUND AND DRONE SURVEYS COMPLETED BY AMES THROUGHOUT CONSTRUCTION AND DESIGN GRADES.
5. FINAL GRADES BASED ON SEPTEMBER 25, 2023 DRONE SURVEY PERFORMED BY AMES.
6. THE ESTIMATED BOTTOM OF THE UPPER ASH POND IS BASED ON JUNE 5, 1974 SARGENT & LUNDY SITE DEVELOPMENT DRAWINGS AND MARCH 15, 1993 SARGENT & LUNDY DRAWINGS (ALLIANT DRAWING NO. 1-0110-4-D-CB002) SUPPLEMENTED WITH INFORMATION FROM GEOTECHNICAL BORINGS COMPLETED IN THE UPPER ASH POND AREA OVERSEEN BY SCS ENGINEERS.

100 0 100
SCALE: 1" = 100'
VERTICAL EXAGGERATION: 5X



CROSS SECTION LOCATION MAP
SCALE: 1" = 300'







NOTES:


- SEE SHEET 2 AND SHEET 3 FOR ADDITIONAL BASE MAP NOTES.
- DOCUMENTED GRADES FOR THE SCOUR PROTECTION LAYER SURVEYED BY MOHN SURVEYING, INC.
- EXCAVATION GRADES BASED ON GROUND AND DRONE SURVEYS COMPLETED BY AMES THROUGHOUT CONSTRUCTION.
- TOP OF LOW PERMEABILITY SOIL GRADES BASED ON GROUND AND DRONE SURVEYS COMPLETED BY AMES THROUGHOUT CONSTRUCTION AND DESIGN GRADES.
- FINAL GRADES BASED ON SEPTEMBER 25, 2023 DRONE SURVEY PERFORMED BY AMES.
- THE ESTIMATED BOTTOM OF THE UPPER ASH POND IS BASED ON JUNE 5, 1974 SARGENT & LUNDY SITE DEVELOPMENT DRAWINGS AND MARCH 15, 1993 SARGENT & LUNDY DRAWINGS (ALLIANT DRAWING NO. 1-0110-4-D-CB002) SUPPLEMENTED WITH INFORMATION FROM GEOTECHNICAL BORINGS COMPLETED IN THE UPPER ASH POND AREA OVERSEEN BY SCS ENGINEERS.

SCALE: 1" = 100'
VERTICAL EXAGGERATION: 5X



CROSS SECTION LOCATION MAP
SCALE: 1" = 300'



	CROSS SECTIONS C AND D	SITE	SCS ENGINEERS INTERSTATE POWER AND LIGHT CO. 2320 POWER PLANT DRIVE LANSING, IA 53718-6751 PHONE: (608) 224-2830	PROJECT NO. 2522150.00 DRAWN BY: BSS/KP CHECKED BY: BSS/MRH APPROVED BY: MRS 11/09/2023
		SHEET		



NOTES:


1. SEE SHEET 2 AND SHEET 3 FOR ADDITIONAL BASE MAP NOTES.
2. EXCAVATION GRADES REPRESENT BOTTOM OF COAL IMPACTED MATERIAL REMOVAL BASED ON SURVEYS PERFORMED BY AMES DURING CONSTRUCTION.
3. COAL YARD RESTORATION GRADES DOCUMENTED BY MOHN SURVEYING, INC. THROUGHOUT CONSTRUCTION.


SCALE: 1" = 100'
VERTICAL EXAGGERATION: 5X




CROSS SECTION LOCATION MAP

SCS ENGINEERS		ASH POND CLOSURE CONSTRUCTION DOCUMENTATION LANSING GENERATING STATION LANSING, IOWA		PROJECT NO. DRAWN: REvised:	25222159.00 10/05/2023 10/27/2023	DRAWN BY: CHECKED BY: APPROVED BY:	BSS/KP BSS/MRH MRS 11/09/2023
SHEET 17 of 19	CROSS SECTIONS E AND F	SITE	INTERSTATE POWER AND LIGHT CO. 2320 POWER PLANT DRIVE LANSING, IA 52151-9733	CLIENT			
		ENGINEER			2830 DAIRY DRIVE MADISON, WI 53718-6751 PHONE: (608) 224-2830		







1 **19** **DOWNSLOPE PIPE**
NOT TO SCALE



PLAN VIEW



SECTION A-A'




SECTION B-B'

SCS ENGINEERS
2830 DARY DRIVE MADISON, WI 53718-6751
PHONE: (608) 224-2830

INTERSTATE POWER AND LIGHT CO.
2320 POWER DRIVE MADISON, WI 53718-6751
CLIENT


ASH FOND CLOSURE CONSTRUCTION
DOCUMENTATION LAISING GENERATING
STATION LANSING, IOWA




NOTE:
1. MAINTAINED 18-INCHES OF LOW
PERMEABILITY SOIL UNDER ENERGY
DISSIPATOR AND DISCHARGE APRON.

Flume	D _i (in.)	Energy Dissipator Dimensions (feet)				Discharge Apron				
		W _b	h ₁	h ₃	h ₄	L	L ₁	L ₂	W ₁	W ₂
Flume 4/ Flume 5	30	8	6.17	1.33	3.33	10.67	4.58	6.17	0.58	2.17
Flume 1										
Flume 2	18	4	3.08	0.67	1.67	5.42	2.33	3.08	0.33	1.08
Flume 3										
		Chute	Apron Width (ft.)	Width (ft.)	Length (ft.)	Thickness (in.)	Stone Type			
		10	10	12	20		IDOT Revetment Stone Class E			
							IDOT Erosion Stone			


3 **19** **ENERGY DISSIPATOR**
NOT TO SCALE



PROFILE A-A'
SCALE: 1" = 10'



PROFILE B-B'
SCALE: 1" = 10'



PLAN VIEW
SCALE: 1" = 10'

4 **19** **COAL YARD OUTLET STRUCTURE**
NOT TO SCALE


2023 ASH DISPOSAL LANDFILL FINAL COVER CONSTRUCTION DOCUMENTATION

LANSING GENERATING STATION LANSING, IOWA


PREPARED FOR: INTERSTATE POWER AND LIGHT CO.
2320 POWER PLANT DRIVE
LANSING, IOWA

PREPARED BY: SCS ENGINEERS
MADISON, WISCONSIN

DATE: NOVEMBER 2023



SITE LOCATOR MAP
APPROXIMATE SCALE: 1" = 2,000'





SITE AERIAL
SCALE: 1" = 700'


INDEX


SHEET NUMBER	SHEET TITLE
1	TITLE SHEET
2	OVERALL SITE PLAN
3	PRE-CONSTRUCTION CONDITIONS
4	LANDFILL COVER SUBGRADES
5	LANDFILL COVER SUBGRADES - NORTHWEST
6	LANDFILL COVER SUBGRADES - SOUTHEAST
7	LANDFILL TOP OF SELECT CLAY FILL
8	LANDFILL TOP OF SELECT CLAY FILL - NORTHWEST
9	LANDFILL TOP OF SELECT CLAY FILL - SOUTHEAST
10	LANDFILL FINAL GRADES
11	LANDFILL FINAL GRADES - NORTHWEST
12	LANDFILL FINAL GRADES - SOUTHEAST
13	RESTORATION PLAN
14	CROSS SECTIONS
15	DETAILS
16	DETAILS
17	DETAILS


SCS ENGINEERS	INTERSTATE POWER AND LIGHT CO. 2320 POWER PLANT DRIVE LANSING, IA 52258-6751 PHONE: (608) 224-2830	PROJECT NO. 25222150.00 DRAWN: 10/05/2023 REVISED: 11/03/2023	DRAWN BY: BSS/KP CHECKED BY: BSS/MRH APPROVED BY: MRS 11/22/2023
2023 ASH DISPOSAL LANDFILL FINAL COVER CONSTRUCTION DOCUMENTATION LANSING GENERATING STATION LANSING, IOWA			














NOTES:

1. SEE SHEET 2 FOR ADDITIONAL BASE MAP LEGEND ITEMS AND NOTES.
2. GRADES WITHIN THE LIMITS OF THE 2023 FINAL COVER REPRESENT DESIGN FINAL COVER TOP OF SELECT CLAY FILL LAYER.
3. SEE TABLE 2 OF DOCUMENTATION REPORT FOR SUMMARY OF DOCUMENTED SURVEY INFORMATION.

A horizontal scale bar with markings at 0 and 80. The segment between 0 and 80 is divided into 8 equal segments by intermediate tick marks. The first segment is shaded black, and the second segment is also shaded black, indicating a scale factor of 1 inch equals 80 feet.


PROJECT NO.	25222159.00	DRAWN BY:	BSS/KP
DRAWN:	10/05/2023	CHECKED BY:	BSS/MRH
REVISED:	11/14/2023	APPROVED BY:	MRS 11/22/2023


S C S E N G I N E E R S		INTERSTATE POWER AND LIGHT CO. 2320 POWER PLANT DRIVE LANSING, IA 52151-9733	CLIENT	PROJECT NO. DRAWN: REVISED:	25222159.00 10/05/2023 11/14/2023	DRAWN BY: CHECKED BY: APPROVED BY:	BSS/KP BSS/MRH MRS 11/22/2023
-------------------------	--	--	--------	-----------------------------------	---	--	-------------------------------------


ENGINEER


COPY OF SELECT CLAY FILL


LANDFILL T





























SCS ENGINEERS		2023 ASH DISPOSAL LANDFILL FINAL COVER CONSTRUCTION DOCUMENTATION LANSING GENERATING STATION LANSING, IOWA		ENGINEER
SITE	CROSS SECTIONS	SHEET		
14 OF 17				
		PROJECT NO.	25222159.00	DRAWN BY: BSS/KP
		DRAWN:	10/05/2023	CHECKED BY: BSS/MRH
		REVISED:	11/03/2023	APPROVED BY: MRS 11/22/2023
INTERSTATE POWER AND LIGHT CO. 2320 POWER PLANT DRIVE LANSING, IA 52151-9733				
2830 DAIRY DRIVE MADISON, WI 53718-6751 PHONE: (608) 224-2830				







1-16 DOWNSLOPE PIPE INLET (TYP)
 NOT TO SCALE



1-16 DOWNSLOPE INLET STRUCTURE
 NOT TO SCALE




PLAN VIEW




3-16 ENERGY DISSIPATOR
 NOT TO SCALE

Flume	D ₁ (in.)	Energy Dissipator Dimensions (feet)				Discharge Apron					
		W _b	h ₁	h ₃	h ₄	L	L ₁	L ₂	W ₁	W ₂	t ₄
Flume 4/ Flume 5	30	8	6.17	1.33	3.33	10.67	4.58	6.17	0.58	2.17	0.5
		Chute Width (ft.)	Apron Width (ft.)	Length (ft.)	Thickness (in.)						Stone Type
		10	10	12	20						IDOT Revetment Stone Class E




NOTES:
 1. TOP OF REVESTMENT STONE/EROSION STONE FLUSH WITH SURROUNDING GRADES.

4-16 ROCK CHUTE
 NOT TO SCALE




5-16 TYPICAL ROCK CHECK DAM
 NOT TO SCALE

ROCK CHUTE	W (FT)	T (IN)	APRON, L (FT)	IDOT RIPRAP CLASSIFICATION
RC1	12	26	16	REVESTMENT STONE CLASS E




ENDWALL PLAN VIEW




RIPRAP APRON
IDOT RIPRAP CLASSIFICATION = EROSION STONE
THICKNESS = 9"
LENGTH = 15'
WIDTH = MATCH SWALE GEOMETRY

ENDWALL PLAN VIEW




ENDWALL ELEVATION




ENDWALL ELEVATION

CULVERT ENDWALL INLET
NOT TO SCALE


CULVERT ENDWALL OUTLET
NOT TO SCALE




3 REINFORCEMENT AT APRON ENDWALL
NOT TO SCALE




4 REINFORCEMENT AT ENDWALL OPENING
NOT TO SCALE



CULVERT BEDDING
NOT TO SCALE



SECTION A-A'



SECTION B-B'

CULVERT PROFILE
NOT TO SCALE

Appendix C

Estimated Groundwater Corrective Action Schedule

