



VIA EMAIL

October 30, 2020

Mr. Jeffrey Maxted
Alliant Energy – Environmental Services Manager
4902 North Biltmore Lane
Madison, WI 53718-2148

**Re: Unstable Areas Determination CCR Surface Impoundments - §257.64
Interstate Power and Light Company (IPL)
Lansing Generating Station
Lansing, Iowa**

Mr. Jeffrey Maxted,

This Unstable Areas Determination has been prepared in accordance with the requirements of the United States Environmental Protection Agency (USEPA) published Final Rule for Hazardous and Solid Waste Management System – Disposal of Coal Combustion Residual (CCR) from Electric Utilities (40 CFR Parts 257 and 261, also known as the CCR Rule) published on April 17, 2015 (effective October 19, 2015) and subsequent amendments. This letter assesses the factors of one CCR unit at Interstate Power and Light Company (IPL), Lansing Generating Station (LAN) in Lansing, Iowa in accordance with the CCR Rule §257.64 Unstable Areas. For purposes of this Report, “CCR unit” refers to an existing or inactive CCR surface impoundment.

Background Information

In accordance with the requirements set forth in §257.64 of the CCR Rule a CCR unit must not be located in an unstable area. The owner or operator must consider all the following factors:

- On-site or local soil conditions that may result in significant differential settling,
- On-site or local geologic or geomorphologic features; and,
- On-site or local human-made features or events (both surface and subsurface).

Facility Specific Information

LAN is located at 2320 Power Plant Drive, Lansing, Iowa. Figure 1 provides both a topographic map and an aerial of the LAN facility location, with the approximate property boundary of the facility identified. LAN has one existing CCR surface impoundment (Figure 2), which is the LAN Upper Ash Pond.

Differential Settling

The LAN Upper Ash Pond was constructed in 1974 in a valley directly south of the LAN generating station. The construction took place within the valley with the east and south side of the Upper Ash Pond being constructed against naturally occurring ground surface. The north and west sides of the impoundment were constructed of dredge spoil medium to fine sand from Mississippi River maintenance dredging.

To allow construction of the impoundment, the Unnamed Creek #1 was rerouted to run along the west side of the valley between the impoundment and a County Road on the east side slope of the valley, Figure 1. Soil investigations completed at the time of construction indicate the valley is underlain by a medium dense deposit of sand and gravel over the full valley floor with loose to very loose river silt laying on top of the sand and gravel at the north end of the planned Upper Ash Pond. Only organic topsoil was removed prior to constructing the two embankment sides of the LAN Upper Ash Pond and the river silt remains in the foundation at the northern end of the LAN Upper Ash Pond. The details of the LAN Upper Ash Pond construction are shown in drawings prepared by Sargent & Lundy in 1974, Exhibit A.

The LAN Upper Ash Pond was constructed on foundation soils that are medium dense sand and gravel in the southern part of the Pond and are suitable foundation soils. In the northern end of the pond the sand and gravels have an overlying river silt deposit that is loose to very loose and is saturated due to the Mississippi River. The original construction of the LAN Upper Ash Pond was completed over the top of the river silt which has no clay-like properties (Exhibit B) and supported the embankment without substantial settlement after construction.

In 2015, a subsurface soil investigation was undertaken to collect soil samples and determine the in-situ density of the north and west embankments and the underlying foundation soil. The soil borings were undertaken with hollow stem augers and sampling was completed with a standard split spoon (Figure 2). The density information along with soil test results for water content, grain size, and Atterberg limits (Exhibit B) indicate the current conditions of the embankments as they were constructed in 1974.

The test results indicate that the embankment is constructed of uniform, fine to medium sand (SP). The sand was compacted to medium dense to dense consistency as shown by the SPT results. Below the embankment, the two northern borings SB-1 and SB-7 (Figure 2) show that a very loose to loose silt is present under the embankment overlying a medium dense gravel. In borings SB-3 and SB-5 (Figure 2) the silt is thin and overlies the same gravel. The silt deposit in the two northern borings is from backwater deposition by the Mississippi River prior to the installation of the LAN Upper Ash Pond and the thin silt layer to the south is natural deposition from flooding of the Unnamed Stream #1.

The silt layer under the northern embankment of the LAN would have compressed under the load from installing the embankment in 1974. Annual inspections of the embankment and topographic surveys completed in 2015 show the northern embankment was built to its design elevation and has not settled since the embankment was installed. The loose silt is susceptible to liquefaction

settlement from an earthquake. However, the LAN site is not in an area of strong ground motion to induce liquefaction.

The Iowa Bedrock Survey Map (Exhibit C), available from the Iowa Geology and Water Survey, July 2013 indicates that bedrock is at an approximate elevation of 560 feet (depth of 90 feet below top of embankment) in the northern part of the LAN Upper Ash Pond and rises in elevation moving south up the valley of the Unnamed Stream #1.

Based on the known geotechnical information, LAN impoundments are not susceptible to significant differential settlement from liquefaction of the silt layer. Additionally, annual inspections of the embankments for the last 4 years have indicated no observable areas of differential settlement on the embankments.

Geologic and Geomorphologic Features

The Bedrock Geologic Map of Iowa (Exhibit C) shows that the site contains up to five types of bedrock formations: Prairie du Chien Group, St. Peter Sandstone, Jordan Sandstone, St. Lawrence, and Lone Rock Formations. The formations are comprised of dolomite and siltstone. The Iowa Bedrock Survey Map available from the Iowa Geology and Water Survey, July 2013 indicates that bedrock is at an approximate elevation of 560 feet (depth of 90 feet below top of embankment) in the northern part of the LAN Upper Ash Pond and rises in elevation moving south up the valley of the Unnamed Stream #1.

Karst formations in Iowa are predominately in the northeast part of the state, see Exhibit D, which is where LAN is located. An Iowa Department of Natural Resources map of known and potential karst terrain and/or paleosinks (sinkholes) near LAN has also been included in Exhibit D. This map shows that the LAN is located inside an area potentially susceptible to karst formations. A sinkhole has been identified approximately 2,000 feet east of the LAN Upper Ash Pond. The mapped location of the sinkhole is approximately 300 feet higher than the impoundment. As presented within the SCS Engineers Unstable Areas Compliance Demonstration¹ for the onsite landfill, The Galena Group, which consists of limestone and dolostone, has identified paleosinks within Allamakee County and is stratigraphically above the weathered sandstone unit observed in many borings installed throughout the LAN Upper Ash Pond and the landfill site. As a result, it is unlikely that karst conditions are present below the impoundment.

Several figures and tables have been included in Exhibit E which have been provided by SCS Engineers. These figures show that the local shallow groundwater direction descends from the bluffs as well as generally moving northward to the Mississippi River. The measurement of occasional downward gradient in the nested wells likely results from the silt layer discussed above acting as an aquitard separating the upper ground water in the valley from the deeper ground water of the Mississippi River elevation. Additionally, water recharging the valley groundwater from operations at LAN is at or above a pH of 7. As a result, there is no risk for the formation of paleosinks.

¹ Unstable Areas Demonstration Lansing Landfill, SCS Engineers, October 2018

Human-made Features or Events

Generally, man-made risks to the stability of CCR impoundments can include such events as: large dam failure, failure due to improper cut and fill during construction, excessive drawdown of groundwater, extreme fluctuations in flooding from human-made changes, or failure due to underground mining. Based on the information provided herein, the LAN Upper Ash Pond are is not susceptible to anthropogenic activities.

Unstable Areas Determination


After review of the reasonably and readily available documentation, we determine that the LAN Upper Ash Pond is not located in unstable area.

Qualified Professional Engineer Certification

The owner or operator of the CCR unit must obtain a certification from a qualified professional engineer attesting that the documentation as to whether a CCR unit meets the requirements 40 CFR 257.64(b).

To meet the requirements of 40 CFR 257.64(c), I Mark W. Loerop hereby certify that I am a licensed Professional Engineer in the State of Iowa; and that, to the best of my knowledge, all information contained in this document is correct and the document was prepared in compliance with all applicable requirements in 40 CFR 257.64.



By: 
Name: MARK LOEROP
Date: OCT 30, 2020

cc: Tony Morse, Alliant Energy
Robert Solak, Hard Hat Services

att: Figure 1 – Site Location
Figure 2 – Soil Boring Locations
Exhibit A – 1974 Drawings
Exhibit B – 2015 Investigation
Exhibit C – Iowa Bedrock Map
Exhibit D – Iowa Karst Maps
Exhibit E – Groundwater Info from SCS Engineers

MWL/tjh/MWL

Z:\Shared\Projects\154 - Alliant Energy\154.018 - CCR Projects\023 - 2020 LAN and BGS UCD\002 - LAN UAD\Unstable Area Determination\LAN Unstable Areas - DRAFT.doc


FIGURES

Alliant Energy
Interstate Power and Light Company
Lansing Generating Station
Lansing, Iowa


Unstable Area Determination
Figure 1 – Site Location
Figure 2 – Soil Boring Locations

Historical Topo Map

2013



This report includes information from the following map sheet(s).



TP, Lansing, 2013, 7.5-minute

SITE NAME: Lansing Generating Station
 ADDRESS: 2364-2366 Power Plant Dr
 Lansing, IA 52151
 CLIENT: Environmental Site Assessors



4555570 - 1 page 5



Historical Aerial Photo



----- Approximate Property Boundary

UPPER AND LOWER CCR POND TOPOGRAPHIC SURVEY AND LOWER CCR POND BATHYMETRY
 at
 ALLIANT LANSING POWER GENERATING STATION
 for
 INTERSTATE POWER & LIGHT COMPANY - ALLIANT ENERGY
 BEING IN PART OF SECTION 2, TOWNSHIP 98 NORTH, RANGE 3 WEST OF THE FIFTH PRINCIPAL MERIDIAN, ALLAMAKEE COUNTY, IOWA.

OWER GENERATING PLANT



- NOTES**
1. PROJECT HORIZONTAL POSITIONS ARE BASED ON THE IOWA STATE PLANE COORDINATE SYSTEM NORTH ZONE (1401) HORIZONTAL NAD83(2011).
 2. PROJECT VERTICAL POSITIONS ARE BASED ON NAVD_88 DATUM (GEOID 12A).
 3. CONTOUR INTERVAL = 1 FOOT.

- LEGEND**
- OHE OVERHEAD ELECTRIC LINE
 - T — UNDERGROUND TELEPHONE UTILITY
 - ⊙ EXISTING POWER POLE
 - SB ⊕ SOIL BORING LOCATION
 - ↔ ANALYSIS CROSS-SECTION

- NOTE:**
1. SURVEY INFORMATION PROVIDED ABOVE WAS COMPILED BY MOHN SURVEYING, INC. 1890 GREAT RIVER ROAD LANSING, IOWA 52151, APRIL 2015.
 2. ALLIANT ENERGY REQUIRES 20 FEET OVERHEAD SEPARATION DISTANCE FOR EQUIPMENT OPERATING UNDER POWERLINES.

NOTICE
 THIS DRAWING IS THE PROPERTY OF HARD HAT SERVICES AND IS NOT TO BE REPRODUCED, CHANGED, OR COPIED IN ANY FORM OR MANNER WITHOUT PRIOR WRITTEN PERMISSION. ALL RIGHTS RESERVED.

REV	DATE	BY	APP	DESCRIPTION

SCALE: AS SHOWN DATE: 5-19-16
 DRAWN BY: JFD CHECKED BY: CTS APPROVED BY: MWL

HARD HAT SERVICES[™]
 Engineering, Construction and Management Solutions

CLIENT / LOCATION
 INTERSTATE POWER AND LIGHT (IPL)
 LANSING GENERATING STATION PROJECT
 2320 POWER PLANT DR
 LANSING, IA 52151

DRAWING DESCRIPTION
 SOIL BORING AND
 SLOPE STABILITY CROSS-SECTION LOCATION

JOB 154.018.012.002
 SHT. FIGURE 2
 DWG. 154.018.012.002-D2



EXHIBIT A – 1974 Drawings

Alliant Energy
Interstate Power and Light Company
Lansing Generating Station
Lansing, Iowa

Unstable Area Determination

NOTES


1. A-1 THRU A-22 25' MAXIMUM OR TO ROCK.
2. B-1 AND B-2 CORE 10' INTO SOLID ROCK, B-3 THRU B-19 TO ROCK.
3. C-1 THRU C-6 25' MAXIMUM BELOW WATER LEVEL OR TO ROCK.
4. STANDARD PENETRATION TEST BLOW COUNTS AT 5' INTERVALS OR CHANGE IN STRATA SHALL BE PROVIDED FOR EACH SAMPLE OF GRANULAR SOIL ENCOUNTERED.
5. STANDARD PENETRATION TEST BLOW COUNTS, FIELD POCKET PENETROMETER TESTS, AND WATER CONTENT DETERMINATIONS AT 5' INTERVALS OR CHANGE IN STRATA, SHALL BE PROVIDED FOR EACH SAMPLE OF COHESIVE SOIL ENCOUNTERED.
6. THE TYPE, CONSISTENCY, RECOVERY RATIO, ROCK QUALITY DESIGNATION AND LABORATORY UNCONFINED COMPRESSION TESTS ON REPRESENTATIVE ROCK SAMPLES SHALL BE PROVIDED FOR EACH ROCK CORE.
7. OBTAIN REPRESENTATIVE SOIL SAMPLES FROM THE RIVER BOTTOM, BORINGS NO. C-1 THRU C-6 AND THE SOUTHERN HALF OF THE SITE. BORINGS NO. A-1, A-11, A-14, A-15 & A-18 PERFORM MODIFIED PROCTOR DENSITY TESTS AND GRAIN SIZE ANALYSIS ON REPRESENTATIVE SAMPLES.
8. FOR THE COMPLETE UNIT 4 BASE LINE & GRID SYSTEM SEE DWG S-11.
9. D-1 THRU D-14 TO ROCK.



SEE TOP OF DRAWING FOR NOTES

REFERENCE DRAWINGS	
S-3	SOIL BORING LOGS - SHEET 1
S-4	SOIL BORING LOGS - SHEET 2
S-5	SOIL BORING LOGS - SHEET 3
S-6	SOIL BORING LOGS - SHEET 4
S-10	SITE DEVELOPMENT - COFFERDAM AND DREDGING PLAN
S-11	SITE DEVELOPMENT - PLANT FILL


I hereby certify that this plan, specification or report was prepared by me or under my direct personal supervision and that I am a duly registered Professional Engineer under the laws of the State of Iowa.
 Date: 7-10-73
 T. N. Bergstrom, P.E. Iowa Reg. No. 4480



BORING LOCATION PLAN
 UNIT 4
 LANSING POWER STATION
 INTERSTATE POWER COMPANY
 LANSING, IOWA

Rev.	Date	Init.	Description
A	4-6-73	WLV	FOR SUBMITTAL
B	9-10-73	WLV	FOR FIELD USE
C	12-3-74	WLV	FOR FIELD USE
D	9-9-77	WLV	FOR FIELD USE

SCALE: 1" = 100'
 DRAWN: W.M. L. VOLK 4-3-73
 CHECKED: R.C. ORR 9-7-73
 ENGINEER: W.M. L. VOLK 9-10-73
 APPROVED: T.N. BERGSTROM 9-10-73
 JOB NO.: 4480-03



DRAWING NO.
 S-1

NOTE: FOR BORINGS NOT SHOWN ON THIS LOCATION PLAN SEE INSET ABOVE.

BORING A-1

Table for Boring A-1 with columns for depth, soil type, and test results.

BORING A-2

Table for Boring A-2 with columns for depth, soil type, and test results.

BORING A-3

Table for Boring A-3 with columns for depth, soil type, and test results.

BORING A-4

Table for Boring A-4 with columns for depth, soil type, and test results.

BORING A-5

Table for Boring A-5 with columns for depth, soil type, and test results.

BORING A-6

Table for Boring A-6 with columns for depth, soil type, and test results.

BORING A-7

Table for Boring A-7 with columns for depth, soil type, and test results.

BORING A-8

Table for Boring A-8 with columns for depth, soil type, and test results.

BORING A-9

Table for Boring A-9 with columns for depth, soil type, and test results.

BORING A-10

Table for Boring A-10 with columns for depth, soil type, and test results.

BORING A-11

Table for Boring A-11 with columns for depth, soil type, and test results.

BORING A-13

Table for Boring A-13 with columns for depth, soil type, and test results.

BORING A-15

Table for Boring A-15 with columns for depth, soil type, and test results.

BORING A-16

Table for Boring A-16 with columns for depth, soil type, and test results.

BORING A-17

Table for Boring A-17 with columns for depth, soil type, and test results.

BORING A-18

Table for Boring A-18 with columns for depth, soil type, and test results.

BORING A-19

Table for Boring A-19 with columns for depth, soil type, and test results.

BORING A-20

Table for Boring A-20 with columns for depth, soil type, and test results.

BORING A-21

Table for Boring A-21 with columns for depth, soil type, and test results.

BORING A-22

Table for Boring A-22 with columns for depth, soil type, and test results.

REFERENCE BID SPEC. G-3105 1-21-74

NOTES

- LEGEND FOR DRILLING METHODS
SS: Split-Spoon--2" O. D.
DC: Drive Casing--2 1/2" I. D., except where noted
WC: Washed Out
RC: Rock Core
RQD: Rock Quality Designator
FA: Flight Auger
HA: Hand Auger

REFERENCE DRAWINGS

BORING C-1

Table for Boring C-1 with columns for depth, soil type, and test results.

BORING C-2

Table for Boring C-2 with columns for depth, soil type, and test results.

BORING C-3

Table for Boring C-3 with columns for depth, soil type, and test results.

BORING C-5

Table for Boring C-5 with columns for depth, soil type, and test results.

BORING C-6

Table for Boring C-6 with columns for depth, soil type, and test results.

BORING C-4


Table for Boring C-4 with columns for depth, soil type, and test results.

I hereby certify that this plan, specification or report was prepared by me or under my direct personal supervision and that I am a duly registered Professional Engineer under the laws of the State of Iowa.
Date 9-10-73
R. N. Bergstrom, P. E., 5040 Reg. No. 4480




SOIL BORING LOGS SHEET 1 LANSING POWER STATION INTERSTATE POWER COMPANY LANSING, IOWA


SCALE NONE
DRAWN V. CASTRO 8-24-73
CHECKED R. O. DODD 9-7-73
ENGINEER R. N. Bergstrom 9-7-73
APPROVED R. N. Bergstrom 9-10-73
JOB NO. 4644-03
DRAWING NO. S-3




SECTION 1-1




SECTION 2-2




SECTION 3-3




SECTION 4-4




SECTION 5-5




SECTION 6-6




SECTION 7-7




SECTION 8-8




SECTION 9-9




SECTION 10-10



SECTION 11-11



TYPICAL NEW SLOPED DIKE SECTION



TYPICAL EXISTING SLOPED DIKE SECTION

- NOTES
1. WORK THE DWG. WITH DWGS S-10 & S-11
 2. ALL FILL SHALL CONFORM TO SPSC G-3105.
 3. ASH DIKE SECTIONS 4, 5 & 6 REVISED AS PER FIELD INFORMATION DATED 7/30/76.

- REFERENCE DRAWINGS
- S-10 SITE DEVELOPMENT - COPPERDAM & DRAINING PLAN
 - S-11 SITE DEVELOPMENT - PLANT FILL - UNIT 4

I hereby certify that in plan, specification or report was prepared by me or under my direct personal supervision and that I am a duly registered Professional Engineer under the laws of the State of Iowa.

Date: 6-5-77

R. M. ...

Rev.	Date	Init.	Description
6-7-74	6-7-74	RCA	REVISED
A	12-22-74
B	2-2-75
C	2-2-75
D	7-2-75
E	9-9-77

SITE DEVELOPMENT
ASH DIKE SECTIONS - SHEET 1
LANSING POWER STATION
INTERSTATE POWER COMPANY
LANSING, IOWA

SCALE: VERT 1"=10' HORIZ 1"=50'	SARGENT & LUNDY ENGINEERS CHICAGO
DRAWN: G.R. BOWE 5-20-74	
CHECKED: R.C. ODEGAARD 5-22-74	DRAWING NO. S-14
ENGINEER: <i>R.M. ...</i> 6-5-77	
APPROVED: <i>R.M. ...</i> 6-5-77	JOB NO. A444-67

EXHIBIT B – 2015 Investigation

Alliant Energy
Interstate Power and Light Company
Lansing Generating Station
Lansing, Iowa

Unstable Area Determination

BORING LOG

CLIENT: Hard Hat

COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED

PROJECT: Lansing, IA

BORING NO.: **SBI**

page 1 of 1

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION BLOW COUNTS	N-VALUE	SOIL CONSISTENCY HISTOGRAM	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i> EDITED BY: <i>John Noyes</i> CHECKED BY: <i>Mark Loerop</i> DATE BEGAN: <i>1/22/15</i> DATE FINISHED: <i>1/22/13/15</i> GROUND SURFACE ELEVATION: <i>NOT MEASURED</i>	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------------------	---------	----------------------------	---------------	---------	---	-------------

	SS1	18"	4 4 5	9.0		0		SILT; brown; plastic; moist; trace clay	
	SS2	18"	4 5 10	15.0		-2		SAND; brown; fine grained; poorly graded; well sorted; dry to moist	
	SS3	18"	3 6 9	15.0		-4		1'-5' sample collected for geotech analysis	
	SS4	18"	7 9 11	20.0		-6		@ 9'2" black stained with plant matter	
	SS5	18"	7 10 13	23.0		-8			
	SS6	18"	7 11 18	29.0		-10			
⊗	SS7	18"	8 11 14	25.0		-12		SAND; gray; fine to medium grained; moist; graded; trace gravel and snail shells	
	SS8	18"	8 11 13	24.0		-14		@ 15' grades wet	
	SS9	18"	8 11 11	22.0		-16		15'-20' sample collected for geotech analysis	
	SS10	18"	4 7 7	14.0		-18		@17.5' grades brown	
	SS11	18"	2 3 6	8.0		-20		@23.5' grades fine to coarse, well graded	
	SS12	18"	0 0 0	0.0		-22		SILT; gray; non plastic; wet; trace clay	
	SS13	18"	0 0 0	0.0		-24		28'-32' sample collected for geotech analysis	
	SS14	18"	1 1 2	3.0		-26		@29' grades trace plant matter and snail shells	
	SS15	18"	3 4 4	8.0		-28			
	SS16	18"	0 9 11	20.0		-30		GRAVEL; brown; coarse; poorly graded; wet; trace cobbles	
	SS17	18"	5 11 10	21.0		-32		40'-50' sample collected for geotech analysis	
	SS18	18"	4 5 7	12.0		-34			
	SS19	18"	3 4 8	12.0		-36		SAND; light gray; coarse grained; poorly graded; wet	
						-38			
						-40			
						-42			
						-44			
						-46			
						-48			
						-50			
						-52		Bottom of boring @ 50'	
						-54		1" PVC temp well installed @ 50'. 10' screen, natural sand pack	

BORING LOG

CLIENT: Hard Hat

COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED

PROJECT: Lansing, IA

BORING NO.: SB3

page 1 of 1

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION BLOW COUNTS	N-VALUE	SOIL CONSISTENCY HISTOGRAM	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Mark Loerop</i>	DATE BEGAN: <i>1/22/15</i>	DATE FINISHED: <i>1/22/15</i>	GROUND SURFACE ELEVATION: <i>NOT MEASURED</i>
								DESCRIPTION					

N	SS1	18"	6 7 7	14.0		0		SILT; gray to black; non plastic; moist; some bottom ash
	SS2	18"	4 9 10	19.0		-2		SAND; brown; fine grained; poorly graded; moist 2'-5' sample collected for geotech analysis
	SS3	18"	5 10 19	29.0		-4		
	SS4	18"	7 13 16	29.0		-6		
	SS5	18"	6 12 17	29.0		-8		
	SS6	18"	6 12 16	28.0		-10		13'-20' sample collected for geotech analysis @13.5' grades wet and trace snail shells
	SS7	18"	12 21 21	42.0		-14		@16' grades fine to medium grained; graded
	SS8	18"	8 12 15	27.0		-16		
	SS9	18"	8 19 21	40.0		-18		
	SS10	18"	8 5 6	11.0		-20		24'-27' sample collected for geotech analysis
	SS11	18"	6 8 15	23.0		-24		SILT; gray; non plastic to low plasticity; wet; some clay; trace organic plant matter
	SS12	18"	5 5 10	15.0		-26		GRAVEL; gray; coarse to cobbles; poorly graded; wet; trace to some sand 27'-32' sample collected for geotech analysis
	SS13	18"	3 1 1	2.0		-28		SILT; gray to black; non plastic; wet; trace to some clay and organic plant matter
	SS14	18"	6 10 10	20.0		-30		
	SS15	18"	4 6 12	18.0		-32		GRAVEL; gray; coarse to cobbles; poorly graded; wet; trace to some sand
	SS16	18"	10 9 7	16.0		-34		
	SS17	18"	6 8 10	18.0		-36		
	SS18	18"	22 24 21	45.0		-38		
	SS19	18"	10 10 12	22.0		-40		
	SS20	18"	14 9 12	21.0		-42		
						-44		
						-46		
						-48		
						-50		Bottom of boring @ 50' 1" PVC temp well installed @ 50'. 10' screen, natural sand pack
						-52		
						-54		

BORING LOG

CLIENT: Hard Hat

COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED

PROJECT: Lansing, IA

BORING NO.: SB5

page 1 of 1

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION BLOW COUNTS	N-VALUE	SOIL CONSISTENCY HISTOGRAM	DEPTH IN FEET	PROFILE	LOGGED BY: <i>John Noyes</i>	EDITED BY: <i>John Noyes</i>	CHECKED BY: <i>Mark Loerop</i>	DATE BEGAN: <i>1/23/15</i>	DATE FINISHED: <i>1/23/15</i>	GROUND SURFACE ELEVATION: <i>NOT MEASURED</i>	DESCRIPTION
-------------------------------	---------------------	-----------------	--------------------------------	---------	----------------------------	---------------	---------	------------------------------	------------------------------	--------------------------------	----------------------------	-------------------------------	---	-------------

	SS1	18"	4 4 3	7.0		0		SILT; black; non plastic; dry to moist
	SS2	18"	5 7 12	19.0		-2		SAND; brown; fine grained; poorly graded; moist; trace to some bottom ash
	SS3	18"	5 13 19	32.0		-4		5' bottom ash grades out
	SS4	18"	5 13 15	28.0		-6		
∇	SS5	18"	5 11 13	24.0		-8		10'-16' sample collected for geotech analysis
	SS6	18"	6 12 16	28.0		-10		@12' grades wet and trace snail shells
	SS7	18"	12 14 17	31.0		-12		@ 16' grades gray to olive
	SS8	18"	3 2 2	4.0		-14		Silty CLAY; black to dark gray; low plasticity; moist; trace fine sand and organic plant matter
	SS9	18"	4 4 4	8.0		-16		18.5'-20' sample collected for geotech analysis
	SS10	18"	14 9 2	11.0		-18		SAND & GRAVEL; black; fine to coarse; well graded; wet; trace to some silt
	SS11	18"	2 2 4	6.0		-20		22'-27.5' sample collected for geotech analysis
	SS12	18"	6 7 8	15.0		-22		
	SS13	18"	9 10 10	20.0		-24		
	SS14	18"	10 36 8	44.0		-26		
	SS15	18"	15 12 9	21.0		-28		
	SS16	18"	20 14 14	28.0		-30		
	SS17	18"	11 12 18	30.0		-32		40'-45' sample collected for geotech analysis
	SS18	18"	17 14 15	29.0		-34		@43.5' grades brown
	SS19	18"	13 14 17	31.0		-36		
	SS20	18"	18 19 24	43.0		-38		
						-40		
						-42		
						-44		
						-46		
						-48		
						-50		
						-52		Bottom of boring @ 50'
						-54		1" PVC temp well installed @ 50'. 10' screen, natural sand pack

BORING LOG

CLIENT: Hard Hat

COORDINATES: *N NOT SURVEYED*
E NOT SURVEYED

PROJECT: Lansing, IA

BORING NO.: SB7


page 1 of 1

DEPTH TO WATER WHILE DRILLING	SAMPLE NO. AND TYPE	SAMPLE RECOVERY	SAMPLE INFORMATION BLOW COUNTS	N-VALUE	SOIL CONSISTENCY HISTOGRAM	DEPTH IN FEET	PROFILE	DESCRIPTION
								LOGGED BY: John Noyes EDITED BY: John Noyes CHECKED BY: Mark Loerop DATE BEGAN: 1/23/15 DATE FINISHED: 1/23/15 GROUND SURFACE ELEVATION: NOT MEASURED

N	SS1	18"	3 2 2	4.0		0	Bottom ASH; black; fine grained; poorly graded
	SS2	18"	9 11 19	20.0		-2	SAND; brown; fine grained; poorly graded; moist
	SS3	18"	4 5 13	18.0		-4	4'-10' sample collected for geotech analysis
	SS4	18"	7 14 18	32.0		-6	
	SS5	18"	5 11 20	31.0		-8	
	SS6	18"	8 15 20	35.0		-10	
	SS7	18"	7 12 14	26.0		-12	@16' grades wet
	SS8	18"	7 9 14	23.0		-14	19'-25' sample collected for geotech analysis
	SS9	18"	11 13 17	30.0		-16	@ 21' grades gray
	SS10	18"	8 12 14	26.0		-18	
	SS11	18"	2 3 3	6.0		-20	
	SS12	18"	1 1 1	2.0		-22	
	SS13	18"	3 3 6	9.0		-24	SILT; black to gray; no plasticity; moist to wet; trace clay
	SS14	18"	2 3 4	7.0		-26	29'-32.5' sample collected for geotech analysis
	SS15	18"	1 2 2	4.0		-28	36'-40' sample collected for geotech analysis
	SS16	18"	0 0 0	0.0		-30	
	SS17	18"	2 3 4	7.0		-32	@ 41' grading trace organic plant matter and trace intermittent 1/16" sand seams
	SS18	18"	3 2 2	4.0		-34	@ 44' is a thin, 1" gravel seam
	SS19	18"	8 4 7	11.0		-36	
	SS20	18"	2 8 9	17.0		-38	GRAVEL; brown; coarse; poorly graded; wet; trace to some silt and sand
					-40	46'-50' sample collected for geotech analysis last spoon blocked with large gravel	
					-42		
					-44		
					-46		
					-48		
					-50	Bottom of boring @ 50'	
					-52	1" PVC temp well installed @ 50'.	
					-54	10' screen, natural sand pack	

Particle Size Distribution

Project: IPL - Lansing Generating Station
Boring No.: SB-1, SB-3 & SB-5 "SAND & GRAVEL"
Tested By: TestAmerica
Date: 2/3/2015



SYMBOL	BORING	DEPTH (FT.)	GRAVEL		SAND			SOIL DESCRIPTION	U.S.C.S.	W%
			coarse	fine	coarse	medium	fine			
▲	SB-1	40 - 50						SAND & GRAVEL	SW/GW	18.5
▲	SB-3	27 - 32						SAND & GRAVEL	SW/GW	13.4
▲	SB-5	22 - 27.5						SAND & GRAVEL	SW/GW	32.1
×	SB-5	44 - 45						SAND & GRAVEL	SW/GW	9.8

COBBLES	GRAVEL		SAND			SILT AND CLAY FRACTION
	coarse	fine	coarse	medium	fine	

NOTICE: THIS DRAWING IS THE PROPERTY OF HARD HAT SERVICES AND IS NOT TO BE REPRODUCED, CHANGED, OR COPIED IN ANY FORM OR MANNER WITHOUT PRIOR WRITTEN PERMISSION. ALL RIGHTS RESERVED.

SCALE: NONE
DRAWN BY: JFD
CHECKED BY: TJH
APPROVED BY: MWL
DATE: 5-14-15


CLIENT / LOCATION: INTERSTATE POWER AND LIGHT (IPL)
LANSING GENERATING STATION PROJECT
2320 POWER PLANT DR
LANSING, IA 52151

DRAWING DESCRIPTION: SEEPAGE CONTROL CUT-OFF WALL
PARTICLE SIZE DISTRIBUTION
SB-1 & SB-3

JOB: 154.021.003
SHT.: 8
DWG.: 154021SW-08-12

Particle Size Distribution

Project: IPL - Lansing Generating Station
Boring No.: SB-1, SB-3 & SB-5 "SANDY SILT"
Tested By: TestAmerica
Date: 2/3/2015



SYMBOL	BORING	DEPTH (FT.)	GRAVEL		SAND			SOIL DESCRIPTION	U.S.C.S.	L.L.	P.L.	W%
			coarse	fine	coarse	medium	fine					
▲	SB-1	28 - 32						Sandy Silt	ML	28	26	36.1
▲	SB-3	24.5 - 27						Sandy Silt	ML	27	23	25.4
▲	SB-5	18.5 - 20						Sandy Silt	ML	24	20	21.8


COBBLES	GRAVEL		SAND			SILT AND CLAY FRACTION
	coarse	fine	coarse	medium	fine	

APPENDIX B
UPDATE TO ADD SB-7
, SEPARATE SILEX 111



Particle Size Distribution

Project: IPL - Lansing Generating Station
 Boring No.: SB-1, SB-3 & SB-5 "UPPER SAND"
 Tested By: TestAmerica Date: 2/3/2015



COBBLES	GRAVEL		SAND			SILT AND CLAY FRACTION
	coarse	fine	coarse	medium	fine	

SYMBOL	BORING	DEPTH (FT.)	SOIL DESCRIPTION	U.S.C.S.	W%
▲	SB-1	1 - 5	Medium - Fine Sand	SP	4.1
▲	SB-1	15 - 20	Medium - Fine Sand	SP	20.1
▲	SB-3	2 - 5	Silty Medium - Fine Sand	SM	3.1
▲	SB-3	13 - 20	Medium - Fine Sand	SP	19.0
▲	SB-5	10 - 16	Medium - Fine Sand	SP	13.3

NOTICE: THIS DRAWING IS THE PROPERTY OF HARD HAT SERVICES AND IS NOT TO BE REPRODUCED, CHANGED, OR COPIED IN ANY FORM OR MANNER WITHOUT PRIOR WRITTEN PERMISSION. ALL RIGHTS RESERVED.

REV	DATE	BY	APP	DESCRIPTION
1	6-15-15	TJH	MWL	INCORPORATE IPL COMMENTS

SCALE: NONE	DATE: 5-14-15
DRAWN BY: JTD	CHECKED BY: TJH
	APPROVED BY: MWL

CUSTOMER / LOCATION
 INTERSTATE POWER AND LIGHT (IPL)
 LANSING GENERATING STATION PROJECT
 2320 POWER PLANT DR
 LANSING, IA 52151


DRAWING DESCRIPTION
 SEEPAGE CONTROL CUT-OFF WALL
 PARTICLE SIZE DISTRIBUTION
 SB-5

JOB: 154.021.003
 SHEET: 9
 DWG: 154021SW-08-12

APPENDIX B
 UPDATE TO ADD SB-7
 SEPARATE 2 1/2 x 11

" UPPER SAND "

PROJECT _____ TESTED BY _____ DATE _____
 PROJECT NO. _____ CALC BY _____ DATE _____
 BORING NO. _____ CHKD BY _____ DATE _____




COBBLES	GRAVEL		SAND			SILT AND CLAY FRACTION
	coarse	fine	coarse	medium	fine	

SYMBOL	BORING	SAMPLE	DEPTH	SOIL DESCRIPTION	U.S.C.S.	L.L.	P.L.	W%
○	SB-1		1-5	MED-FINE SAND	SP			4.1
□	SB-1		15-20	"	SP			20.1
△	SB-3		2-5	SILTY MED-FINE SAND	SM			3.1
▽	SB-3		13-20	MED-FINE SAND	SP			19.0
⊙	SB-5		10-16	"	SP			13.3
◇	SB-7		4-10	"	SPSM			3.1
■	SB-7		19-25	"	SP			17.1

"SANDY SILT"

PROJECT _____ TESTED BY _____ DATE _____
 PROJECT NO. _____ CALC BY _____ DATE _____
 BORING NO. _____ CHKD BY _____ DATE _____




COBBLES	GRAVEL		SAND			SILT AND CLAY FRACTION
	coarse	fine	coarse	medium	fine	

SYMBOL	BORING	SAMPLE	DEPTH	SOIL DESCRIPTION	U.S.C.S.	L.L.	PL	W%
○	SB-1		28-32	SANDY SILT	ML	28	26	36.1
□	SB-3		24.5-27	SANDY SILT	ML	27	23	23.4
△	SB-5		18.5-20	SANDY SILT	ML	24	20	21.8
▽	SB-7		29-32.5	SANDY SILT	ML	29	25	27.0
⊙	SB-7		36-40	SANDY SILT	ML	31	26	35.7

"SANDY GRAVEL"

PROJECT _____ TESTED BY _____ DATE _____
 PROJECT NO. _____ CALC BY _____ DATE _____
 BORING NO. _____ CHKD BY _____ DATE _____



COBBLES	GRAVEL		SAND			SILT AND CLAY FRACTION
	coarse	fine	coarse	medium	fine	

SYMBOL	BORING	SAMPLE	DEPTH	SOIL DESCRIPTION	U.S.C.S.	L.L.	P.L.	W%
○	SB-1		40-50	SAND & GRAVEL	SW/GM			16.5
□	SB-3		27-32	"	"			13.4
△	SB-5		22-27.5	"	"			32.1
▽	SB-5		44-45	"	"			9.8
◇	SB-7		46-50	"	"			35.7

EXHIBIT C – Iowa Bedrock Map

Alliant Energy
Interstate Power and Light Company
Lansing Generating Station
Lansing, Iowa

Unstable Area Determination

BEDROCK GEOLOGIC MAP OF IOWA

1:500,000

Iowa Geological and Water Survey
Open File Map OFM-2010-01
March 2010


Primary Map Compilation By
Brian J. Witzke, Raymond R. Anderson and John P. Pope
Iowa Geological and Water Survey, Iowa City, Iowa

ACKNOWLEDGEMENTS

Recognized for significant contributions to the map's production: Bill J. Bunker, James D. Giglietto, Greg A. Ludvigson, Robert M. McKay, Huibao P. Liu, and Thomas R. Marshall.
Supported in part with funding from the U.S. Geological Survey - National Cooperative Geologic Mapping Program.

Lansing
Generating
Station

Bedrock Formations
Surrounding
Lansing
Generating Station



EXPLANATION

CRETACEOUS

- Kint
- Manson Impact Structure, Tertiary Tertiary (brassic)
- Kimm
- Manson Impact Structure, Cretaceous Most (shaly brassic)
- Kinc
- Manson Impact Structure, Central Peak (brassic, basement rock impregnation)
- Km
- Hobbs Formation (shale)
- Kf
- Fort Benton Group (shale, chert)
- Kd
- Dakota and Winnebago Formations (sandstone, shale)

JURASSIC

- Jf
- Fort Dodge Formation (limestone, redbeds)

PENNSYLVANIAN

- Pw
- Wabasha Group (shale, limestone)
- Pb
- Shawnee Group (limestone, shale)
- Pd
- Douglas Group (shale, limestone, sandstone)
- Pt
- Lansing Group (limestone, shale)
- Pc
- Hannas City Group (limestone, shale)
- Pb
- Bronson Group (limestone, shale)
- Pm
- Mormon Group (shale, limestone)
- Pcu
- Upper Cherokee Group (shale, sandstone, limestone)
- Pcl
- Lower Cherokee Group and Racoon Creek Group (shale, sandstone)

MISSISSIPPIAN

- Mt
- St. Louis and Pella Formations (dolomite, limestone, sandstone)
- Mh
- Augusta Group (dolomite, limestone, chert)
- Mg
- Gilmore City Formation (limestone, dolomite)
- Mk
- Mississippi River (dolomite, limestone, siliceous)

DEVONIAN

- Df
- Farmington Formations (shale, siliceous, dolomite)
- Di
- Line Creek and Besant Creek Formations (shale, limestone)
- Dc
- Cedar Valley Group (dolomite, limestone)
- Dw
- Wapsiegan Group (limestone, limestone, sandstone, anthracite)

SILURIAN

- Sg
- Gower Formation (dolomite)
- Ss
- Scott Grove Formation (dolomite, chert)
- Sh
- Hopkinton, Standing, Tule, and Mott, Madison Formations (limestone, chert)
- Sf
- Lafayette City Formation (limestone, chert)
- Sw
- Waucoma Formation (limestone)

ORDOVICIAN

- Om
- Moscow Formation (shale, dolomite)
- Og
- Gilbert Group and Pottawatomie Formation (dolomite, shale, chert)

CAMBRIAN

- Op
- Pierre du Chien Group and St. Peter Sandstone (limestone, sandstone)
- Cw
- Waverly Formation (sandstone)
- Cc
- Elm Grove Formation (sandstone, shale)
- Cm
- St. Simon Sandstone (sandstone)

PRECAMBRIAN

- Q
- Beau Quartzite (granite)

Scale: 0 5 10 20 30 40 50 60 Miles
0 5 10 20 30 40 50 60 Kilometers


Transparent shades of gray show the bedrock surface as viewed by stereoscopy by an artificial light source coming from the NW direction.

EXHIBIT D – Iowa Karst Maps

Alliant Energy
Interstate Power and Light Company
Lansing Generating Station
Lansing, Iowa

Unstable Area Determination

NE Iowa Karst



Map layers Legend

- AFO Siting Data
 - Sinkholes
 - Ag Drainage Well
 - Wells
 - Animal Feeding Operation
 - Active, Confined/Open
 - Active, Confinement
 - Active, Open Feedlot
 - Inactive
 - Public Drainage Infrastructure
 - Drainage Districts
 - High Qty Wtr Resource (Rivers)
 - High Qty Wtr Resource (Waterbody)
 - Major Water Source (Rivers)
 - Major Water Source (Lake)
 - Surface Water
 - Public Land
 - Public Land Survey (PLSS)
 - Designated Wetland
 - Designated Wetland
 - Wetland Buffer(2500ft)
 - Sinkhole or Potential Karst
 - Sinkhole w/ 1000 ft radius
 - Karst and Potential Karst
 - 100 Year Flood Plain
 - Alluvial Soils







EXHIBIT E – Groundwater Info from SCS Engineers

Alliant Energy
Interstate Power and Light Company
Lansing Generating Station
Lansing, Iowa

Unstable Area Determination



LEGEND

	APPROVED LIMITS OF WASTE
	LIMITS OF PHASE 1 FINAL COVER
	LIMITS OF PHASE 2 FINAL COVER
	SLURRY WALL
	EXISTING STREAM
	EXISTING MONITORING WELL
	EXISTING PIEZOMETER
	ABANDONED MONITORING WELL
	ABANDONED PIEZOMETER
	CCR MONITORING WELL
	CCR UNITS

- NOTES:
- 2011 AERIAL PHOTOGRAPH FROM THE USDA-FSA AERIAL PHOTOGRAPHY FIELD OFFICE.
 - MONITORING WELL LOCATIONS AND CCR UNIT LIMITS ARE APPROXIMATE.
 - MONITORING WELLS MW20, MW301, MW302, AND MW303 WERE INSTALLED BY CASCADE DRILLING IN NOVEMBER 2015.
 - MONITORING WELLS MW304, MW305, AND MW306 WERE INSTALLED BY ROBERTS ENVIRONMENTAL DRILLING IN MAY 2019.
 - MONITORING WELLS MW302A, MW304A, AND MW306A WERE INSTALLED BY CASCADE DRILLING IN DECEMBER 2019.

PROJECT NO.	25220070.00	DRAWN BY:	BSS
DRAWN:	11/27/2019	CHECKED BY:	MDB
REVISED:	03/12/2020	APPROVED BY:	TK 03/12/2020



SCS ENGINEERS
 2830 DAIRY DRIVE MADISON, WI 53718-6751
 PHONE: (608) 224-2830

CLIENT INTERSTATE POWER AND LIGHT
 2320 POWER PLANT DRIVE
 LANSING, IA 52151-9733

SITE ALLIANT ENERGY
 LANSING POWER STATION
 LANSING, IOWA

SITE PLAN AND MONITORING
 WELL LOCATIONS

FIGURE
 2



LEGEND	
	APPROVED LIMITS OF WASTE
	LIMITS OF PHASE 1 FINAL COVER
	LIMITS OF PHASE 2 FINAL COVER
	SLURRY WALL
	EXISTING STREAM
	EXISTING MONITORING WELL
	EXISTING PIEZOMETER
	ABANDONED MONITORING WELL
	ABANDONED PIEZOMETER
	CCR MONITORING WELL
	CCR UNITS
	WATER TABLE ELEVATION MEASURED ON 07/06/2020
	WATER TABLE CONTOUR
	APPROXIMATE GROUNDWATER FLOW DIRECTION

- NOTES:
- 2011 AERIAL PHOTOGRAPH FROM THE USDA-FSA AERIAL PHOTOGRAPHY FIELD OFFICE.
 - MONITORING WELL LOCATIONS AND CCR UNIT LIMITS ARE APPROXIMATE.
 - MONITORING WELLS MW20, MW301, MW302, AND MW303 WERE INSTALLED BY CASCADE DRILLING IN NOVEMBER 2015.
 - MONITORING WELLS MW304, MW305, AND MW306 WERE INSTALLED BY ROBERTS ENVIRONMENTAL DRILLING IN MAY 2019.
 - MONITORING WELLS MW302A, MW304A, AND MW306A WERE INSTALLED BY CASCADE DRILLING IN DECEMBER 2019.

PROJECT NO.	25220070.00	DRAWN BY:	BSS
DRAWN:	07/31/2020	CHECKED BY:	MDB
REVISED:	07/31/2020	APPROVED BY:	

ENGINEER	
----------	--

SCS ENGINEERS
 2830 DAIRY DRIVE MADISON, WI 53718-6751
 PHONE: (608) 224-2830

CLIENT	INTERSTATE POWER AND LIGHT 2320 POWER PLANT DRIVE LANSING, IA 52151-9733
--------	--

SITE	ALLIANT ENERGY LANSING POWER STATION LANSING, IOWA
------	--

POTENTIOMETRIC SURFACE MAP JULY 6, 2020
--

FIGURE 2

Table 2. Vertical Hydraulic Gradient Summary
Interstate Power & Light - Lansing, Iowa / SCS Engineers Project #25220070.00

Vertical Hydraulic Gradients	MW302/MW302A		MW304/MW304A		MW306/MW306A			
	Monitoring Well screen bottom (feet amsl)	Piezometer effective screen midpoint (feet amsl)	Distance between screen midpoints (feet)	Vertical Gradient (ft/ft) ⁽¹⁾	Distance between screen midpoints (feet)	Vertical Gradient (ft/ft) ⁽¹⁾		
	MW302 616.90	MW302A 592.43			MW304 620.43	MW304A 591.10	MW306 611.48	MW306A 587.06
Measurement Date								
May 20-21, 2020	29.9	-0.150	29.9	0.111	28.9	-0.001		
July 6, 2020	NM	NM	NM	NM	NM	NM		
August 19-21, 2020	29.8	-0.135	30.0	NM	28.9	0.009		
October 19-20, 2020	29.6	-0.139	29.8	0.101	28.6	0.009		

Notes:

1: A positive vertical gradient indicates upward groundwater flow. A negative gradient indicates downward flow.

2: The screen midpoint for water table wells is calculated as the midpoint between the water table elevation and screen bottom elevation.

NM: Not Measured

NI: Not Installed

Created by: TK
 Last revision by: TK
 Checked by: NDK

Date: 10/23/2020
 Date: 10/23/2020
 Date: 10/23/2020

I:\25220070.00\Data and Calculations\Tables\[LAN_wlstat.xls]gradient (CCR Wells)