

**Interstate Power and Light Company
Lansing Generating Station (LAN)**

Coal Combustion Residuals (CCR) Fugitive Dust Control Plan

November 14, 2025

The procedures in this plan apply to the following CCR units at this facility:

CCR Surface Impoundments

LAN Upper Ash Pond

Coal Combustion Residuals (CCR) Fugitive Dust Control Plan for CCR Surface Impoundments

November 14, 2025

Purpose of CCR Fugitive Dust Control Plan

This plan describes the measures used to minimize fugitive CCR dust from facilities with CCR surface impoundments¹, the procedure for logging citizen complaints involving CCR fugitive dust events, and the procedure for periodic review of this plan. This plan has been developed in accordance with 40 CFR 257.80(b).

Measures for Controlling Fugitive Dust

The facility previously consisted of a coal-fired power plant, a CCR landfill, and an existing CCR surface impoundment. The facility has retired, and the plant has been demolished. In addition, the CCR landfill has been closed, and the CCR surface impoundment has initiated closure activities including installation of a final cover system.

The following measures are appropriate for minimizing CCR from becoming airborne from the CCR surface impoundments at this facility, if CCR management occurs at this facility in the future:

- Establishing and enforcing a vehicle speed limit of 15 mph or less.
- Covering all open-bodied trucks that are transporting CCR.
- Minimizing fall distances when handling or transferring CCR.
- Promptly collecting CCR that is observed in vehicle loading/unloading areas.

Procedure for Logging Citizen Complaints

Citizen complaints pertaining to fugitive dust will be managed in accordance with Alliant Corporate Policy ENV-107. Specifically, the complaint must be reported to Environmental Services (1) via phone call and (2) in writing by submitting a completed Environmental Incident Report to Environmental Services within 10 business days. Citizen complaints will be tracked within the Alliant Environmental Management Information System (“ENVIANCE”).

Procedure for Periodic Review of CCR Fugitive Dust Control Plan

The CCR Fugitive Dust Control Plan will be reviewed and updated, as necessary, in accordance with Alliant Energy Corporate Policy ENV-103 (Environmental Compliance Verification).


During the periodic review, staff will evaluate each measure for controlling fugitive dust to ensure that it is still appropriate for minimizing CCR from becoming airborne at the facility, will verify that the procedure for logging complaints is sufficient, and will evaluate other operations changes at the facility to determine whether additional dust control measures should be added.

- END -

¹ “CCR” and “CCR surface impoundment” are defined at 40 CFR 257.53.

P.E. Certification

I, the undersigned, hereby certify that this CCR Fugitive Dust Control Plan meets the requirements of 40 CFR 257.80(b), was prepared by me or under my direct supervision, and that I am a duly licensed Professional Engineer under the laws of the State of Iowa.



Signature



Eric J. Nelson

First and Last Name

23136

P.E. License Number

November 11, 2025

Date

My license renewal date is December 31, 2026.