



Alliant Energy
4902 North Biltmore Lane
P.O. Box 77007
Madison, WI 53707-1007

1-800-ALLIANT (800-255-4268)
alliantenergy.com

August 12, 2020

To: CCR Operating Record

Re: Notification of Groundwater Protection Standard Exceedance pursuant to 40 CFR 257.95

A constituent in Appendix IV to part 40 CFR 257 was detected at a statistically significant level above the groundwater protection standard (GPS) established under 40 CFR 257.95(h) in a monitoring well located at the former M.L. Kapp Generating Station. The constituent exceeding the GPS is molybdenum, as sampled in monitoring wells MW-301, MW-302, MW-304, and MW-305. This notification has been prepared in accordance with 40 CFR 257.95(g) and 257.105(h)(8).

This notification applies to the following CCR units at this facility:

CCR units

KAP Main Ash Pond (closed)

Signed,

A handwritten signature in black ink, appearing to read "Jeff Maxted".

Print Name Jeff Maxted	Title Manager - Environmental Services
Phone No. or Email Address (608) 458-3853; jeffreymaxted@alliantenergy.com	