

2024 Annual Groundwater Monitoring and Corrective Action Report

Ottumwa Midland Landfill
Ottumwa, Iowa

Prepared for:

Alliant Energy



SCS ENGINEERS

25224073.00 | January 31, 2025

2830 Dairy Drive
Madison, WI 53718-6751
608-224-2830

OVERVIEW OF CURRENT STATUS

Ottumwa-Midland Landfill 2024 Annual Report

In accordance with §257.90(e)(6), this section at the beginning of the annual report provides an overview of the current status of groundwater monitoring and corrective action programs for the Coal Combustion Residual (CCR) unit. The groundwater monitoring system at the Ottumwa Midland Landfill (OML) monitors a single CCR unit. Supporting information is provided in the text of the annual report.

Category	Rule Requirement	Site Status
Monitoring Status – Start of Year	(i) At the start of the current annual reporting period, whether the CCR unit was operating under the detection monitoring program in §257.94 or the assessment monitoring program in §257.95;	Detection
Monitoring Status – End of Year	(ii) At the end of the current annual reporting period, whether the CCR unit was operating under the detection monitoring program in §257.94 or the assessment monitoring program in §257.95;	Detection
Statistically Significant Increases (SSIs)	(iii) If it was determined that there was an SSI over background for one or more constituents listed in appendix III to this part pursuant to §257.94(e): (A) Identify those constituents listed in appendix III to this part and the names of the monitoring wells associated with such an increase; and	<u>October 2023</u> No SSIs <u>April 2024</u> No SSIs
	(B) Provide the date when the assessment monitoring program was initiated for the CCR unit.	Not applicable Assessment monitoring not required

Category	Rule Requirement	Site Status
Statistically Significant Levels (SSL) Above Groundwater Protection Standard	(iv) If it was determined that there was an SSL above the groundwater protection standard for one or more constituents listed in appendix IV to this part pursuant to §257.95(g) include all of the following:	Not applicable In detection monitoring
	(A) Identify those constituents listed in appendix IV to this part and the names of the monitoring wells associated with such an increase;	
	(B) Provide the date when the assessment of corrective measures was initiated for the CCR unit;	
	(C) Provide the date when the public meeting was held for the assessment of corrective measures for the CCR unit; and	
	(D) Provide the date when the assessment of corrective measures was completed for the CCR unit.	
Selection of Remedy	(v) Whether a remedy was selected pursuant to §257.97 during the current annual reporting period, and if so, the date of remedy selection; and	Not applicable In detection monitoring
Corrective Action	(vi) Whether remedial activities were initiated or are ongoing pursuant to §257.98 during the current annual reporting period.	Not applicable In detection monitoring

Table of Contents

Section	Page
Overview of Current Status.....	i
1.0 Introduction.....	1
2.0 Background.....	1
2.1 Geologic and Hydrogeologic Setting.....	1
2.1.1 Regional Information.....	1
2.1.2 Site information	2
2.2 CCR Rule Monitoring System.....	2
3.0 § 257.90(e) Annual Report Requirements.....	3
3.1 §257.90(e)(1) Site Map.....	3
3.2 §257.90(e)(2) Monitoring System Changes.....	3
3.3 §257.90(e)(3) Summary of Sampling Events.....	3
3.4 § 257.90(e)(4) Monitoring Transition Narrative.....	4
3.5 § 257.90(e)(5) Other Requirements.....	4
3.5.1 § 257.90(e) General Requirements.....	5
3.5.2 § 257.94(d) Alternative Detection Monitoring Frequency	6
3.5.3 § 257.94(e)(2) Alternative Source Demonstration for Detection Monitoring	6
3.5.4 § 257.95(c) Alternative Assessment Monitoring Frequency	6
3.5.5 § 257.95(d)(3) Assessment Monitoring Results and Standards	6
3.5.6 § 257.95(g)(3)(ii) Alternative Source Demonstration for Assessment Monitoring	6
3.5.7 § 257.96(a) Extension of Time for Corrective Measures Assessment	6
3.6 §257.90(e)(6) Overview.....	7
4.0 References.....	7

Tables

- Table 1. Groundwater Monitoring Well Network
- Table 2. CCR Rule Groundwater Samples Summary
- Table 3. Groundwater Elevation – CCR Rule Monitoring Network
- Table 4. Horizontal Gradients and Flow Velocity
- Table 5. Groundwater Analytical Results Summary
- Table 6. Groundwater Field Data Summary

Figures

- Figure 1. Site Location Map
- Figure 2. Site Plan and Monitoring Well Locations
- Figure 3. Potentiometric Surface Map, April 3-4, 2024
- Figure 4. Potentiometric Surface Map, October 8, 2024

Appendices

- Appendix A Regional Hydrogeologic Information
- Appendix B Boring Logs and Well Construction Documentation
- Appendix C Laboratory Reports
- Appendix D Historical Monitoring Results

I:\25224073.00\Deliverables\2024 - Annual CCR Report\250131_2024 Annual CCR GW Report_OML_Final.docx

1.0 INTRODUCTION

This 2024 Annual Groundwater Monitoring and Corrective Action Report was prepared to support compliance with the groundwater monitoring requirements of the Coal Combustion Residuals (CCR) Rule [40 CFR 257.50-107]. Specifically, this report was prepared to fulfill the requirements of 40 CFR 257.90(e). The applicable sections of the Rule are provided below in *italics*, followed by applicable information relative to the 2024 Annual Groundwater Monitoring and Corrective Action Report for the CCR Units.

This report covers the period of groundwater monitoring from January 1, 2024, through December 31, 2024.

The groundwater monitoring system at the Ottumwa Midland Landfill (OML) monitors a single CCR unit with two phases:

- OML Landfill & OML Landfill Expansion - Phase 1 (existing landfill)

The system is designed to detect monitored constituents in the uppermost aquifer at the waste boundary of OML as required by 40 CFR 257.91(d). The groundwater monitoring system consists of two upgradient and three downgradient monitoring wells.

2.0 BACKGROUND

To provide context for the annual report, the following background information is provided in this section of the report, prior to the annual report requirement sections:

- Geologic and hydrogeologic setting
- CCR Rule monitoring system

2.1 GEOLOGIC AND HYDROGEOLOGIC SETTING

2.1.1 Regional Information

The uppermost bedrock unit in the site area consists of Pennsylvanian shales with minor siltstone, sandstone, limestone, and coal intervals. The continuity of these minor beds is highly variable. The thickness of the Pennsylvanian shale is variable; in some areas of Wapello County, it is over 100 feet thick, while in other areas it is absent. The variation in thickness is due to erosion of the bedrock surface. Underlying the Pennsylvanian shales are Mississippian limestone and dolomite, with some shale and sandstone. The Devonian units underlying the Mississippian are composed of shale, dolomite, and limestone, and are in turn underlain by Silurian dolomite (Montgomery Watson, 1994). A summary of the regional hydrogeologic stratigraphy is presented in **Appendix A**.

The Des Moines River and associated alluvial aquifers are a major source of surface water and shallow groundwater in the area; however, the alluvial aquifer is not present at the OML site. Unconsolidated deposits at the site consist of clays overlain by loess, which are not productive sources of groundwater. The uppermost Pennsylvanian bedrock unit is considered to be a regional aquitard. The Mississippian unit is the shallowest regional bedrock aquifer. The Cambrian-Ordovician aquifer, comprised of dolomite and sandstone, is commonly the source of municipal and industrial high-capacity wells in the region (Coble, 1971).

A summary of the regional hydrogeologic stratigraphy and a map showing regional bedrock surface topography and the top of the Mississippian limestone in Southeastern Iowa are included in **Appendix A**. The bedrock surface elevation is highly variable due to erosion. Regional information indicates that groundwater flow within the Mississippian limestone is to the south-southeast. A map showing the regional potentiometric surface in the Mississippian limestone is included with the hydrogeologic background information presented in **Appendix A**.

For the purposes of groundwater monitoring, the Mississippian limestone unit is considered to be the uppermost aquifer unit at the OML site as defined under 40 CFR 257.53.

2.1.2 Site information

Unconsolidated soils at the site include clay, loam, silt loam, silty clay, sandy loam, and intermediate types. Where present, these soils are generally 5 to 7 feet thick. Pennsylvanian shales and Mississippian limestone underlie the unconsolidated soils. Soils encountered during the drilling and installation of the existing background wells, MW-102M and MW-122M, were described as 10 to 11 feet of lean clay, overlying 126 to 129 feet of shale with intermittent stringers of sandstone and coal. The shale was underlain by Mississippian limestone at 138 to 139 feet below ground surface.

During drilling of CCR wells MW-301, MW-302, and MW-303, soils were described as 4 to 11 feet of clay and silt, overlying 112 to 173 feet of shale with intermittent stringers of sandstone and coal. The shale was underlain by Mississippian limestone at 116 to 168 feet below ground surface.

The boring logs for the landfill CCR monitoring wells are provided in **Appendix B**. All CCR monitoring wells are screened within the Mississippian bedrock unit.

Based on water level monitoring performed for the state monitoring program, shallow groundwater flow at the water table appears to be controlled partially by the landfill underdrain system and partially by the top of the Pennsylvanian shale. Shallow groundwater, near the current fill area, flows toward the landfill and the sedimentation pond. The landfill underdrain system includes a drainage layer and collection piping below the landfill liner and is used to ensure shallow groundwater does not affect performance of the landfill liner.

Based on water levels in the existing Mississippian piezometers at the OML site, a generally south-southeast flow direction has been identified in the Mississippian limestone aquifer, consistent with the regional flow information. The potentiometric surface elevations and groundwater flow directions for the April 2024 monitoring event are shown on **Figure 3**, and the potentiometric surface elevations and groundwater flow directions for the October 2024 monitoring event are shown on **Figure 4**. The groundwater elevation data for the CCR monitoring wells are provided in **Table 3**. Calculated horizontal gradients and flow velocities for each of the flow paths are provided in **Table 4**.

2.2 CCR RULE MONITORING SYSTEM

The groundwater monitoring system established within the CCR Rule consists of two upgradient (background) monitoring wells and three downgradient monitoring wells (**Table 1** and **Figure 2**). The upgradient monitoring wells include MW-122M and MW-102M. The downgradient monitoring wells include MW-301, MW-302, and MW-303. The CCR Rule wells are installed in the upper portions of the Mississippian Limestone aquifer. Well depths range from approximately 150.0 to 204.5 feet, measured from the top of the well casing.

3.0 § 257.90(E) ANNUAL REPORT REQUIREMENTS

Annual groundwater monitoring and corrective action report. For existing CCR landfills and existing CCR surface impoundments, no later than January 31, 2018, and annually thereafter, the owner or operator must prepare an annual groundwater monitoring and corrective action report. For new CCR landfills, new CCR surface impoundments, and all lateral expansions of CCR units, the owner or operator must prepare the initial annual groundwater monitoring and corrective action report no later than January 31 of the year following the calendar year a groundwater monitoring system has been established for such CCR unit as required by this subpart, and annually thereafter. For CCR management units, the owner or operator must prepare the initial annual groundwater monitoring and corrective action report no later than January 31, 2029, and annually thereafter. For the preceding calendar year, the annual report must document the status of the groundwater monitoring and corrective action program for the CCR unit, summarize key actions completed, describe any problems encountered, discuss actions to resolve the problems, and project key activities for the upcoming year. For purposes of this section, the owner or operator has prepared the annual report when the report is placed in the facility's operating record as required by § 257.105(h)(1). At a minimum, the annual groundwater monitoring and corrective action report must contain the following information, to the extent available:

3.1 §257.90(E)(1) SITE MAP

A map, aerial image, or diagram showing the CCR unit and all background (or upgradient) and downgradient monitoring wells, to include the well identification numbers, that are part of the groundwater monitoring program for the CCR unit;

A map showing the location of the site is provided as **Figure 1**. The OML CCR units and all background (or upgradient) and downgradient monitoring wells with identification numbers for the groundwater monitoring program are shown on **Figure 2**.

3.2 §257.90(E)(2) MONITORING SYSTEM CHANGES

Identification of any monitoring wells that were installed or decommissioned during the preceding year, along with a narrative description of why those actions were taken;

No new monitoring wells were installed and no wells were decommissioned as part of the groundwater monitoring program for OML in 2024.

3.3 §257.90(E)(3) SUMMARY OF SAMPLING EVENTS

In addition to all the monitoring data obtained under §§ 257.90 through 257.98, a summary including the number of groundwater samples that were collected for analysis for each background and downgradient well, the dates the samples were collected, and whether the sample was required by the detection monitoring or assessment monitoring programs;

Two semiannual groundwater sampling events were completed in 2024 for OML as part of ongoing detection monitoring.

Groundwater samples collected during the semiannual events, in April and October 2024, were analyzed for the Appendix III constituents. A summary including the number of groundwater samples that were collected for analysis for each background and downgradient well, the dates the samples

were collected, and whether the sample was required by the detection monitoring or assessment monitoring program is included in **Table 2**.

The validation and evaluation of the October 2023 monitoring event data was completed and transmitted to IPL on January 24, 2024. The validation and evaluation of the April 2024 monitoring event data was completed and transmitted to IPL on July 19, 2024. The validation and evaluation of the October 2024 monitoring event data was in progress at the end of 2024 and will be transmitted to IPL in 2025; therefore, the October 2024 monitoring results will be included in the 2025 annual report. The October 2024 groundwater elevation data is included in this report.

The sampling results for Appendix III parameters in October 2023 and April 2024 are summarized in **Table 5**. Field parameter results for the October 2023 and April 2024 sampling events are provided in **Table 6**. The results of the October 2023 and April 2024 analytical laboratory analyses are provided in the laboratory reports in **Appendix C**. Historical results for each monitoring well through April 2024 are summarized in **Appendix D**.

3.4 § 257.90(E)(4) MONITORING TRANSITION NARRATIVE

A narrative discussion of any transition between monitoring programs (e.g., the date and circumstances for transitioning from detection monitoring to assessment monitoring in addition to identifying the constituent(s) detected at a statistically significant increase over background levels);

There were no transitions between monitoring programs in 2024. OML remained in the detection monitoring program.

The monitoring results for the October 2023 and April 2024 monitoring events were evaluated for SSIs in detection monitoring parameters relative to background. For all parameters except chloride, the comparison to background was based on a prediction limit approach, comparing the results to interwell upper prediction limits (UPLs) based on background monitoring results from the upgradient wells (MW-122M and MW-102M). For chloride, the comparison to background used introwell UPLs based on background monitoring results from the compliance wells (MW-301, MW-302, and MW-303).

The interwell and introwell UPLs were most recently updated in August 2023 using background data collected through April 2023 for interwell UPLs and through October 2022 for introwell UPLs. The August 2023 Statistical Analysis was included in the 2023 Annual Report. The Unified Guidance for Statistical Analysis of Groundwater Monitoring Data at Resource Conservation and Recovery Act (RCRA) Facilities (U.S. EPA, 2009; Section 5.3.1) recommends periodic updating of background for both introwell and interwell analyses. For semiannual monitoring, an update interval of 2 to 3 years is recommended.

No SSIs were identified based on the 2024 monitoring data evaluations.

3.5 § 257.90(E)(5) OTHER REQUIREMENTS

Other information required to be included in the annual report as specified in §§ 257.90 through 257.98.

Additional potentially applicable requirements for the annual report, and the location of the requirement within the Rule, are provided in the following sections. For each cited section of the Rule, the portion referencing the annual report requirement is provided below in italics, followed by

applicable information relative to the 2024 Annual Groundwater Monitoring and Corrective Action Report for OML.

3.5.1 § 257.90(e) General Requirements

For the preceding calendar year, the annual report must document the status of the groundwater monitoring and corrective action program for the CCR unit, summarize key actions completed, describe any problems encountered, discuss actions to resolve the problems, and project key activities for the upcoming year.

Status of Groundwater Monitoring and Corrective Action Program. The groundwater monitoring and corrective action program is currently in detection monitoring.

Summary of Key Actions Completed.

- Statistical evaluation and determination of SSIs for the October 2023 and April 2024 monitoring events.
- Two semiannual detection monitoring events (April and October 2024).

Description of Any Problems Encountered. For the October 2023 event, calcium and total dissolved solids (TDS) were detected in the field blank at concentrations exceeding the limit of quantification. The detected levels of both parameters were lower than the levels reported for the monitoring wells. Calcium and TDS were not detected in the method blank samples analyzed by the laboratory, and the monitoring well concentrations for these parameters were consistent with previous results.

In October 2023, field parameters were not collected for background well MW-122M because there was insufficient water available to sample for both the lab parameters and field parameters.

In April 2024, insufficient sample volume was available for sample analysis of all Appendix III lab parameters for background well MW-122M, so TDS and laboratory pH were not analyzed.

Discussion of Actions to Resolve the Problems. For the October 2023 event, the field blank detection did not appear to indicate a problem with the laboratory analysis but may indicate that the water used for the field blank was not reagent quality. During sample collection, the field blank bottles and water do not contact the sampling equipment used at the monitoring wells, so cross-contamination from monitoring wells is not suspected. The data were usable and are not affected by the field blank detections.

Water levels at background well MW-122M were adequate for field parameter analysis and limited Appendix III lab parameter analysis in April 2024 and for field parameter analysis and the full suite of Appendix III lab parameters in October 2024; therefore, additional action to address the previously observed low water levels is not necessary.

Projection of Key Activities for the Upcoming Year (2025).

- Statistical evaluation and determination of any SSIs for the October 2024 and April 2025 monitoring events.
- If an SSI is determined, then within 90 days either:
 - Complete Alternative Source Demonstration (ASD) (if applicable), or
 - Establish an assessment monitoring program.

- Two semiannual groundwater sampling and analysis events (April and October 2025).

3.5.2 § 257.94(d) Alternative Detection Monitoring Frequency

The owner or operator must include the demonstration providing the basis for the alternative monitoring frequency and the certification by a qualified professional engineer in the annual groundwater monitoring and corrective action report required by § 257.90(e).

Not applicable. No alternative detection monitoring frequency has been proposed.

3.5.3 § 257.94(e)(2) Alternative Source Demonstration for Detection Monitoring

The owner or operator must also include the demonstration in the annual groundwater monitoring and corrective action report required by § 257.90(e), in addition to the certification by a qualified professional engineer.

Not applicable. No ASDs were completed in 2024.

3.5.4 § 257.95(c) Alternative Assessment Monitoring Frequency

The owner or operator must include the demonstration providing the basis for the alternative monitoring frequency and the certification by a qualified professional engineer in the annual groundwater monitoring and corrective action report required by § 257.90(e).

Not applicable. Assessment monitoring has not been initiated.

3.5.5 § 257.95(d)(3) Assessment Monitoring Results and Standards

Include the recorded concentrations required by paragraph (d)(1) of this section, identify the background concentrations established under § 257.94(b), and identify the groundwater protection standards established under paragraph (d)(2) of this section in the annual groundwater monitoring and corrective action report required by § 257.90(e).

Not applicable. Assessment monitoring has not been initiated.

3.5.6 § 257.95(g)(3)(ii) Alternative Source Demonstration for Assessment Monitoring

The owner or operator must also include the demonstration in the annual groundwater monitoring and corrective action report required by § 257.90(e), in addition to the certification by a qualified professional engineer.

Not applicable. Assessment monitoring has not been initiated.

3.5.7 § 257.96(a) Extension of Time for Corrective Measures Assessment

The assessment of corrective measures must be completed within 90 days, unless the owner or operator demonstrates the need for additional time to complete the assessment of corrective measure due to site-specific conditions or circumstances. The owner or operator must obtain a

certification from a qualified professional engineer attesting that the demonstration is accurate. The 90-day deadline to complete the assessment of corrective measures may be extended for longer than 60 days. The owner or operator must also include the demonstration in the annual groundwater monitoring and corrective action report required by § 257.90(e), in addition to the certification by a qualified professional engineer.

Not applicable. Corrective measures assessment has not been initiated.

3.6 §257.90(E)(6) OVERVIEW

A section at the beginning of the annual report that provides an overview of the current status of groundwater monitoring and corrective action programs for the CCR unit.

The specific requirements for the overview under §257.90(e)(6) are listed and the information is provided at the beginning of this report, before the Table of Contents.

4.0 REFERENCES

Coble, R.W., and Roberts, J.V., 1971, The Water Resources of Southeast Iowa: Iowa Geological Survey Water Atlas Number 4, 101 p.

Montgomery Watson, 1994, May 24, 1994, Hydrogeological Investigation Report and Hydrologic Monitoring System Plan, Ottumwa-Midland Commercial Landfill, Montgomery Watson, 1994.

U.S. Environmental Protection Agency (U.S. EPA), 2009, Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance, EPA 530-R-09-007, March 2009.

[This page left blank intentionally.]

Tables

- 1 Groundwater Monitoring Well Network
- 2 CCR Rule Groundwater Samples Summary
- 3 Groundwater Elevation – CCR Rule Monitoring Network
- 4 Horizontal Gradients and Flow Velocity
- 5 Groundwater Analytical Results Summary
- 6 Groundwater Field Data Summary

Table 1. Groundwater Monitoring Well Network
Ottumwa Midland Landfill / SCS Engineers Project #25224073.00

Monitoring Well	Location in Monitoring Network	Role in Monitoring Network
MW-102M	Upgradient	Background
MW-122M	Upgradient	Background
MW-301	Downgradient	Compliance
MW-302	Downgradient	Compliance
MW-303	Downgradient	Compliance

Last revision by:
Checked by:

NLB
LH

Date: 11/21/2024
Date: 12/4/2024

Table 2. CCR Rule Groundwater Samples Summary
Ottumwa Midland Landfill / SCS Engineers Project #25224073.00

Sample Dates	Downgradient Wells			Background Wells	
	MW-301	MW-302	MW-303	MW-102M	MW-122M
April 3-4, 2024	D	D	D	D	D
October 8, 2024	D	D	D	D	D
Total Samples	2	2	2	2	2

Abbreviations:

D = Required by Detection Monitoring Program

Last revision by:

NLB

Date: 11/21/2024

Checked by:

LH

Date: 12/4/2024

**Table 3. Groundwater Elevation - CCR Rule Monitoring Network
Ottumwa-Midland Landfill / SCS Engineers Project #25224073.00**

Ground Water Elevation in feet above mean sea level (amsl)					
Well Number	MW-301	MW-302	MW-303	MW-102M	MW-122M
Top of Casing Elevation (feet amsl)	817.88	761.77	762.40	798.03	792.70
Screen Length (ft)	5.0	5.0	5.0	5.0	5.0
Total Depth (ft from top of casing)	204.5	157.7	150.0	152.1	155.3
Top of Well Screen Elevation (ft)	618.38	609.07	617.40	652.65	642.94
Measurement Date					
May 4, 2016	686.46	685.80	686.04	728.73	729.27
June 22, 2016	686.40	685.79	687.72	718.74	725.67
August 9, 2016	686.19	685.48	687.77	715.65	725.16
October 25-26, 2016	683.70	684.94	685.56	716.94	724.61
January 17, 2017	685.57	685.68	685.60	717.91	724.02
April 19-20, 2017	685.72	684.73	685.51	717.80	724.04
June 20-21, 2017	685.88	684.76	685.59	714.83	723.51
July 17, 2017	NM	NM	684.92	NM	NM
August 21-22, 2017	684.96	683.89	684.70	713.23	722.02
November 7-8, 2017	684.50	683.38	684.26	713.53	720.52
April 16-18, 2018	684.85	683.87	684.68	717.38	723.25
October 15-16, 2018	684.58	683.52	684.33	717.05	723.36
April 16-17, 2019	686.38	685.35	686.13	717.97	723.43
June 6, 2019	NA	NA	686.05	NA	NA
August 7, 2019	NA	NA	NA	712.00	720.42
October 14-15, 2019	686.56	685.44	686.08	715.50	708.94
May 20-26, 2020	687.29	686.25	687.14	717.61	724.23
June 29, 2020	NA	NA	687.36	NA	NA
October 5-6, 2020	686.80	685.86	686.35	712.05	718.39
April 12 - 13, 2021	687.25	686.26	687.05	710.95	720.52
October 5, 2021	686.87	685.85	686.84	714.85	717.76
April 13-14, 2022	687.00	685.07	686.91	710.24	704.81
October 24-27, 2022	686.01	684.97	685.86	709.07	719.03
April 3-5, 2023	686.58	685.65	686.51	701.93	706.90
October 11, 2023	684.55	684.12	684.95	720.93	707.90
April 3-4, 2024	684.96	684.00	684.82	709.84	700.90
October 7-8, 2024	684.69	683.75	684.51	706.63	699.12
Bottom of Well Elevation (ft)	613.38	604.07	612.40	645.93	637.40

Notes:

NM = not measured

Created by: NDK

Date: 4/2/2019

Last rev. by: RM

Date: 10/18/2024

Checked by: NLB

Date: 10/25/2024

Table 4. Horizontal Gradients and Flow Velocity
Ottumwa Midland Landfill / SCS Engineers Project #25224073.00
January - December 2024

Flow Path - South					
Sampling Dates	h1 (ft)	h2 (ft)	Δl (ft)	Δh/Δl (ft/ft)	V (ft/d)
April 3-4, 2024	700.00	684.00	1263	0.013	0.2
October 7-8, 2024	696.00	683.75	1069	0.011	0.2

Well	(cm/sec)	(ft/d)	Assumed Porosity, n
MW-102M	N/A	N/A	
MW-122M	N/A	N/A	
MW-301	8.0E-04	2.3	
MW-302	3.6E-04	1.0	
MW-303	1.1E-02	30	
Geometric Mean	1.5E-03	4.1	0.25

Groundwater flow velocity equation: $V = [K * (\Delta h / \Delta l)] / n$

ft = feet

ft/d = feet per day

K = hydraulic conductivity

n = effective porosity

cm/sec = centimeters per second

V = groundwater flow velocity

h1, h2 = point interpreted groundwater elevation at locations 1 and 2

Δl = distance between location 1 and 2

Δh/Δl = hydraulic gradient

N/A = Not applicable, geometric mean K based on downgradient wells

Notes:

- See Figures 3 and 4 for velocity calculation flow path locations.

Last revision by:

NLB

Date: 12/10/2024

Checked by:

LH

Date: 12/10/2024

Table 5. Groundwater Analytical Results Summary
Ottumwa Midland Landfill / SCS Engineers Project #25224073.00

Parameter Name	Interwell UPL	Background Wells					Compliance Wells							
		MW-102M		MW-122M		MW-301			MW-302			MW-303		
		10/11/2023	4/4/2024	10/11/2023	4/4/2024	Intrawell UPL	10/11/2023	4/4/2024	Intrawell UPL	10/11/2023	4/3/2024	Intrawell UPL	10/11/2023	4/3/2024
Groundwater Elevation, ft amsl		720.93	709.84	707.90	700.90		684.55	684.96		684.12	684		684.95	684.82

Appendix III

Boron, µg/L	6,400	1,500	1,500	4,400	5,500		710	770		790	840		740	760
Calcium, mg/L	599	15	15	450	450		120	110		40	45		110	110
Chloride, mg/L		28	31	8.2	8.6	62.9	21	22	10.2	5.6	6.2	8.72	7.9	8.1
Fluoride, mg/L	5.70	5.00	4.5	0.57 J	<0.38		0.99 J	0.77 J		1.20	1.10		0.92 J	0.7 J
Field pH, Std. Units	8.52	7.73	7.61	--	7.04		6.74	6.66		7.24	7.15		6.81	6.73
Sulfate, mg/L	17,500	400	430	10,000	9,000		360	310		72	73		350	300
Total Dissolved Solids, mg/L	18,100	1,500	1,500	15,000	--		960	850		640	630		930	890

4.4

Blue shaded cell indicates the compliance well result exceeds the UPL and the LOQ.

Abbreviations:

UPL = Upper Prediction Limit

SSI = Statistically Significant Increase

LOQ = Limit of Quantitation

LOD = Limit of Detection

µg/L = micrograms per liter

mg/L = milligrams per liter

Notes:

- An individual result above the UPL does not constitute an SSI above background. See the accompanying report text for identification of statistically significant results.
- Interwell UPLs calculated based on results from background wells MW-102M and MW-122M for the period from May 2016 through April 2023. Interwell UPLs based on 1-of-2 retesting approach. The UPLs were updated in August 2023
- Intrawell UPL for chloride was calculated based on results from each monitoring well for the period from May 2016 through October 2022. Intrawell UPLs based on 1-of-2 retesting approach. The UPLs were updated in August 2023.

Created by:
Last revision by:
Checked by:

RM
EMS
JM

Date: 5/22/2023
Date: 9/20/2024
Date: 9/20/2024

Table 6. Groundwater Field Data Summary
Ottumwa Midland Landfill / SCS Engineers Project #25224073.00

Sample	Date	Groundwater Elevation (ft. amsl)	Temperature (Deg. C)	pH (Std. Units)	Dissolved Oxygen (mg/L)	Specific Conductivity ($\mu\text{mhos}/\text{cm}$)	Oxidation Reduction Potential (mV)	Turbidity (NTU)
MW-102M	10/11/2023	720.93	20.0	7.73	6.39	2,272	8.4	17.31
	4/4/2024	709.84	8.9	7.61	8.80	2,095.0	-53.5	20.43
MW-122M	10/11/2023*	707.90	--	--	--	--	--	--
	4/4/2024	700.90	7.3	7.04	9.58	13,249	-36.6	33.24
MW-301	10/11/2023	684.55	13.4	6.74	0.39	1,562	-97.3	6.55
	4/4/2024	684.96	12.2	6.66	0.44	1,332	-92.7	14.94
MW-302	10/11/2023	684.12	13.6	7.24	0.44	1,129	-100.9	68.96
	4/3/2024	684.00	12.0	7.15	0.60	1,009	-111	37.92
MW-303	10/11/2023	684.95	14.1	6.81	0.55	1,617	-85.7	64.61
	4/3/2024	684.82	12.3	6.73	0.46	1,458	-92.5	102.35

Abbreviations:

amsl = above mean sea level

$\mu\text{mhos}/\text{cm}$ = micromhos per centimeter

NA = not applicable

mg/L = milligrams per liter

mV = millivolts

Std. Units = Standard Units

Notes:


*In October 2023, field parameters were not collected for background well MW-122M because there was insufficient water available to sample for both the lab parameters and the field parameters.

Created by: AJR
 Last revision by: EMS
 Checked by: JM


Date: 8/15/2019
 Date: 9/19/2024
 Date: 9/20/2024

Figures


- 1 Site Location Map
- 2 Site Plan and Monitoring Well Locations
- 3 Potentiometric Surface Map, April 3-4, 2024
- 4 Potentiometric Surface Map, October 8, 2024





OTTUMWA NORTH QUADRANGLE
IOWA-WAPELLO CO.
7.5 MINUTE SERIES (TOPOGRAPHIC)
2018
SCALE: 1" = 2,000'



CLIENT	ALLIANT ENERGY OTTUMWA MIDLAND LANDFILL OTTUMWA, IOWA		SITE LOCATION MAP	
PROJECT NO.	DRAWN BY:	BSS	ENGINEER	FIGURE
DRAWN:	11/18/2019	CHECKED BY:	MDB	
REVISED:	01/13/2020	APPROVED BY:	TK 01/30/2020	
I:\25219073.00\Drawings\CCR 2019 Annual Report\Site Location Map.dwg, 1/30/2020 3:56:54 PM		SCS ENGINEERS 2830 DAIRY DRIVE MADISON, WI 53718-6751 PHONE: (608) 224-2830		1







NOTES:

1. 2015 AERIAL PHOTOGRAPH IS FROM THE IOWA GEOGRAPHIC MAP SERVER-IOWA STATE UNIVERSITY GEOGRAPHIC INFORMATION SYSTEMS SUPPORT & RESEARCH FACILITY.
2. PROPERTY LINE SOUTH OF 130TH STREET FROM SURVEY MAP PREPARED BY GARDEN & ASSOCIATES, OSKALOOSA, IOWA, DATED DECEMBER 20, 1988.
3. PROPERTY LINE NORTH OF 130TH STREET FROM PLAT OF SURVEY MAP PREPARED BY SCS ENGINEERS, MADISON, WISCONSIN, DATED FEBRUARY 20, 2013.
4. EXISTING LIMITS OF WASTE ARE APPROXIMATE.
5. THE BACKGROUND MONITORING WELLS FOR THE OTTUMWA MIDLAND LANDFILL ARE: MW-122M AND MW-102M.


400 0 400
SCALE: 1" = 400'

PROJECT NO.	25224073.00	DRAWN BY:	SB	SCS ENGINEERS 2830 DAIRY DRIVE MADISON, WI 53718-6751 PHONE: (608) 224-2830	CLIENT INTERSTATE POWER AND LIGHT CO. 15300 130th STREET OTTUMWA, IA 52501	SITE	OTTUMWA MIDLAND LANDFILL OTTUMWA, IOWA	CCR POTENTIOMETRIC GROUNDWATER SURFACE CONTOUR MAP APRIL 3-4, 2024	FIGURE
DRAWN:	06/05/2024	CHECKED BY:	NLB/BRK						3
REVISED:	1/24/2025	APPROVED BY:	BRK						



NOTES:

1. AERIAL PHOTOGRAPH IMPORTED FROM BING MAPS (2024) USING AUTOCAD GEOLOCATION MAP TOOL.
2. PROPERTY LINE SOUTH OF 130TH STREET FROM SURVEY MAP PREPARED BY GARDEN & ASSOCIATES, OSKALOOSA, IOWA, DATED DECEMBER 20, 1988.
3. PROPERTY LINE NORTH OF 130TH STREET FROM PLAT OF SURVEY MAP PREPARED BY SCS ENGINEERS, MADISON, WISCONSIN, DATED FEBRUARY 20, 2013.
4. EXISTING LIMITS OF WASTE ARE APPROXIMATE.
5. THE BACKGROUND MONITORING WELLS FOR THE OTTUMWA MIDLAND LANDFILL ARE: MW-122M AND MW-102M.




PROJECT NO.	25224073.00	DRAWN BY:	SB	DRAWN:	11/01/2024	CHECKED BY:	NLB/BRK	ENGINEER	SCS ENGINEERS	CLIENT	INTERSTATE POWER AND LIGHT CO. 15300 130th STREET OTTUMWA, IA 52501	SITE	OTTUMWA MIDLAND LANDFILL OTTUMWA, IOWA	CCR POTENTIOMETRIC SURFACE ELEVATION CONTOUR MAP OCTOBER 7-8, 2024	FIGURE
REVISED:	1/24/2025	APPROVED BY:	BRK											4	

I:\Client\Alliant\PROJECT SITES\Ottumwa\CAD Master References OML\Water Table Maps\2024 Annual CCR Report\24 Annual Rpt_Ottumwa CCR WTBL Map.dwg, 1/24/2025 1:50:46 PM

Appendix A

Regional Hydrogeologic Information



Legend

BEDROCK SURFACE ELEVATION

ELEVATION ABOVE MEAN SEA LEVEL IN FEET


- BELOW 300
- 300 TO 400
- 400 TO 500
- 500 TO 600
- 600 TO 700
- 700 TO 800
- 800 TO 900



0 5 10 20 Miles

MAP DATA DERIVED FROM IOWA GEOLOGICAL AND WATER SURVEY
IOWA BEDROCK SURFACE ELEVATION AS OBTAINED
FROM IOWA NATURAL RESOURCES
GEOGRAPHIC INFORMATION SYSTEMS LIBRARY


CLIENT	INTERSTATE POWER AND LIGHT CO. 15300 130TH STREET OTTUMWA, IA 52501	SITE	OTTUMWA MIDLAND LANDFILL OTTUMWA, IOWA	SE IOWA REGIONAL BEDROCK SURFACE ELEVATION
PROJECT NO.	25215053.03	DRAWN BY:	JB	FIGURE
DRAWN:	07/29/13	CHECKED BY:	MDB	
REVISED:	08/02/13	APPROVED BY:		4



Legend

MISSISSIPPAN AQUIFER ELEVATION

ELEVATION ABOVE MEAN SEA LEVEL IN FEET




0 5 10 20 Miles

MAP DATA DERIVED FROM IOWA GEOLOGICAL AND WATER SURVEY
MISSISSIPPAN AQUIFER SURFACE ELEVATION AS OBTAINED
FROM IOWA NATURAL RESOURCES
GEOGRAPHIC INFORMATION SYSTEMS LIBRARY

CLIENT	INTERSTATE POWER AND LIGHT CO. 15300 130TH STREET OTTUMWA, IA 52501	SITE	OTTUMWA MIDLAND LANDFILL OTTUMWA, IOWA	SE IOWA REGIONAL MISSISSIPPAN AQUIFER SURFACE ELEVATION	
PROJECT NO.	25215053.03	DRAWN BY:	JB	ENGINEER	SCS ENGINEERS
DRAWN:	07/29/13	CHECKED BY:	MDB	FIGURE	
REVISED:	08/02/13	APPROVED BY:			5

2830 DAIRY DRIVE MADISON, WI 53718-6751
PHONE: (608) 224-2830 FAX: (608) 224-2839



Legend

MISSISSIPPAN AQUIFER POTENTIOMETRIC SURFACE

ELEVATION ABOVE MEAN SEA LEVEL IN FEET

	MISSISSIPPAN NOT PRESENT
	550
	650
	750



0 5 10 20 Miles

MAP DATA DERIVED FROM IOWA GEOLOGICAL AND WATER SURVEY
MISSISSIPPAN AQUIFER POTENTIOMETRIC SURFACE ELEVATION AS OBTAINED
FROM IOWA NATURAL RESOURCES
GEOGRAPHIC INFORMATION SYSTEMS LIBRARY

CLIENT INTERSTATE POWER AND LIGHT CO. 15300 130TH STREET OTTUMWA, IA 52501	SITE OTTUMWA MIDLAND LANDFILL OTTUMWA, IOWA	SE IOWA REGIONAL MISSISSIPPAN AQUIFER POTENTIOMETRIC SURFACE ELEVATION
PROJECT NO. 25215053.03	DRAWN BY: JB	ENGINEER
DRAWN: 07/29/13	CHECKED BY: MDB	SCS ENGINEERS 2830 DAIRY DRIVE MADISON, WI 53718-6751 PHONE: (608) 224-2830 FAX: (608) 224-2839
REVISED: 08/02/13	APPROVED BY:	FIGURE 7

FIGURE 4-18

16

**POTENTIOMETRIC SURFACE
CONTOURS - MISSISSIPPAN
(03-02-94)**

OTTUMWA-MIDLAND
DEVELOPMENT CORPORATION

- NOTES:
1. CONTOUR INTERVAL = 10 FT.
 2. ALL ELEVATIONS ARE REFERENCED TO NGVD.

661.69 POTENTIOMETRIC SURFACE
ELEVATION ON 03-02-94
→ INFERRED DIRECTION OF
GROUNDWATER FLOW

PROPOSED LANDFILL
BOUNDARY

● SHALLOW MONITORING WELL

◎ MULTIPLE-CASED DEEP WELL

◆ DEEP MONITORING WELL

LEGEND:

0 - 200
SCALE IN FEET

FIRST DEVELOPMENT AREA

710

B-3
MW-2

700

B-2
MW-1

690

B-1
MW-1

POTENTIAL
DEVELOPMENT
AREA

680

B-1
MW-1

670

B-1
MW-1

B-10
MW-9 P.M.
646.42

B-8
MW-7 P.M.
661.69

B-12
MW-6 P.M.
650

MONTGOMERY WATSON



Appendix B

Boring Logs and Well Construction Documentation

SCS ENGINEERS
Civil & Environmental Engineering

SOIL BORING LOG INFORMATION

10-92

Page 1

Facility/Project Name Ottumwa Midland Landfill				License/Permit/Monitoring Number SCS # 25211509.03			Boring Number B-102				
Boring Drilled By (Firm name and name of crew chief) Boart Longyear Paul Dickinson				Drilling Started 08/20/2012		Drilling Completed 08/27/2012		Drilling Method HSA, Air Hammer, Core			
Facility Well No.		Unique Well No.	Common Well Name MW-102M	Static Water Level Feet		Surface Elevation 795.0 Feet		Borehole Diam. 10.5/6 Inches			
Boring Location State Plane N, E NE 1/4 of SE 1/4 of Section 34, T. 73 N., R. 14 W.				Lat. Long.		Local Grid Location (If applicable)					
County Wapello				Location Code		Civil Town/City/or Village Ottumwa					
Sample		Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties		RQD/ Comments
Number	Length Recovered								Standard Penetration	Moisture Content	
S1	8	05,07 09,12		SILTY CLAY, dark brown (10YR 3/3), stiff, massive, few roots (topsoil/loess).	CL-ML			1.25	M		begin drilling with 6-1/4" hollow stem augers and sampling with split-spoons and 140 lb hammer
S2	8	06,13 09,18		LEAN CLAY, mottled olive yellow (2.5Y 6/8) and light olive brown (2.5Y 5/3), hard, blocky (loess).	CL			>4.5	M		
S3	14	12,17 10,14	5	LEAN CLAY, very dark grayish brown (2.5Y 3/2) mottled dark red (2.5YR 3/6), with silt, very stiff, cobble at 6' (till).	CL			>4.5	M		
S4 ST	24				CL			4.0	M		pushed shelby tube from 7.5' to 9.5'
I hereby certify that the information on this form is true and correct to the best of my knowledge.											
Signature				Firm SCS ENGINEERS Tyler Munson							

Boring Number B-102

Page 2

Sample		Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/Comments
Number	Length Recovered								Standard Penetration	Moisture Content	P200	
S5	10	12,21 38, 30 1/2"		CLAY, grayish brown (10YR 5/2) with black (10YR 2/1) and dark reddish brown (2.5YR 2.5/4) mottles, hard. WEATHERED SHALE, gray (2.5Y 5/1), trace to few black (2.5Y 2.5/1) zones, massive, with silt (Pennsylvanian).	CL			4.25	M			
S6	12	22,17 61 1/4"		As above, except silty with pale red zones instead of black zones.	Shale			>4.5	M			
S7			15	SHALE, light brownish gray (10YR 6/2) and brownish yellow (10YR 6/6).								
S8			20	As above, except trace very dark grayish brown (10YR 3/2).								
S9			25	As above, except gray (10YR 6/1 to 10YR 5/1).	Shale							

Boring Number B-102

Page 3

Sample	Number	Length Recovered	Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/Comments
										Standard Penetration	Moisture Content	P200	
S10					As above.								
S11				35	SHALE with coal, black (10YR 2/1) to very dark brown (10YR 2/2).	Shale							
S12				40	COAL, black (10YR 2/1).	Shale							
S13				45	SHALE, light gray (10YR 7/1) to gray (10YR 6/1).	Coal							

Boring Number B-102

Page 4

Sample	Number	Length Recovered	Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/Comments
										Standard Penetration	Moisture Content	P200	
S14					SHALE, gray (10YR 5/1)								
S15				55									
S16				60	As above, except gray (10YR 6/1) to dark gray (10YR 4/1).	Shale							
S17				65	As above, except very dark gray (10YR 3/1).								

Boring Number B-102

Page 5

Sample		Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties		RQD/Comments
Number	Length Recovered								Standard Penetration	Moisture Content	
S18	Run 1 58/78			SHALE, gray (10YR 6/1).	Shale						at 74', begin NQ3 coring Run 1 (74' to 81.5') TCR=74% SCR=74% MCR=45% RQD=Poor lost circulation at 80' Run 2 (81.5' to 83.5') TCR=33% SCR=0% MCR=0% RQD=Very Poor Run 3 (83.5' to 91.5') TCR=59% SCR=53% MCR=8% RQD=Very Poor
				SILTY SHALE, gray (10YR 5/1), 1mm to 3mm-thick lamina, intensely fractured.	Shale						
				SANDSTONE, gray (10YR 5/1) with some light yellowish brown (10YR 6/4) lamina, strong, moderately fractured.	Sand-stone						
				SILTY SHALE, gray (10YR 5/1), 1mm to 3mm-thick lamina, moderately fractured, moderate to strong.	Shale						
				SANDSTONE, gray (10YR 5/1) with some light yellowish brown (10YR 6/4) lamina, strong, moderately fractured.	Sand-stone						
				SILTY SHALE, gray (10YR 5/1), 1mm to 3mm-thick lamina, moderately fractured, moderate to strong.	Shale						
				SANDSTONE, gray (10YR 5/1), strong, moderately fractured.	Sand-stone						
				VOID or FRACTURES in possible shale.	Shale						
				WEATHERED SHALE (clay).	Shale						
				SHALE, very dark gray (10YR 3/1), moderate strength, intensely fractured, few pyrite nodules up to 1mm by 3mm in size, some highly decomposed zones.	Shale						
Run 2	8/24				Shale						
Run 3	57/96				Shale						

Boring Number B-102

Page 6

Sample		Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/Comments
Number	Length Recovered								Standard Penetration	Moisture Content	P200	
Run 4	31/120			As above.	Shale							Run 4 (91.5' to 101.5') TCR=26% SCR=21% MCR=3% RQD=Very Poor
				SILTY SHALE, black (10YR 2/1), weak to moderate strength, intensely fractured.								
Run 5	88/120			SILTY SHALE, dark brown (7.5YR 3/2), very weak, 1mm to 3mm-thick lamina, highly decomposed.	Shale							Run 5 (101.5'-111.5') TCR=73% SCR=73% MCR=35% RQD=Poor
				SILTY SHALE, dark gray (7.5YR 4/1), moderate strength to strong, massive, few weak zones, no decomposition.								



Boring Number B-102

Page 7

	Sample	Number	Length Recovered	Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/Comments
											Standard Penetration	Moisture Content	P200	
Run 6	119/120					As above, except calcitic, pyrite nodules 5mm by 20mm in size at 112.8' and 117.3', slightly disintegrated and decomposed, slightly fractured, with some pyrite infilling.	Shale							Run 6 (111.5'-121.5') TCR=99% SCR=99% MCR=84% RQD=Good
						SHALE, greenish gray (5GY 6/1), weak to moderate strength, pyrite mineralization along laminated zones, few disintegrated zones.								
Run 7	44/120					As above, except dark gray (7.5YR 4/1), massive, aphanitic.	Shale							Run 7 (121.5'-131.5') TCR=37% SCR=35% MCR=27% RQD=Poor
						SHALE, reddish brown (2.5YR 4/3), highly decomposed.								
						SHALE, gray (7.5YR 5/1), weak to moderate strength, with white limestone								

Boring Number B-102

Page 8

	Sample	Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/Comments
									Number	Length Recovered	Standard Penetration	Moisture Content
Run 8	0/120			gravel, slightly to moderately disintegrated.	Shale							Run 8 (131.5'-141.5') TCR=0% SCR=0% MCR=0% RQD=Very Poor at 138', driller reports change in drilling
				WEATHERED SHALE, highly decomposed, possibly soft shale in clay. Possible limestone at 138'.								
Run 9	29/60			LIMESTONE, gray (10YR 5/1), strong (Mississippian).	Lime-stone							Run 9 (141.5'-146.5') TCR=48% SCR=38% MCR=15% RQD=Very Poor after coring, reamed hole with 6" air hammer to 153'
				Blind drill.								

Boring Number B-102

Page 9

Sample		Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/ Comments
Number	Length Recovered								Standard Penetration	Moisture Content	P200	
				Blind drill.								
				End of boring @ 153'. Set MW-102M with 5' PVC screen to 148'.								
			155									
			160									
			165									

SCS ENGINEERS
Civil & Environmental Engineering

SOIL BORING LOG INFORMATION

10-92

Page 1

Facility/Project Name Ottumwa Midland Landfill				SCS # 25211509.03			License/Permit/Monitoring Number			Boring Number B-122			
Boring Drilled By (Firm name and name of crew chief) Boart Longyear				Paul Dickinson			Drilling Started 12/06/2012		Drilling Completed 12/09/2012		Drilling Method HSA, Air Hammer, Core		
Facility Well No.		Unique Well No.		Common Well Name MW-122M		Static Water Level Feet		Surface Elevation 790.6 Feet		Borehole Diam. 10.5/6 Inches			
Boring Location State Plane NW 1/4 of SE 1/4 of Section 34, T. 73 N., R. 14 W.				N, E		Lat. Long.		Local Grid Location (If applicable)					
County Wapello				Location Code			Civil Town/City/or Village Ottumwa						
Sample		Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit			USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties		RQD/ Comments
Number	Length Recovered										Standard Penetration	Moisture Content	
S1	9	06-10 14-20		SILT, dark yellowish brown (10YR 4/4), massive, few roots (topsoil/loess).			ML			1.5	M		
S2	24	06-17 20-26		LEAN CLAY, olive yellow (2.5Y 6/6) mottled gray (2.5Y 6/1) and reddish brown (5YR 4/4), trace fine to coarse sand (till).			CL			2.75			
S3 ST	20		5	CLAY, gray (5Y 5/1), few olive yellow (2.5Y 6/6) and dark reddish brown (5YR 3/4) layers, hard, 1mm to 5mm-thick lamina (weathered shale).			CL			2.0	M		
S4	24	07-17 27-34		As above, except less gray and with black layers/lamina.						4.5			
				CLAY, black (2.5Y 2.5/1), 1mm to 2mm-thick lamina (weathered shale)			CL			3.5	M		pushed shelly tube from 5' to 7'
at 10', auger refusal, and begin drilling with 6" air hammer and sampling drill cuttings													
I hereby certify that the information on this form is true and correct to the best of my knowledge.													
Signature				Firm SCS ENGINEERS Meghan Blodgett									

Boring Number B-122

Page 2

Sample	Number	Length Recovered	Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/Comments
										Standard Penetration	Moisture Content	P200	
S5					WEATHERED SHALE, black (2.5Y 2.5/1), lamina up to 5mm-thick.								
S6				15	WEATHERED SHALE, dark gray (2.5Y 4/1) to black (2.5Y 2.5/1).								
S7				20	SHALE and WEATHERED SHALE, dark gray (2.5Y 4/1).	Shale							
S8				25	SHALE and WEATHERED SHALE, dark gray (2.5Y 4/1) to black (2.5Y 2.5/1).								

Boring Number B-122

Page 3

Sample	Number	Length Recovered	Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/Comments
										Standard Penetration	Moisture Content	P200	
S9					As above.								
S10				35	SHALE, dark gray (2.5Y 4/1).								
S11				40	As above.								
S12				45	As above.								

Boring Number B-122

Page 4

Sample	Number	Length Recovered	Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/Comments
										Standard Penetration	Moisture Content	P200	
S13					SHALE, dark gray (2.5Y 4/1) to black (2.5Y 2.5/1).								
S14				55	As above.								
S15				60	As above, except 6" coal seam at approximately 64.5'.	Shale							
S16				65	SHALE, light gray (2.5Y 7/1) to very dark gray (2.5y 3/1).								

Boring Number B-122

Page 5

Sample		Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			P200	RQD/ Comments
Number	Length Recovered								Standard Penetration	Moisture Content			
Run 1	68/78			SHALE, very dark gray (2.5Y 3/1) to gray (2.5Y 5/1), weak to moderate strength, 1mm to 5mm-thick lamina, moderately decomposed (clay along fractures), intensely fractured, some sand at 70' to 71'.								begin NQ3 coring at 70'	
Run 2	54/60		75	As above, except few sandy intervals up to 2" in length at 77.5' to 78.5'.								Run 1 (70' to 76.5') TCR=87% SCR=82% MCR=46% RQD=Poor	
Run 3	40/60		80	SHALE, very dark gray (2.5Y 3/1) with little gray (2.5Y 5/1 & 6/1), 1mm to 5mm-thick lamina, moderately weathered (clay along fractures), trace pyrite nodules throughout.	Shale							Run 2 (76.5' to 81.5') TCR=90% SCR=75% MCR=8% RQD=Very Poor	
Run 4	36/60		85	As above.								Run 3 (81.5' to 86.5') TCR=67% SCR=55% MCR=0% RQD= Very Poor	
												Run 4 (86.5' to 91.5') TCR=60% SCR=53% MCR=40% RQD=Poor	

Boring Number B-122

Page 6

Sample		Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/ Comments
Number	Length Recovered								Standard Penetration	Moisture Content	P200	
Run 4 (cont)				As above.	Shale							four 6" to 8" bit drops one foot apart indicated possible voids from 93' to 97'
				SILTSTONE, very dark gray (2.5Y 3/1), moderately strong, massive, trace fractures infilled with calcite.	Silt-stone							
Run 5	59/120		95	SHALE, very dark gray (2.5Y 3/1), very weak to weak, 1mm to 5mm-thick lamina, moderately to highly decomposed (highly decomposed in top 2' of recovered shale), trace pyrite throughout, possible voids from approximately 93' to 97', bedding planes are horizontal where present.								Run 5 (91.5'-101.5') TCR=49% SCR=29% MCR=7% RQD=Very Poor
Run 6	48/60		100	SHALE, light to dark gray (2.5Y 7/1 to 4/1), weak, 1mm to 3mm-thick lamina, massive from 104' to 105', trace coal on fracture planes, trace pyrite throughout.								Run 6 (101.5'-106.5') TCR=80% SCR=68% MCR=48% RQD=Poor
Run 7	6/60		105	SHALE, gray (2.5Y 5/1), weak to moderate strength, 1mm to 3mm-thick lamina, silty.								Run 7 (106.5'-111.5') TCR=10% SCR=10% MCR=7% RQD=Very Poor




Boring Number B-122

Page 7

Sample		Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/Comments
Number	Length Recovered								Standard Penetration	Moisture Content	P200	
Run 7 (cont)				As above.								
Run 8	30/30			SHALE, dark gray (2.5Y 4/1) with gray (2.5Y 5/1), weak to moderate strength, bedding variable, 1mm-thick lamina to 2cm-thick beds, moderately decomposed (clay in fractures), few 1cm to 3cm-thick sandy zones, trace pyrite nodules throughout.								Run 8 (111.5'-114') TCR=100% SCR=80% MCR=60% RQD=Fair
Run 9	65/90		115	Interbedded SHALE, SILTSTONE, and SANDSTONE, gray (10YR 6/1) to very dark gray (10YR 3/1), weak strength to strong, sandstone/siltstone/shale intervals are 1" to 10"-thick, bedding ranges from 1mm-thick lamina in shale to massive in siltstones, some slump/flame structures in sand, intensely fractured, fresh to moderately decomposed (clay in fractures), trace pyrite throughout.	Shale							Run 9 (114'-121.5') TCR=72% SCR=70% MCR=9% RQD=Very Poor
Run 10	12/12		120									
			125	SHALY SILTSTONE and SANDSTONE, black (2.5Y 2.5/1) with bands of light gray (2.5Y 7/1), moderate strength, 1mm to 10mm-thick lamina, trace pyrite throughout, moderately to intensely fractured.	Silt-stone							Run 10 (121.5'-122.5') TCR=100% SCR=92% MCR=0% RQD=Very Poor
Run 11	108/ 108			SHALE, black (2.5Y 2.5/1), weak, 1mm to 5mm-thick lamina, some silt and sand, moderately decomposed, moderately fractured, trace pyrite throughout.	Shale							Run 11 (122.5'-131.5') TCR=100% SCR=95% MCR=60% RQD=Fair


Boring Number B-122

Page 8

Sample		Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties			RQD/Comments
Number	Length Recovered								Standard Penetration	Moisture Content	P200	
Run 11 (cont)				As above.	Shale							Run 12 (131.5'-141.5') TCR=92% SCR=86% MCR=63% RQD=Fair
				SHALE, dark greenish gray (5GY 4/1), weak to moderate strength, 1mm to 5mm-thick lamina, moderately to highly decomposed.	Shale							
Run 12	110/ 120		135		Shale							
			140	LIMESTONE CONGLOMERATE, reddish brown (5YR 5/3) with gray shale between clasts, weak, massive.	Lime-stone							
			145	SHALY LIMESTONE, greenish gray (5GY 5/1), weak, massive, 2" of light gray clay at interface with above conglomerate.	Lime-stone							
Run 13	114/ 120		145	SHALY LIMESTONE, reddish brown (5YR 4/3), few greenish gray zones, moderate strength, few clasts of hard competent limestone up to 1.5" in diameter, moderately decomposed.	Lime-stone							Run 13 (141.5'-151.5') TCR=95% SCR=95% MCR=73% RQD=Fair

Boring Number B-122

Page 9

Sample		Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	Max. PID/FID	Soil Properties		RQD/ Comments
Number	Length Recovered								Standard Penetration	Moisture Content	
Run 13 (cont)				SHALY LIMESTONE, yellowish gray (5GY 5/1), weak, massive, fresh to slightly decomposed.	Lime-stone						
Run 14	30/30			As above. End of Boring @ 154'. Set MW-122M with 5' PVC screen to 152'.							Run 14 (151.5'-154') TCR=100% SCR=90% MCR=90% RQD=Good

SCS ENGINEERS

Environmental Consultants and Contractors

SOIL BORING LOG INFORMATION

Route To: Watershed/Wastewater Waste Management
 Remediation/Redevelopment Other

Page 1 of 9

Facility/Project Name IPL-Ottumwa Midland Landfill SCS#: 25215135.50			License/Permit/Monitoring Number 90-SDP-8-92P			Boring Number MW-301					
Boring Drilled By: Name of crew chief (first, last) and Firm Todd Schmalfeld Cascade Drilling			Date Drilling Started 11/16/2015	Date Drilling Completed 11/19/2015	Drilling Method 4.25'HSA /6"air rot/core						
Unique Well No. N/A	DNR Well ID No. N/A	Common Well Name MW-301	Final Static Water Level Feet	Surface Elevation 815.5 Feet	Borehole Diameter 8.5"/6" in						
Local Grid Origin <input type="checkbox"/> (estimated: <input type="checkbox"/>) or Boring Location <input checked="" type="checkbox"/>			Local Grid Location								
State Plane 1,930,292 N, 394,330 E S/C/N			Lat ° ' "	<input type="checkbox"/> N <input type="checkbox"/> E							
NE 1/4 of SE 1/4 of Section 34, T 73 N, R 14 W			Long ° ' "	Feet <input type="checkbox"/> S <input type="checkbox"/> W							
Facility ID		County Wapello	Civil Town/City/ or Village Ottumwa								
Sample Number and Type Length Att. & Recovered (in)	Blow Counts Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties				RQD/ Comments
							Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	
S1	16	FAT CLAY, very dark grayish brown, (2.5Y 3/2).	CH				M				
S2	16	FAT CLAY, black (2.5Y 2.5/1).					M				
S3	22	Same as above, except very dark grayish brown (2.5Y 3/2).					M				
S4	5	Same as above, except black (2.5Y 2.5/1).	CH				M				
S5	20						M				
S6	21	Same as above, except very dark grayish brown (2.5Y 3/2).					M				

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature  Firm **SCS Engineers**
 2830 Dairy Drive Madison, WI 53711 Tel: (608) 224-2830
 Fax:

Boring Number

MW-301

Page 2 of 9

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties				RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	
S7	23	3 4 8 9	16 17 18	LEAN CLAY WITH SAND, gray (2.5Y 5/1), fine grained sand.	CL				M				
S8	20	4 9 9 11	19 20	FAT CLAY, primary color-black (2.5Y 2.5/1), secondary color-yellowish brown (10YR 5/6).	CH				M				
S9	24	8 27 22 24	21 22	SILT, ash, black (2.5Y 2.5/1).	ML				M				
S10	16	18 28 34 44	23 24	SHALE, gray (10YR 5/1) matrix, moderate strength, massive.					M				Saturation @ 23.5 ft bgs
S11			25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40	Same as above, except light yellowish brown (10YR 6/4).					S				Air Rotary
S12				Same as above, except light yellowish brown (10YR 6/4).					S				
S13				Same as above, except gray (10YR 5/1).					S				

Boring Number

MW-301

Page 3 of 9

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
S14			41	SHALE, gray (10YR 5/1) matrix, moderate strength, massive. <i>(continued)</i>						S				
S15			42							S				
S16			43							S				
S17			44	Same as above, except yellowish brown (10YR 6/4).						S				
S18			45							S				
			46											
			47											
			48											
			49											
			50											
			51											
			52											
			53											
			54											
			55											
			56											
			57											
			58	Same as above, except dark gray (10YR 4/1).										
			59											
			60											
			61											
			62											
			63	Same as above, except black (10YR 2/1).						S				
			64											
			65											

Boring Number

MW-301

Page 4 of 9

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
S19				SHALE, gray (10YR 5/1) matrix, moderate strength, massive. <i>(continued)</i>						S				
S20										S				
S21				Same as above, except light gray (2.5Y 7/1).						S				
S22				Same as above, except very dark gray (5Y 3/1).						S				
S23										S				

Boring Number MW-301

Page 5 of 9

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
S24			91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110 111 112 113 114 115	SHALE, gray (10YR 5/1) matrix, moderate strength, massive. <i>(continued)</i> Same as above, except black (10YR 2/1). VOID.						S				
S25									S					
S26									S					
S27				SHALE, black (10YR 2/1).					S					Void @ 105 ft bgs, sulfur smell.

Boring Number

MW-301

Page 6 of 9

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties				RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	
S28			116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135 136 137 138 139 140	SHALE, black (10YR 2/1). (continued)						S			
S29										S			
S30										S			
S31										S			
S32										S			

Boring Number

MW-301

Page 7 of 9

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
S33			141	SHALE, black (10YR 2/1). (continued)						S				
S34			142							S				
S35			143							S				
S36			144							S				
			145											
			146											
			147											
			148											
			149											
			150	Same as above, except drak grayish brown (10YR 3/2).										
			151											
			152											
			153											
			154											
			155	WEATHERED SHALE AND LIMESTONE, dark grayish brown (10YR 3/2), gray limestone (10YR 6/1).										
			156											
			157											
			158											
			159											
			160	NO RECOVERY.										
			161											
			162											
			163											
			164	WEATHERED SHALE, gray (2.5Y 6/1),soft shale in clay.										
			165											

Boring Number

MW-301

Page 8 of 9

Number and Type	Length Att. & Recovered (in)	Sample	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties				RQD/Comments
								Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	
R1	62/72		WEATHERED SHALE, gray (2.5Y 6/1), soft shale in clay. (continued)									
			166									
			167									
			168									
			LIMESTONE, gray (10YR 5/1), strong, massive.									
			169									
			170									
R2	22/24		171									
			172									
			173									
R3	32/36		SHALE, greenish gray (5G 5/1), with pyrite, weak.									
			174									
			175									
			176									
			LIMESTONE, gray (10YR 5/1), interbedded with shale laminations, strong.									
			177									
			178									
			179									
R4	18/120		180									
			181									
			182									
			183									
			184									
			SHALE, greenish gray (5G 5/1), weak.									
			185									
			LIMESTONE, gray (10YR 5/1), strong.									
			186									
			187									
			SHALE, grayish green (5G 4/2), weak.									
			188									
			LIMESTONE, gray (10YR 5/1), strong.									
			189									
			190									


Boring Number MW-301

Page 9 of 9

Sample	Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/ Comments
										Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
R5	16/120			185'	LIMESTONE, gray (10YR 5/1), strong. (continued)										Run 5 185'-195' bgs TCR=97% SCR=93% MCR=84%
				191	SHALE, greenish gray (5G 5/1), clayey.										
				192											
				193											
				194	SANDSTONE, greenish gray (5G 6/1), strong, well cemented.										
				195											
				196											
				197	Very weak.										
R6	33/60			198											Run 6 195'-200' bgs TCR=55% SCR=47% MCR=13%
				199											
				200											
				201											
				202	End of Boring at 202 feet bgs. Boring reamed to 202' bgs prior to installation of MW-301.										

Route To: Watershed/Wastewater Waste Management
 Remediation/Redevelopment Other

Page 1 of 7

Facility/Project Name IPL-Ottumwa Midland Landfill SCS#: 25215135.50			License/Permit/Monitoring Number 90-SDP-8-92P		Boring Number MW-302									
Boring Drilled By: Name of crew chief (first, last) and Firm Todd Schmalfeld Cascade Drilling			Date Drilling Started 12/1/2015	Date Drilling Completed 12/3/2015	Drilling Method 4.25'HSA /6"air rot/core									
Unique Well No. N/A	DNR Well ID No. N/A	Common Well Name MW-302	Final Static Water Level Feet	Surface Elevation 759.5 Feet	Borehole Diameter 8.5"/6" in									
Local Grid Origin <input type="checkbox"/> (estimated: <input checked="checked" type="checkbox"/>) or Boring Location <input checked="checked" type="checkbox"/>			Local Grid Location											
State Plane 1,929,605 N, 394,359 E S/C/N NW 1/4 of SE 1/4 of Section 34, T 73 N, R 14 W			Lat ° ' "	Long ° ' "	□ N □ S □ E □ W									
Facility ID		County Wapello	Civil Town/City/ or Village Ottumwa											
Number and Type Length Att. & Recovered (in)	Sample	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit		Soil Properties				RQD/ Comments				
				U S C S	Graphic Log	Well Diagram	Vane Shear	Standard Penetration	Moisture Content		Liquid Limit	Plasticity Index	P 200	
S1	20	2 3 5 8	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15	TOPSOIL FAT CLAY, dark gray (10YR 4/1), secondary color- Dark yellowish brown (10YR 4/4), organics, fill. Weathered Shale	TOPSOIL CH				M	M	M	M	S	Saturation @12.5 ft bgs.

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature



Firm

SCS Engineers
2830 Dairy Drive Madison, WI 53711

Tel: (608) 224-2830

Fax:

Boring Number MW-302

Page 2 of 7

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	Soil Properties					RQD/ Comments	
					U S C S	Graphic Log	Well Diagram	Vane Shear	Standard Penetration	Moisture Content	
S7			16	SHALE, dark gray (10YR 4/1), moderate strength, massive. <i>(continued)</i>						S	
			17	same as above, except black (2.5Y 2.5/1), clayey.						S	
S8			18							S	
			19							S	
			20							S	
			21							S	
S9			22							S	
			23							S	
			24							S	
			25							S	
			26							S	
S10			27	same as above, except dark gray (2.5Y 4/1), clayey.						S	
			28							S	
			29							S	
			30							S	
			31							S	
			32							S	
S11			33							S	
			34							S	
			35							S	
			36							S	
			37							S	
			38							S	
			39							S	
			40							S	

Boring Number MW-302

Page 3 of 7

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	Soil Properties					RQD/ Comments	
					U S C S	Graphic Log	Well Diagram	Vane Shear	Standard Penetration	Moisture Content	
S12			41	SHALE, dark gray (10YR 4/1), moderate strength, massive. <i>(continued)</i> same as above, except black (2.5Y 2.5/1).						S	
S13			42							S	
S14			43							S	
S15			44							S	
S16			45							S	
			46								
			47								
			48								
			49								
			50								
			51								
			52								
			53								
			54								
			55								
			56								
			57								
			58								
			59								
			60								
			61								
			62								
			63								
			64								
			65								

a lot of
water @ 62
ft bgs.

Boring Number MW-302

Page 4 of 7

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	Soil Properties				RQD/ Comments	
					U S C S	Graphic Log	Well Diagram	Vane Shear	Standard Penetration	
S17			66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90	SHALE, dark gray (10YR 4/1), moderate strength, massive. <i>(continued)</i> Shale, black (2.5Y2.5/1), not as clayey as above.						
S18										
S19				same as above, except dark gray (2.5Y 4/1).						
S20										
S21										

Boring Number MW-302

Page 5 of 7

Sample	Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/Comments
										Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
S22				91	SHALE, dark gray (10YR 4/1), moderate strength, massive. <i>(continued)</i>										
				92	same as above, except gray (2.5Y 5/1).										
R1	24/36			96	WEATHERED SHALE, greenish gray (5G 5/1), clayey.										Run 1 96'-99' bgs TCR=66% SCR=66% MCR=47%
				97											
				98	SHALE, greenish gray (5G 5/1), weak, massive.										
				99											
				100											
				101	SHALE, very dark brown (2.5YR 2.5/3), very weak.										
				102											
				103											
R2	02/120			104	SHALE, clayey, greenish gray (5G 5/1), very weak.										Run 2 99'-109' bgs TCR=85% SCR=77% MCR=52%
				105											
				106											
				107											
				108											
				109											
				110											
				111											
				112											
R3	68/72			113											Run 3 109'-117' bgs TCR=95% SCR=90%
				114											
				115											

Boring Number MW-302

Page 6 of 7

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
R4	24/24		116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135 136 137 138 139 140	SHALE, clayey, greenish gray (5G 5/1), very weak. <i>(continued)</i> not as clayey, weak.										MCR=75%
R5	16/120			LIMESTONE, gray (10YR 6/1), interbedded with shale lamination, strong.										Run 5 119'-129' bgs TCR=97% SCR=97% MCR=93%
R6	20/120			SHALE, greenish gray (5G 5/1), weak.										Run 6 129'-139' bgs TCR=100% SCR=100% MCR=95%

Boring Number MW-302

Page 7 of 7

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties				RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	
R7	03/120		141	LIMESTONE, gray (10YR 6/1), strong.									
			142	SHALE, greenish gray (5G 5/1), weak.									
			143										
			144										
			145	SANDSTONE, greenish gray (5G 5/1), very weak, fine grained.									
			146										
			147										
			148										
			149										
			150										
			151										
R8	45/60		152										
			153										
			154										
			155										
			156	End of Boring at 156.5 ft bgs. Boring reamed with air rotary prior to installation of MW-302.									

SCS ENGINEERS

Environmental Consultants and Contractors

SOIL BORING LOG INFORMATION

Route To: Watershed/Wastewater Waste Management
 Remediation/Redevelopment Other

Page 1 of 7

Facility/Project Name IPL-Ottumwa Midland Landfill SCS#: 25215135.50			License/Permit/Monitoring Number 90-SDP-8-92P		Boring Number MW-303									
Boring Drilled By: Name of crew chief (first, last) and Firm Don Carlson Team Services			Date Drilling Started 4/11/2016	Date Drilling Completed 4/26/2016	Drilling Method 4.25'HSA /6"air rot/core									
Unique Well No. N/A	DNR Well ID No. N/A	Common Well Name MW-303	Final Static Water Level Feet	Surface Elevation 759.9 Feet	Borehole Diameter 8.5"/6" in									
Local Grid Origin <input type="checkbox"/> (estimated: <input checked="checked" type="checkbox"/>) or Boring Location <input checked="checked" type="checkbox"/>			Local Grid Location											
State Plane 1,929,977 N, 394,335 E S/C/N NW 1/4 of SE 1/4 of Section 34, T 73 N, R 14 W			Lat ° ' " <input type="checkbox"/>	Long ° ' " <input type="checkbox"/>	□ N □ S □ E □ W									
Facility ID		County Wapello	Civil Town/City/ or Village Ottumwa											
Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit		U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties				RQD/ Comments
				Standard Penetration	Moisture Content					Liquid Limit	Plasticity Index	P 200		
S1	11	2 4 6	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15	TOPSOIL. TOPSOIL FAT CLAY, light gray (10YR 7/1). CH	TOPSOIL FAT CLAY, light gray (10YR 7/1). CH					M				
S2	16	2 3 16	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15	SHALE, Gray (10YR 6/1), very weak, massive, clayey.	SHALE, Gray (10YR 6/1), very weak, massive, clayey.					M				
S3	0	50/5	1 2 3 4 5 6 7 8 9 10 11 12 13 14 15	Same as above except, dark gray (10YR 4/1).	Same as above except, dark gray (10YR 4/1).									No return-refusal.
S4														
S5														

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature



Firm

SCS Engineers
2830 Dairy Drive Madison, WI 53711

Tel: (608) 224-2830

Fax:

Boring Number MW-303

Page 2 of 7

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties				RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	
S6			16	SHALE, Gray (10YR 6/1), very weak, massive, clayey. <i>(continued)</i>									
			17	Same as above except, black (10YR 3/1).									
			18										
			19										
			20	Same as above except, light gray (10YR 1/1).									
S7			21										
			22										
			23										
			24										
			25	Same as above except, gray (10YR 6/1).									
S8			26										
			27										
			28										
			29										
			30	Same as above except, light gray (10YR 7/1).									
S9			31										
			32										
			33										
			34										
			35	Same as above except, gray (10YR 6/1).									
S10			36										
			37										
			38										
			39										
			40										

Boring Number

MW-303

Page 3 of 7

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
S11				SHALE, Gray (10YR 6/1), very weak, massive, clayey. <i>(continued)</i>										38'-45' no return. need to add water.
	41													
	42													
	43													
	44													
	45			Same as above except, dark gray (10YR 4/1), clayey.										
	46													
	47													
S12														
	48													
	49													
	50													
	51													
S13														
	52													
	53													
	54													
	55			Same as above except, black (10YR 2/1), less clayey.										
	56													
	57													
S14														Borehole producing a lot of water.
	58													
	59													
	60													
	61													
	62													
	63													
	64													
S15														
	65													

Boring Number MW-303

Page 4 of 7

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
S16			66	SHALE, Gray (10YR 6/1), very weak, massive, clayey. <i>(continued)</i>										
			67	Same as above except, black (10YR 2/1) and gray (10YR 6/1), laminated.										
S17			68											
			69											
			70											
S18			71											
			72											
			73											
			74											
			75											
S19			76											
			77											
			78											
			79											
			80	Same as above except, gray (10YR 6/1), clayey.										
			81											
			82											
			83											
			84											
			85	Same as above except, gray (10YR 6/1), black (10YR 2/1), Reddish brown (5YR 4/3).										Sulfur smell.
S20			86											
			87											
			88											
			89											
			90											

Boring Number MW-303

Page 5 of 7

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
S21			91	SHALE, Gray (10YR 6/1), very weak, massive, clayey. <i>(continued)</i>										
			92	Same as above except, black (10YR 2/1), reddish brown (5YR 4/3), dark greenish gray (5GY 4/1).										
S22			93											
			94											
			95											
			96											
			97											
S23			98											
			99											
			100											
			101	Same as above with laminations.										
S24			102											
			103											
			104											
			105	SHALE, black (10YR 2/1), reddish brown (5YR 4/3), dark greenish gray (5G 4/1), clayey.										
S25			106											
			107											
			108											
			109											
			110	Same as above except, black (10YR 3/1), pale brown (10YR 6/3), reddish brown (5YR 4/3), Dark Greenish Gray (5GY 4/1), clayey.										
			111											
			112											
			113											
			114	Same as above except, limestone fragments are encountered.										
			115											

Boring Number MW-303

Page 6 of 7

Sample	Number and Type	Length Att. & Recovered (in)	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/Comments	
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200		
S26			116	SHALE, Gray (10YR 6/1), very weak, massive, clayey. <i>(continued)</i>											
			117	LIMESTONE, dark greenish gray (5G 4/1), clayey, clay is pale brown (10YR 6/3) and reddish brown (5YR 4/3), shale fragments, shale is black (10YR 3/1).											
R1	8/12		118												
R2	12/12		119												
R3	36/36		120	SHALE, greensih gray (5GY 6/1), strong, massive, clayey.											Run 1 120'-121'. Run 1 TCR=66% SCR=66% MCR=42% Run 2 121'-122'. Run 2 TCR=100% SCR=100% MCR=77%. Run 3 122'-125'. Run 3 TCR=100% SCR=100% MCR=92%.
			121												
			122	LIMESTONE, gray (10YR 6/1), interbedded with shale laminations, strong, shells.											
			123												
			124	SHALE, greenish gray (5GY 6/1), shells, very weak, clayey, massive.											
			125												
			126	LIMESTONE, gray (10YR 5/1), strong.											
			127												
			128	SHALE, greenish gray (5GY 6/1), weak.											
			129	LIMESTONE, gray (10YR 5/1), strong, interbedded with shale laminations.											
R4	00/120		130												
			131												
			132												
			133												
			134												
			135												
			136	SHALE, dark greenish gray (5GY 4/1), clayey, weak, interbedded with limestone-gray (10YR 5/1).											
			137												
R5	59/60		138												
			139												
			140												

Boring Number MW-303

Page 7 of 7

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	Vane Shear	Soil Properties					RQD/ Comments
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
R6	87/120		141	SANDSTONE, greenish gray (5GY 6/1), very weak, fine grained.										
			142											
			143											
			144											
			145											
			146											
			147											
			148											
			149	SHALE, dark greenish gray (5GY 4/1), clayey, weak, interbedded with limestone-gray (10YR 5/1).										
			150	End of boring at 150.5 ft bgs. Boring reamed with 6" rotary before installation of MW-303.										
														Run 6 140.5'-150.5'. Run 6 TCR=73% SCR=69% MCR=59%.



IOWA DEPARTMENT OF NATURAL RESOURCES
MONITORING WELL/PIEZOMETER CONSTRUCTION DOCUMENTATION FORM

Disposal Site Name: Ottumwa Midland Landfill _____ Permit No.: 38223

Well or Piezometer No: MW-102M

Dates Started: August 20, 2012

Date Completed: August 27, 2012

A. SURVEYED LOCATIONS AND ELEVATIONS		B. SOIL BORING INFORMATION
Locations (± 0.5 ft):		
Specify corner of site:	NE	
Distance & direction along boundary:	29 S	
Distance & direction from boundary to wall:	7 W	
Elevations (± 0.01 ft MSL):		
Ground Surface:	795.50	
Top of protective casing:	798.23	
Top of well casing:	798.03	
Benchmark elevation:	820.39	
Benchmark description:	Brass cap in concrete, 408 ft N of MW-20	

C. MONITORING WELL INSTALLATION		
Casing material:	Flush threaded PVC schedule 80	
Length of casing:	152.1	
Outside casing diameter:	2.4 in	
Inside casing diameter:	1.9 in	
Casing joint type:	Flush Threaded	
Casing/screen joint type:	Flush Threaded	
Screen material:	Sch 80 PVC	
Screen opening size:	0.01 in	
Screen length:	5 ft	
Depth of well:	147.9 ft	
Filter Pack:		
Material:	Red Flint Filter Sand	
Grain size:	#40	
Volume:	1.5 ft^3	
Seal (minimum 3 ft length above filter pack):		
Material:	3/8 inch bentonite chips	
Placement method:	Gravity	
Volume:	0.7 ft^3	
Backfill (if different from seal):		
Material:	Bentonite Slurry	
Placement method:	Tremie pumped	
Volume:	40.1 ft^3	
Surface seal design:		
Material of protective casing:	Steel	
Material of grout between protective casing and well casing:	bentonite & concrete	
Protective cap:		
Material:	Aluminum	
Vented:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Locking:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Well Cap:		
Material:	plastic with rubber gasket	
Vented:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No

D. GROUNDWATER MEASUREMENT (± 0.01 ft below top of inner well casing)		
Water level:	100.81	Stabilization Time: 1 week
Well development method:	Surged & bailed with bailer and pump	
Average depth of frostline:	3 feet	


Attachments: Driller's log, Pipe schedules and grouting schedules. 8 1/2x11 inch map showing locations of all monitoring wells and piezometers.

Please mail completed form to: Iowa Department of Natural Resources, Land Quality Bureau, 502 E 9th St, Des Moines IA 50319-0034.

Questions? Call or Email: Nina Koger, Environmental Engineer Sr., 515-281-8986, Nina.Koger@dnr.iowa.gov

ELEVATIONS: ± 0.01 ft MSL
DEPTHS: ± 0.1 ft FROM GROUND SURFACE

SPACE TO ATTACH ENTIRE SOIL BORING LOG
(SHOW SCREENED INTERVAL AND FILTER PACK INTERVAL.)





**IOWA DEPARTMENT OF NATURAL RESOURCES
MONITORING WELL/PIEZOMETER CONSTRUCTION DOCUMENTATION FORM**

Disposal Site Name: Ottumwa Midland Landfill

Permit No.: 38230

Well or Piezometer No: MW-122M

Dates Started: December 6, 2012

Date Completed: December 9, 2012

A. SURVEYED LOCATIONS AND ELEVATIONS

Locations (± 0.5 ft):	
Specify corner of site:	NW
Distance & direction along boundary:	553 S
Distance & direction from boundary to wall:	462 E
Elevations (± 0.01 ft MSL):	
Ground Surface:	790.74
Top of protective casing:	792.94
Top of well casing:	792.70
Benchmark elevation:	820.39
Benchmark description:	Brass cap in concrete, 408 ft N of MW-20

B. SOIL BORING INFORMATION

Name & Address of Construction Company:	
Boart Longyear	
901D Grossman Drive	
Schofield, WI 54476	
Name of Driller:	Paul Dickinson
Drilling Method:	Rotary, HSA
Drilling Fluid:	Air
Bore Hole Diameter:	10.5" to 10', 6" below 10'
Soil Sampling Method:	Split spoon, screen air rotary chips
Depth of Boring:	154 ft

C. MONITORING WELL INSTALLATION

Casing material:	Flush threaded PVC schedule 80	Placement method:	Gravity
Length of casing:	155.3	Volume:	0.67 ft^3
Outside casing diameter:	2.4 in	Backfill (if different from seal):	
Inside casing diameter:	1.89 in	Material:	Bentonite Slurry / 3/8" Chips
Casing joint type:	Flush Threaded	Placement method:	Tremie Pumped / Gravity
Casing/screen joint type:	Flush Threaded	Volume:	400 gal. Slurry / 6 ft^3 Chips
Screen material:	PVC	Surface seal design:	
Screen opening size:	0.01 in	Material of protective casing:	Steel
Screen length:	5 ft	Material of grout between	
Depth of well:	152.8 ft	protective casing and well casing:	bentonite & concrete
Filter Pack:		Protective cap:	
Material:	Red Flint Filter Sand	Material:	aluminum
Grain size:	#40	Vented:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Volume:	1.5 ft^3	Locking:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Seal (minimum 3 ft length above filter pack):		Well Cap:	
Material:	3/8 inch bentonite chips	Material:	plastic with rubber gasket
Vented:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		

D. GROUNDWATER MEASUREMENT (± 0.01 ft below top of inner well casing)

Water level: 68.81 Stabilization Time: 1 week

Well development method: Surged & bailed with bailer and pump


Average depth of frostline: 3 feet

Attachments: Driller's log. Pipe schedules and grouting schedules. 8 1/2x11 inch map showing locations of all monitoring wells and piezometers.

Please mail completed form to: Iowa Department of Natural Resources, Land Quality Bureau, 502 E 9th St, Des Moines IA 50319-0034.Questions? Call or Email: Nina Koger, Environmental Engineer Sr., 515-281-8986, Nina.Koger@dnr.iowa.gov

ELEVATIONS: \pm 0.01 ft MSL
DEPTHS: \pm 0.1 ft FROM GROUND SURFACE

SPACE TO ATTACH ENTIRE SOIL BORING LOG
(SHOW SCREENED INTERVAL AND FILTER PACK INTERVAL.)





IOWA DEPARTMENT OF NATURAL RESOURCES
MONITORING WELL/PIEZOMETER CONSTRUCTION DOCUMENTATION FORM

Disposal Site Name: IPL - Ottumwa Midland LandfillPermit No.: 90-SDP-8-92PWell or Piezometer No: MW-301Dates Started: 11/23/15Date Completed: 11/24/15**A. SURVEYED LOCATIONS AND ELEVATIONS**Locations (± 0.5 ft): _____Specify corner of site: SEDistance & direction along boundary: 700'NDistance & direction from boundary to wall: 90' WElevations (± 0.01 ft MSL): _____Ground Surface: 815.51'Top of protective casing: 818.36'Top of well casing: 817.88'Benchmark elevation: 818.70Benchmark description: Control Point #2**B. SOIL BORING INFORMATION**

Name & Address of Construction Company:

Cascade Drilling, LP301 Alderson StSchofield, WI 54476Name of Driller: Todd SchmalfeldDrilling Method: 4.25' HSA to 24.5'/Air Rotary to 164'/coringDrilling Fluid: NABore Hole Diameter: 8.50 inch/ 6 inchSoil Sampling Method: Split Spoon/cuttings/coreDepth of Boring: 202'**C. MONITORING WELL INSTALLATION**Casing material: sch 80 PVCLength of casing: 196'Outside casing diameter: 2.38"Inside casing diameter: 1.9"Casing joint type: threadedCasing/screen joint type: threadedScreen material: PVCScreen opening size: 0.010Screen length: 5 ftDepth of well: 201 ft

Filter Pack: _____

Material: Red FlintGrain size: #40Volume: 2 cubic ft

Seal (minimum 3 ft length above filter pack): _____

Material: AquaGuard groutPlacement method: tremieVolume: 400 gallons

Backfill (if different from seal): _____

Material: 3/8" bentonite chips and Aqua Guard groutPlacement method: gravity/tremie

Volume: _____

Surface seal design: _____

Material of protective casing: Steel 6 inchMaterial of grout between protective casing and well casing: sand

Protective cap: _____


Material: SteelVented: Yes No Locking: Yes No

Well Cap: _____

Material: PVCVented: Yes No**D. GROUNDWATER MEASUREMENT (± 0.01 ft below top of inner well casing)**Water level: 125.9Stabilization Time: 20 HRWell development method: Surged and bailed, then pumped to reduce turbidity.Average depth of frostline: 3.5'**Attachments: Driller's log. Pipe schedules and grouting schedules. 8 1/2x11 inch map showing locations of all monitoring wells and piezometers.****Please mail completed for to:** Iowa Department of Natural Resources, Land Quality Bureau, 502 E 9th St, Des Moines IA 50319-0034.**Questions? Call or Email:** Nina Koger, Environmental Engineer Sr., 515-281-8986, Nina.Koger@dnr.iowa.gov

ELEVATIONS: ± 0.01 ft MSL
DEPTHS: ± 0.1 ft FROM GROUND SURFACE

SPACE TO ATTACH ENTIRE SOIL BORING LOG
(SHOW SCREENED INTERVAL AND FILTER PACK INTERVAL.)



Note: Grout placed from 190.4' bgs to 113' bgs. Void noted from 105' bgs to 113'. Grout basket placed at 95'bgs. Annular space above grout basket sealed with 3/8" bentonite chips (80'-95' bgs) and bentonite grout (3' bgs to 80' bgs).



**IOWA DEPARTMENT OF NATURAL RESOURCES
MONITORING WELL/PIEZOMETER CONSTRUCTION DOCUMENTATION FORM**

Disposal Site Name: IPL - Ottumwa Midland LandfillPermit No.: 90-SDP-8-92PWell or Piezometer No: MW-302Dates Started: 12/1/15Date Completed: 12/3/15

A. SURVEYED LOCATIONS AND ELEVATIONS		B. SOIL BORING INFORMATION
Locations (± 0.5 ft): _____		Name & Address of Construction Company: <u>Cascade Drilling, LP</u>
Specify corner of site: <u>SE</u>		<u>301 Alderson St</u>
Distance & direction along boundary: <u>700' N</u>		<u>Schofield, WI 54476</u>
Distance & direction from boundary to wall: <u>725' W</u>		
Elevations (± 0.01 ft MSL): _____		Name of Driller: <u>Todd Schmalfeld</u>
Ground Surface: <u>759.50'</u>		Drilling Method: <u>4.25'HSA to 14.5'/Air Rotary to 95'/coring</u>
Top of protective casing: <u>762.31'</u>		Drilling Fluid: <u>NA</u>
Top of well casing: <u>761.77'</u>		Bore Hole Diameter: <u>8.5 inch/6 inch</u>
Benchmark elevation: <u>818.70</u>		Soil Sampling Method: <u>Spoon/cuttings/core</u>
Benchmark description: <u>Control Point #2</u>		Depth of Boring: <u>156.5'</u>

C. MONITORING WELL INSTALLATION			
Casing material:	<u>sch 80 PVC</u>	Placement method:	<u>gravity</u>
Length of casing:	<u>150'</u>	Volume:	<u>0.5 cubic ft</u>
Outside casing diameter:	<u>2.38"</u>	Backfill (if different from seal):	<u>Agua Guard Grout</u>
Inside casing diameter:	<u>1.9"</u>	Material:	<u>Tremie</u>
Casing joint type:	<u>threaded</u>	Volume:	<u>300 gallons</u>
Casing/screen joint type:	<u>threaded</u>	Surface seal design:	<u>Steel 6 inch</u>
Screen material:	<u>PVC</u>	Material of protective casing:	<u>Steel 6 inch</u>
Screen opening size:	<u>0.010</u>	Material of grout between protective casing and well casing:	<u>sand</u>
Screen length:	<u>5'</u>	Protective cap:	<u>Red Flint</u>
Depth of well:	<u>155'</u>	Material:	<u>Steel</u>
Filter Pack:		Vented:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Material:	<u>Red Flint</u>	Locking:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Grain size:	<u>#40</u>	Well Cap:	<u>PVC</u>
Volume:	<u>2 cubic ft</u>	Vented:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Seal (minimum 3 ft length above filter pack):	<u>3/8" bentonite chips</u>	Material:	<u>Steel</u>

D. GROUNDWATER MEASUREMENT (± 0.01 ft below top of inner well casing)			
Water level:	<u>75.97'</u>	Stabilization Time:	<u><1 hour</u>
Well development method:	<u>Surged and bailed then pumped to reduce turbidity</u>		
Average depth of frostline:	<u>3.5'</u>		


Attachments: Driller's log. Pipe schedules and grouting schedules. 8 1/2x11 inch map showing locations of all monitoring wells and piezometers.

Please mail completed for to: Iowa Department of Natural Resources, Land Quality Bureau, 502 E 9th St, Des Moines IA 50319-0034.

Questions? Call or Email: Nina Koger, Environmental Engineer Sr., 515-281-8986, Nina.Koger@dnr.iowa.gov

ELEVATIONS: \pm 0.01 ft MSL
DEPTHS: \pm 0.1 ft FROM GROUND SURFACE

SPACE TO ATTACH ENTIRE SOIL BORING LOG
(SHOW SCREENED INTERVAL AND FILTER PACK INTERVAL.)





IOWA DEPARTMENT OF NATURAL RESOURCES
MONITORING WELL/PIEZOMETER CONSTRUCTION DOCUMENTATION FORM

Disposal Site Name: IPL - Ottumwa Midland LandfillPermit No.: 90-SDP-8-92PWell or Piezometer No: MW-303Dates Started: 4/25/16Date Completed: 4/26/16

A. SURVEYED LOCATIONS AND ELEVATIONS		B. SOIL BORING INFORMATION
Locations (± 0.5 ft): _____		Name & Address of Construction Company: _____ _____ _____
Specify corner of site: <u>SE</u>		Name of Driller: _____
Distance & direction along boundary: <u>700' N</u>		Drilling Method: <u>4.25'HSA to/Air Rotary/coring</u>
Distance & direction from boundary to wall: <u>350' W</u>		Drilling Fluid: <u>NA</u>
Elevations (± 0.01 ft MSL): _____		Bore Hole Diameter: <u>8.5 inch/6 inch</u>
Ground Surface: <u>759.93</u>		Soil Sampling Method: <u>Spoon/cuttings/core</u>
Top of protective casing: <u>762.94</u>		Depth of Boring: _____
Top of well casing: <u>762.40</u>		
Benchmark elevation: <u>818.70</u>		
Benchmark description: <u>Control Point #2</u>		
C. MONITORING WELL INSTALLATION		
Casing material: <u>sch 80 PVC</u>		Placement method: <u>tremie</u>
Length of casing: <u>142'</u>		Volume: <u>300 gal</u>
Outside casing diameter: <u>2.40"</u>		Backfill (if different from seal): _____
Inside casing diameter: <u>1.9"</u>		Material: <u>3/8" bentonite chips</u>
Casing joint type: <u>threaded</u>		Placement method: <u>gravity</u>
Casing/screen joint type: <u>threaded</u>		Volume: <u>15 cubic ft</u>
Screen material: <u>PVC sch 80</u>		Surface seal design: _____
Screen opening size: <u>0.010</u>		Material of protective casing: <u>steel</u>
Screen length: <u>5'</u>		Material of grout between protective casing and well casing: <u>bentonite chips and sand</u>
Depth of well: <u>147'</u>		Protective cap: _____
Filter Pack: _____		Material: <u>steel</u>
Material: <u>Unamin Filtersil</u>		Vented: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Locking: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Grain size: <u>10/20 mesh</u>		Well Cap: _____
Volume: <u>2.5 cubic ft</u>		Material: <u>Plastic</u>
Seal (minimum 3 ft length above filter pack): _____		Vented: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Material: <u>3/8" bentonite chips</u>		

D. GROUNDWATER MEASUREMENT (± 0.01 ft below top of inner well casing)		
Water level: <u>76.36</u>	Stabilization Time: <u><1hr.</u>	
Well development method: <u>surged and bailed, then pumped to reduce turbidity.</u>		
Average depth of frostline: <u>3.5</u>		


Attachments: Driller's log. Pipe schedules and grouting schedules. 8 1/2x11 inch map showing locations of all monitoring wells and piezometers.

Please mail completed form to: Iowa Department of Natural Resources, Land Quality Bureau, 502 E 9th St, Des Moines IA 50319-0034.

Questions? Call or Email: Nina Koger, Environmental Engineer Sr., 515-281-8986, Nina.Koger@dnr.iowa.gov

ELEVATIONS: \pm 0.01 ft MSL
DEPTHS: \pm 0.1 ft FROM GROUND SURFACE

SPACE TO ATTACH ENTIRE SOIL BORING LOG
(SHOW SCREENED INTERVAL AND FILTER PACK INTERVAL.)



Appendix C

Laboratory Reports

ANALYTICAL REPORT

PREPARED FOR

Attn: Meghan Blodgett
SCS Engineers
2830 Dairy Drive
Madison, Wisconsin 53718

Generated 10/26/2023 2:01:27 PM

JOB DESCRIPTION

Ottumwa Midland Landfill 25223073

JOB NUMBER

310-267271-1

Eurofins Cedar Falls

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Environment Testing North Central, LLC Project Manager.

Authorization



Generated
10/26/2023 2:01:27 PM

Authorized for release by
Sandie Fredrick, Project Manager II
Sandra.Fredrick@et.eurofinsus.com
(920)261-1660

Table of Contents

Cover Page	1
Table of Contents	3
Case Narrative	4
Sample Summary	5
Detection Summary	6
Client Sample Results	8
Definitions	14
QC Sample Results	15
QC Association	18
Chronicle	20
Certification Summary	22
Method Summary	23
Chain of Custody	24
Receipt Checklists	27
Field Data Sheets	28

Case Narrative

Client: SCS Engineers
Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

Job ID: 310-267271-1

Laboratory: Eurofins Cedar Falls

Narrative

**Job Narrative
310-267271-1**

Receipt

The samples were received on 10/13/2023 5:30 PM. Unless otherwise noted below, the samples arrived in good condition, and where required, properly preserved and on ice. The temperature of the cooler at receipt was 2.3° C.

HPLC/IC

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Metals

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

General Chemistry

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Sample Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
310-267271-1	MW-301	Water	10/11/23 12:10	10/13/23 17:30
310-267271-2	MW-302	Water	10/11/23 14:35	10/13/23 17:30
310-267271-3	MW-303	Water	10/11/23 13:35	10/13/23 17:30
310-267271-4	MW-102M	Water	10/11/23 11:00	10/13/23 17:30
310-267271-5	MW-122M	Water	10/11/23 10:38	10/13/23 17:30
310-267271-6	Field Blank	Water	10/11/23 14:30	10/13/23 17:30

Detection Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

Client Sample ID: MW-301

Lab Sample ID: 310-267271-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloride	21		5.0	2.3	mg/L	5		9056A	Total/NA
Fluoride	0.99	J	1.0	0.38	mg/L	5		9056A	Total/NA
Sulfate	360		5.0	2.1	mg/L	5		9056A	Total/NA
Boron	710		100	76	ug/L	1		6020B	Total/NA
Calcium	120		0.50	0.19	mg/L	1		6020B	Total/NA
Total Dissolved Solids	960		50	34	mg/L	1		SM 2540C	Total/NA
pH	7.6	HF	1.0	1.0	SU	1		SM 4500 H+ B	Total/NA
Groundwater Elevation	684.55				ft	1		Field Sampling	Total/NA
Oxidation Reduction Potential	-97.3				mV	1		Field Sampling	Total/NA
Oxygen, Dissolved	0.39				mg/L	1		Field Sampling	Total/NA
Field pH	6.74				SU	1		Field Sampling	Total/NA
Field Conductivity	1562				umhos/cm	1		Field Sampling	Total/NA
Field Temperature	13.4				Degrees C	1		Field Sampling	Total/NA
Field Turbidity	6.55				NTU	1		Field Sampling	Total/NA

Client Sample ID: MW-302

Lab Sample ID: 310-267271-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloride	5.6		5.0	2.3	mg/L	5		9056A	Total/NA
Fluoride	1.2		1.0	0.38	mg/L	5		9056A	Total/NA
Sulfate	72		5.0	2.1	mg/L	5		9056A	Total/NA
Boron	790		100	76	ug/L	1		6020B	Total/NA
Calcium	40		0.50	0.19	mg/L	1		6020B	Total/NA
Total Dissolved Solids	640		250	170	mg/L	1		SM 2540C	Total/NA
pH	8.0	HF	1.0	1.0	SU	1		SM 4500 H+ B	Total/NA
Groundwater Elevation	684.12				ft	1		Field Sampling	Total/NA
Oxidation Reduction Potential	-100.9				mV	1		Field Sampling	Total/NA
Oxygen, Dissolved	0.44				mg/L	1		Field Sampling	Total/NA
Field pH	7.24				SU	1		Field Sampling	Total/NA
Field Conductivity	1129				umhos/cm	1		Field Sampling	Total/NA
Field Temperature	13.6				Degrees C	1		Field Sampling	Total/NA
Field Turbidity	68.96				NTU	1		Field Sampling	Total/NA

Client Sample ID: MW-303

Lab Sample ID: 310-267271-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloride	7.9		5.0	2.3	mg/L	5		9056A	Total/NA
Fluoride	0.92	J	1.0	0.38	mg/L	5		9056A	Total/NA
Sulfate	350		5.0	2.1	mg/L	5		9056A	Total/NA
Boron	740		100	76	ug/L	1		6020B	Total/NA
Calcium	110		0.50	0.19	mg/L	1		6020B	Total/NA
Total Dissolved Solids	930		50	34	mg/L	1		SM 2540C	Total/NA
pH	7.8	HF	1.0	1.0	SU	1		SM 4500 H+ B	Total/NA
Groundwater Elevation	684.95				ft	1		Field Sampling	Total/NA
Oxidation Reduction Potential	-85.7				mV	1		Field Sampling	Total/NA
Oxygen, Dissolved	0.55				mg/L	1		Field Sampling	Total/NA
Field pH	6.81				SU	1		Field Sampling	Total/NA
Field Conductivity	1617				umhos/cm	1		Field Sampling	Total/NA
Field Temperature	14.1				Degrees C	1		Field Sampling	Total/NA
Field Turbidity	64.61				NTU	1		Field Sampling	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Cedar Falls

Detection Summary

Client: SCS Engineers

Job ID: 310-267271-1

Project/Site: Ottumwa Midland Landfill 25223073

Client Sample ID: MW-102M

Lab Sample ID: 310-267271-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloride	28		5.0	2.3	mg/L	5		9056A	Total/NA
Fluoride	5.0		1.0	0.38	mg/L	5		9056A	Total/NA
Sulfate	400		5.0	2.1	mg/L	5		9056A	Total/NA
Boron	1500		100	76	ug/L	1		6020B	Total/NA
Calcium	15		0.50	0.19	mg/L	1		6020B	Total/NA
Total Dissolved Solids	1500		50	34	mg/L	1		SM 2540C	Total/NA
pH	8.3	HF	1.0	1.0	SU	1		SM 4500 H+ B	Total/NA
Groundwater Elevation	720.93				ft	1		Field Sampling	Total/NA
Oxidation Reduction Potential	8.4				mV	1		Field Sampling	Total/NA
Oxygen, Dissolved	6.39				mg/L	1		Field Sampling	Total/NA
Field pH	7.73				SU	1		Field Sampling	Total/NA
Field Conductivity	2272.0				umhos/cm	1		Field Sampling	Total/NA
Field Temperature	20.0				Degrees C	1		Field Sampling	Total/NA
Field Turbidity	17.31				NTU	1		Field Sampling	Total/NA

Client Sample ID: MW-122M

Lab Sample ID: 310-267271-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloride	8.2		5.0	2.3	mg/L	5		9056A	Total/NA
Fluoride	0.57	J	1.0	0.38	mg/L	5		9056A	Total/NA
Sulfate	10000		200	84	mg/L	200		9056A	Total/NA
Boron	4400		100	76	ug/L	1		6020B	Total/NA
Calcium	450		0.50	0.19	mg/L	1		6020B	Total/NA
Total Dissolved Solids	15000		2500	1700	mg/L	1		SM 2540C	Total/NA
pH	7.9	HF	1.0	1.0	SU	1		SM 4500 H+ B	Total/NA
Groundwater Elevation	707.90				ft	1		Field Sampling	Total/NA

Client Sample ID: Field Blank

Lab Sample ID: 310-267271-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Calcium	0.70		0.50	0.19	mg/L	1		6020B	Total/NA
Total Dissolved Solids	240		50	34	mg/L	1		SM 2540C	Total/NA
pH	7.8	HF	1.0	1.0	SU	1		SM 4500 H+ B	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Job ID: 310-267271-1

Project/Site: Ottumwa Midland Landfill 25223073

Client Sample ID: MW-301

Lab Sample ID: 310-267271-1

Date Collected: 10/11/23 12:10

Matrix: Water

Date Received: 10/13/23 17:30

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	21		5.0	2.3	mg/L			10/24/23 22:01	5
Fluoride	0.99	J	1.0	0.38	mg/L			10/24/23 22:01	5
Sulfate	360		5.0	2.1	mg/L			10/24/23 22:01	5

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	710		100	76	ug/L			10/20/23 16:17	1
Calcium	120		0.50	0.19	mg/L			10/20/23 16:17	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids (SM 2540C)	960		50	34	mg/L			10/16/23 15:37	1
pH (SM 4500 H+ B)	7.6	HF	1.0	1.0	SU			10/14/23 03:39	1

Method: EPA Field Sampling - Field Sampling

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Groundwater Elevation	684.55				ft			10/11/23 12:10	1
Oxidation Reduction Potential	-97.3				mV			10/11/23 12:10	1
Oxygen, Dissolved	0.39				mg/L			10/11/23 12:10	1
Field pH	6.74				SU			10/11/23 12:10	1
Field Conductivity	1562				umhos/cm			10/11/23 12:10	1
Field Temperature	13.4				Degrees C			10/11/23 12:10	1
Field Turbidity	6.55				NTU			10/11/23 12:10	1

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Job ID: 310-267271-1

Project/Site: Ottumwa Midland Landfill 25223073

Client Sample ID: MW-302

Lab Sample ID: 310-267271-2

Date Collected: 10/11/23 14:35

Matrix: Water

Date Received: 10/13/23 17:30

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	5.6		5.0	2.3	mg/L			10/24/23 22:46	5
Fluoride	1.2		1.0	0.38	mg/L			10/24/23 22:46	5
Sulfate	72		5.0	2.1	mg/L			10/24/23 22:46	5

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	790		100	76	ug/L		10/17/23 10:30	10/20/23 16:20	1
Calcium	40		0.50	0.19	mg/L		10/17/23 10:30	10/20/23 16:20	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids (SM 2540C)	640		250	170	mg/L			10/16/23 15:37	1
pH (SM 4500 H+ B)	8.0	HF	1.0	1.0	SU			10/14/23 03:35	1

Method: EPA Field Sampling - Field Sampling

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Groundwater Elevation	684.12				ft			10/11/23 14:35	1
Oxidation Reduction Potential	-100.9				mV			10/11/23 14:35	1
Oxygen, Dissolved	0.44				mg/L			10/11/23 14:35	1
Field pH	7.24				SU			10/11/23 14:35	1
Field Conductivity	1129				umhos/cm			10/11/23 14:35	1
Field Temperature	13.6				Degrees C			10/11/23 14:35	1
Field Turbidity	68.96				NTU			10/11/23 14:35	1

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Job ID: 310-267271-1

Project/Site: Ottumwa Midland Landfill 25223073

Client Sample ID: MW-303

Lab Sample ID: 310-267271-3

Date Collected: 10/11/23 13:35

Matrix: Water

Date Received: 10/13/23 17:30

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	7.9		5.0	2.3	mg/L			10/24/23 23:01	5
Fluoride	0.92	J	1.0	0.38	mg/L			10/24/23 23:01	5
Sulfate	350		5.0	2.1	mg/L			10/24/23 23:01	5

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	740		100	76	ug/L			10/20/23 16:24	1
Calcium	110		0.50	0.19	mg/L			10/20/23 16:24	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids (SM 2540C)	930		50	34	mg/L			10/16/23 15:37	1
pH (SM 4500 H+ B)	7.8	HF	1.0	1.0	SU			10/14/23 05:14	1

Method: EPA Field Sampling - Field Sampling

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Groundwater Elevation	684.95				ft			10/11/23 13:35	1
Oxidation Reduction Potential	-85.7				mV			10/11/23 13:35	1
Oxygen, Dissolved	0.55				mg/L			10/11/23 13:35	1
Field pH	6.81				SU			10/11/23 13:35	1
Field Conductivity	1617				umhos/cm			10/11/23 13:35	1
Field Temperature	14.1				Degrees C			10/11/23 13:35	1
Field Turbidity	64.61				NTU			10/11/23 13:35	1

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Job ID: 310-267271-1

Project/Site: Ottumwa Midland Landfill 25223073

Client Sample ID: MW-102M

Lab Sample ID: 310-267271-4

Date Collected: 10/11/23 11:00

Matrix: Water

Date Received: 10/13/23 17:30

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	28		5.0	2.3	mg/L			10/24/23 23:15	5
Fluoride	5.0		1.0	0.38	mg/L			10/24/23 23:15	5
Sulfate	400		5.0	2.1	mg/L			10/24/23 23:15	5

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	1500		100	76	ug/L			10/20/23 16:27	1
Calcium	15		0.50	0.19	mg/L			10/20/23 16:27	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids (SM 2540C)	1500		50	34	mg/L			10/16/23 15:37	1
pH (SM 4500 H+ B)	8.3	HF	1.0	1.0	SU			10/14/23 05:18	1

Method: EPA Field Sampling - Field Sampling

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Groundwater Elevation	720.93				ft			10/11/23 11:00	1
Oxidation Reduction Potential	8.4				mV			10/11/23 11:00	1
Oxygen, Dissolved	6.39				mg/L			10/11/23 11:00	1
Field pH	7.73				SU			10/11/23 11:00	1
Field Conductivity	2272.0				umhos/cm			10/11/23 11:00	1
Field Temperature	20.0				Degrees C			10/11/23 11:00	1
Field Turbidity	17.31				NTU			10/11/23 11:00	1

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Job ID: 310-267271-1

Project/Site: Ottumwa Midland Landfill 25223073

Client Sample ID: MW-122M

Lab Sample ID: 310-267271-5

Matrix: Water

Date Collected: 10/11/23 10:38

Date Received: 10/13/23 17:30

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	8.2		5.0	2.3	mg/L			10/24/23 23:30	5
Fluoride	0.57 J		1.0	0.38	mg/L			10/24/23 23:30	5
Sulfate	10000		200	84	mg/L			10/25/23 15:49	200

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	4400		100	76	ug/L			10/20/23 16:34	1
Calcium	450		0.50	0.19	mg/L			10/20/23 16:34	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids (SM 2540C)	15000		2500	1700	mg/L			10/17/23 15:08	1
pH (SM 4500 H+ B)	7.9 HF		1.0	1.0	SU			10/14/23 04:19	1

Method: EPA Field Sampling - Field Sampling

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Groundwater Elevation	707.90				ft			10/11/23 10:38	1

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Job ID: 310-267271-1

Project/Site: Ottumwa Midland Landfill 25223073

Client Sample ID: Field Blank**Lab Sample ID: 310-267271-6**

Matrix: Water

Date Collected: 10/11/23 14:30

Date Received: 10/13/23 17:30

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	<0.45		1.0	0.45	mg/L			10/24/23 23:44	1
Fluoride	<0.075		0.20	0.075	mg/L			10/24/23 23:44	1
Sulfate	<0.42		1.0	0.42	mg/L			10/24/23 23:44	1

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	<76		100	76	ug/L		10/17/23 10:30	10/20/23 16:38	1
Calcium	0.70		0.50	0.19	mg/L		10/17/23 10:30	10/20/23 16:38	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids (SM 2540C)	240		50	34	mg/L			10/16/23 15:44	1
pH (SM 4500 H+ B)	7.8	HF	1.0	1.0	SU			10/14/23 03:21	1

Eurofins Cedar Falls

Definitions/Glossary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

Qualifiers

HPLC/IC

Qualifier	Qualifier Description
4	MS, MSD: The analyte present in the original sample is greater than 4 times the matrix spike concentration; therefore, control limits are not applicable.
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

General Chemistry

Qualifier	Qualifier Description
HF	Parameter with a holding time of 15 minutes. Test performed by laboratory at client's request. Sample was analyzed outside of hold time.

Glossary

Abbreviation These commonly used abbreviations may or may not be present in this report.

□	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

QC Sample Results

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

Method: 9056A - Anions, Ion Chromatography

Lab Sample ID: MB 310-403851/3

Matrix: Water

Analysis Batch: 403851

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	<0.45		1.0	0.45	mg/L			10/24/23 18:37	1
Fluoride	<0.075		0.20	0.075	mg/L			10/24/23 18:37	1
Sulfate	<0.42		1.0	0.42	mg/L			10/24/23 18:37	1

Lab Sample ID: LCS 310-403851/45

Matrix: Water

Analysis Batch: 403851

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte		Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride		10.0	10.1		mg/L		101	90 - 110
Fluoride		2.00	2.15		mg/L		108	90 - 110
Sulfate		10.0	10.6		mg/L		106	90 - 110

Lab Sample ID: 310-267271-1 MS

Matrix: Water

Analysis Batch: 403851

Client Sample ID: MW-301
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MS Result	MS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride	21		25.0	45.8		mg/L		99	80 - 120
Fluoride	0.99	J	5.00	6.34		mg/L		107	80 - 120
Sulfate	360		25.0	377	4	mg/L		62	80 - 120

Lab Sample ID: 310-267271-1 MSD

Matrix: Water

Analysis Batch: 403851

Client Sample ID: MW-301
Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	Spike Added	MSD Result	MSD Qualifier	Unit	D	%Rec	%Rec Limits	RPD	RPD Limit
Chloride	21		25.0	45.7		mg/L		99	80 - 120	0	15
Fluoride	0.99	J	5.00	6.32		mg/L		107	80 - 120	0	15
Sulfate	360		25.0	375	4	mg/L		55	80 - 120	1	15

Method: 6020B - Metals (ICP/MS)

Lab Sample ID: MB 310-402733/1-A

Matrix: Water

Analysis Batch: 403196

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 402733

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	<76		100	76	ug/L		10/17/23 10:30	10/19/23 19:09	1
Calcium	<0.19		0.50	0.19	mg/L		10/17/23 10:30	10/19/23 19:09	1

Lab Sample ID: LCS 310-402733/2-A

Matrix: Water

Analysis Batch: 403196

Client Sample ID: Lab Control Sample
Prep Type: Total/NA
Prep Batch: 402733

Analyte		Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Boron		200	193		ug/L		97	80 - 120
Calcium		2.00	1.71		mg/L		85	80 - 120

Eurofins Cedar Falls

QC Sample Results

Client: SCS Engineers
Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

Method: SM 2540C - Solids, Total Dissolved (TDS)

Lab Sample ID: MB 310-402676/1

Matrix: Water

Analysis Batch: 402676

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids	<34		50	34	mg/L			10/16/23 15:37	1

Lab Sample ID: LCS 310-402676/2

Matrix: Water

Analysis Batch: 402676

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Total Dissolved Solids	1000	968		mg/L		97	90 - 110

Lab Sample ID: MB 310-402678/1

Matrix: Water

Analysis Batch: 402678

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids	<34		50	34	mg/L			10/16/23 15:44	1

Lab Sample ID: LCS 310-402678/2

Matrix: Water

Analysis Batch: 402678

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Total Dissolved Solids	1000	980		mg/L		98	90 - 110

Lab Sample ID: MB 310-402825/1

Matrix: Water

Analysis Batch: 402825

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids	<34		50	34	mg/L			10/17/23 15:08	1

Lab Sample ID: LCS 310-402825/2

Matrix: Water

Analysis Batch: 402825

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
Total Dissolved Solids	1000	1000		mg/L		100	90 - 110

Method: SM 4500 H+ B - pH

Lab Sample ID: LCS 310-402565/53

Matrix: Water

Analysis Batch: 402565

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	Limits
pH	7.00	7.0		SU		100	98 - 102

Eurofins Cedar Falls

QC Sample Results

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

Method: SM 4500 H+ B - pH (Continued)

Lab Sample ID: LCS 310-402565/79

Matrix: Water

Analysis Batch: 402565

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
pH	7.00	7.0		SU	100	98 - 102	

QC Association Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

HPLC/IC

Analysis Batch: 403851

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-267271-1	MW-301	Total/NA	Water	9056A	
310-267271-2	MW-302	Total/NA	Water	9056A	
310-267271-3	MW-303	Total/NA	Water	9056A	
310-267271-4	MW-102M	Total/NA	Water	9056A	
310-267271-5	MW-122M	Total/NA	Water	9056A	
310-267271-5	MW-122M	Total/NA	Water	9056A	
310-267271-6	Field Blank	Total/NA	Water	9056A	
MB 310-403851/3	Method Blank	Total/NA	Water	9056A	
LCS 310-403851/45	Lab Control Sample	Total/NA	Water	9056A	
310-267271-1 MS	MW-301	Total/NA	Water	9056A	
310-267271-1 MSD	MW-301	Total/NA	Water	9056A	

Metals

Prep Batch: 402733

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-267271-1	MW-301	Total/NA	Water	3005A	
310-267271-2	MW-302	Total/NA	Water	3005A	
310-267271-3	MW-303	Total/NA	Water	3005A	
310-267271-4	MW-102M	Total/NA	Water	3005A	
310-267271-5	MW-122M	Total/NA	Water	3005A	
310-267271-6	Field Blank	Total/NA	Water	3005A	
MB 310-402733/1-A	Method Blank	Total/NA	Water	3005A	
LCS 310-402733/2-A	Lab Control Sample	Total/NA	Water	3005A	

Analysis Batch: 403196

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
MB 310-402733/1-A	Method Blank	Total/NA	Water	6020B	402733
LCS 310-402733/2-A	Lab Control Sample	Total/NA	Water	6020B	402733

Analysis Batch: 403333

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-267271-1	MW-301	Total/NA	Water	6020B	402733
310-267271-2	MW-302	Total/NA	Water	6020B	402733
310-267271-3	MW-303	Total/NA	Water	6020B	402733
310-267271-4	MW-102M	Total/NA	Water	6020B	402733
310-267271-5	MW-122M	Total/NA	Water	6020B	402733
310-267271-6	Field Blank	Total/NA	Water	6020B	402733

General Chemistry

Analysis Batch: 402565

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-267271-1	MW-301	Total/NA	Water	SM 4500 H+ B	
310-267271-2	MW-302	Total/NA	Water	SM 4500 H+ B	
310-267271-3	MW-303	Total/NA	Water	SM 4500 H+ B	
310-267271-4	MW-102M	Total/NA	Water	SM 4500 H+ B	
310-267271-5	MW-122M	Total/NA	Water	SM 4500 H+ B	
310-267271-6	Field Blank	Total/NA	Water	SM 4500 H+ B	
LCS 310-402565/53	Lab Control Sample	Total/NA	Water	SM 4500 H+ B	
LCS 310-402565/79	Lab Control Sample	Total/NA	Water	SM 4500 H+ B	

Eurofins Cedar Falls

QC Association Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

General Chemistry

Analysis Batch: 402676

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-267271-1	MW-301	Total/NA	Water	SM 2540C	
310-267271-2	MW-302	Total/NA	Water	SM 2540C	
310-267271-3	MW-303	Total/NA	Water	SM 2540C	
310-267271-4	MW-102M	Total/NA	Water	SM 2540C	
MB 310-402676/1	Method Blank	Total/NA	Water	SM 2540C	
LCS 310-402676/2	Lab Control Sample	Total/NA	Water	SM 2540C	

Analysis Batch: 402678

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-267271-6	Field Blank	Total/NA	Water	SM 2540C	
MB 310-402678/1	Method Blank	Total/NA	Water	SM 2540C	
LCS 310-402678/2	Lab Control Sample	Total/NA	Water	SM 2540C	

Analysis Batch: 402825

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-267271-5	MW-122M	Total/NA	Water	SM 2540C	
MB 310-402825/1	Method Blank	Total/NA	Water	SM 2540C	
LCS 310-402825/2	Lab Control Sample	Total/NA	Water	SM 2540C	

Field Service / Mobile Lab

Analysis Batch: 403834

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-267271-1	MW-301	Total/NA	Water	Field Sampling	
310-267271-2	MW-302	Total/NA	Water	Field Sampling	
310-267271-3	MW-303	Total/NA	Water	Field Sampling	
310-267271-4	MW-102M	Total/NA	Water	Field Sampling	
310-267271-5	MW-122M	Total/NA	Water	Field Sampling	

Eurofins Cedar Falls

Lab Chronicle

Client: SCS Engineers
Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

Client Sample ID: MW-301
Date Collected: 10/11/23 12:10
Date Received: 10/13/23 17:30

Lab Sample ID: 310-267271-1
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		5	403851	QTZ5	EET CF	10/24/23 22:01
Total/NA	Prep	3005A			402733	KCK5	EET CF	10/17/23 10:30
Total/NA	Analysis	6020B		1	403333	A6US	EET CF	10/20/23 16:17
Total/NA	Analysis	SM 2540C		1	402676	D7CP	EET CF	10/16/23 15:37
Total/NA	Analysis	SM 4500 H+ B		1	402565	D7CP	EET CF	10/14/23 03:39
Total/NA	Analysis	Field Sampling		1	403834	BJ0R	EET CF	10/11/23 12:10

Client Sample ID: MW-302
Date Collected: 10/11/23 14:35
Date Received: 10/13/23 17:30

Lab Sample ID: 310-267271-2
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		5	403851	QTZ5	EET CF	10/24/23 22:46
Total/NA	Prep	3005A			402733	KCK5	EET CF	10/17/23 10:30
Total/NA	Analysis	6020B		1	403333	A6US	EET CF	10/20/23 16:20
Total/NA	Analysis	SM 2540C		1	402676	D7CP	EET CF	10/16/23 15:37
Total/NA	Analysis	SM 4500 H+ B		1	402565	D7CP	EET CF	10/14/23 03:35
Total/NA	Analysis	Field Sampling		1	403834	BJ0R	EET CF	10/11/23 14:35

Client Sample ID: MW-303
Date Collected: 10/11/23 13:35
Date Received: 10/13/23 17:30

Lab Sample ID: 310-267271-3
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		5	403851	QTZ5	EET CF	10/24/23 23:01
Total/NA	Prep	3005A			402733	KCK5	EET CF	10/17/23 10:30
Total/NA	Analysis	6020B		1	403333	A6US	EET CF	10/20/23 16:24
Total/NA	Analysis	SM 2540C		1	402676	D7CP	EET CF	10/16/23 15:37
Total/NA	Analysis	SM 4500 H+ B		1	402565	D7CP	EET CF	10/14/23 05:14
Total/NA	Analysis	Field Sampling		1	403834	BJ0R	EET CF	10/11/23 13:35

Client Sample ID: MW-102M
Date Collected: 10/11/23 11:00
Date Received: 10/13/23 17:30

Lab Sample ID: 310-267271-4
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		5	403851	QTZ5	EET CF	10/24/23 23:15
Total/NA	Prep	3005A			402733	KCK5	EET CF	10/17/23 10:30
Total/NA	Analysis	6020B		1	403333	A6US	EET CF	10/20/23 16:27
Total/NA	Analysis	SM 2540C		1	402676	D7CP	EET CF	10/16/23 15:37
Total/NA	Analysis	SM 4500 H+ B		1	402565	D7CP	EET CF	10/14/23 05:18
Total/NA	Analysis	Field Sampling		1	403834	BJ0R	EET CF	10/11/23 11:00

Eurofins Cedar Falls

Lab Chronicle

Client: SCS Engineers
 Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

Client Sample ID: MW-122M

Lab Sample ID: 310-267271-5

Matrix: Water

Date Collected: 10/11/23 10:38

Date Received: 10/13/23 17:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		5	403851	QTZ5	EET CF	10/24/23 23:30
Total/NA	Analysis	9056A		200	403851	QTZ5	EET CF	10/25/23 15:49
Total/NA	Prep	3005A			402733	KCK5	EET CF	10/17/23 10:30
Total/NA	Analysis	6020B		1	403333	A6US	EET CF	10/20/23 16:34
Total/NA	Analysis	SM 2540C		1	402825	ENB7	EET CF	10/17/23 15:08
Total/NA	Analysis	SM 4500 H+ B		1	402565	D7CP	EET CF	10/14/23 04:19
Total/NA	Analysis	Field Sampling		1	403834	BJ0R	EET CF	10/11/23 10:38

Client Sample ID: Field Blank

Lab Sample ID: 310-267271-6

Matrix: Water

Date Collected: 10/11/23 14:30

Date Received: 10/13/23 17:30

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		1	403851	QTZ5	EET CF	10/24/23 23:44
Total/NA	Prep	3005A			402733	KCK5	EET CF	10/17/23 10:30
Total/NA	Analysis	6020B		1	403333	A6US	EET CF	10/20/23 16:38
Total/NA	Analysis	SM 2540C		1	402678	D7CP	EET CF	10/16/23 15:44
Total/NA	Analysis	SM 4500 H+ B		1	402565	D7CP	EET CF	10/14/23 03:21

Laboratory References:

EET CF = Eurofins Cedar Falls, 3019 Venture Way, Cedar Falls, IA 50613, TEL (319)277-2401

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Eurofins Cedar Falls

Accreditation/Certification Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

Laboratory: Eurofins Cedar Falls

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Iowa	State	007	12-01-23

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Eurofins Cedar Falls

Method Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25223073

Job ID: 310-267271-1

Method	Method Description	Protocol	Laboratory
9056A	Anions, Ion Chromatography	SW846	EET CF
6020B	Metals (ICP/MS)	SW846	EET CF
SM 2540C	Solids, Total Dissolved (TDS)	SM	EET CF
SM 4500 H+ B	pH	SM	EET CF
Field Sampling	Field Sampling	EPA	EET CF
3005A	Preparation, Total Metals	SW846	EET CF

Protocol References:

EPA = US Environmental Protection Agency

SM = "Standard Methods For The Examination Of Water And Wastewater"

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EET CF = Eurofins Cedar Falls, 3019 Venture Way, Cedar Falls, IA 50613, TEL (319)277-2401

Eurofins Cedar Falls



Environment Testing
America



310-267271 Chain of Custody

Cooler/Sample Receipt and Temperature Log Form

Client Information			
Client: SCS			
City/State:	CITY	STATE	WV
Project:			
Receipt Information			
Date/Time Received:	DATE 10/13/23	TIME 1730	Received By:
Delivery Type:	<input type="checkbox"/> UPS	<input type="checkbox"/> FedEx	<input type="checkbox"/> FedEx Ground
	<input type="checkbox"/> Lab Courier	<input type="checkbox"/> Lab Field Services	<input type="checkbox"/> Client Drop-off
	<input type="checkbox"/> US Mail <input type="checkbox"/> Spee-Dee		
	<input type="checkbox"/> Other: _____		
Condition of Cooler/Containers			
Sample(s) received in Cooler?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	If yes: Cooler ID: _____
Multiple Coolers?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	If yes: Cooler # _____ of _____
Cooler Custody Seals Present?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	If yes: Cooler custody seals intact? <input type="checkbox"/> Yes <input type="checkbox"/> No
Sample Custody Seals Present?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	If yes: Sample custody seals intact? <input type="checkbox"/> Yes <input type="checkbox"/> No
Trip Blank Present?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	If yes: Which VOA samples are in cooler? ↓
Temperature Record			
Coolant:	<input checked="" type="checkbox"/> Wet ice	<input type="checkbox"/> Blue ice	<input type="checkbox"/> Dry ice
	<input type="checkbox"/> Other: _____	<input type="checkbox"/> NONE	
Thermometer ID:	T	Correction Factor (°C):	+0.0
• Temp Blank Temperature – If no temp blank, or temp blank temperature above criteria, proceed to Sample Container Temperature			
Uncorrected Temp (°C):	2.3	Corrected Temp (°C):	2.3
• Sample Container Temperature			
Container(s) used:	CONTAINER 1		CONTAINER 2
Uncorrected Temp (°C):			
Corrected Temp (°C):			
Exceptions Noted			
1) If temperature exceeds criteria, was sample(s) received same day of sampling? <input type="checkbox"/> Yes <input type="checkbox"/> No			
a) If yes: Is there evidence that the chilling process began? <input type="checkbox"/> Yes <input type="checkbox"/> No			
2) If temperature is <0°C, are there obvious signs that the integrity of sample containers is compromised? (e.g., bulging septa, broken/cracked bottles, frozen solid?) <input type="checkbox"/> Yes <input type="checkbox"/> No			
NOTE: If yes, contact PM before proceeding. If no, proceed with login			
Additional Comments			

Eurosinsome

3019 Venture Way
Cedar Falls IA 50613
Phone (319) 277-2401 Phone (319) 277-2425

Ver 01/16/2019

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15

Table 2. Sampling Points and Parameters - CCR Rule Sampling Program - Detection Monitoring
Groundwater Monitoring - Ottumwa Midland Landfill / SCS Engineers Project #25223073

	Parameter	MW-301	MW-302	MW-303	MW-102M	MW-122M	Field Blank	TOTAL
Appendix III Parameters	Boron	x	x	x	x	x	x	6
	Calcium	x	x	x	x	x	x	6
	Chloride	x	x	x	x	x	x	6
	Fluoride	x	x	x	x	x	x	6
	pH	x	x	x	x	x	x	6
	Sulfate	x	x	x	x	x	x	6
	TDS	x	x	x	x	x	x	6
Appendix IV Parameters	Antimony							0
	Arsenic							0
	Barium							0
	Beryllium							0
	Cadmium							0
	Chromium							0
	Cobalt							0
	Fluoride							0
	Lead							0
	Lithium							0
	Mercury							0
	Molybdenum							0
	Selenium							0
	Thallium							0
	Radium							0
Field Parameters	Groundwater Elevation	x	x	x	x	x		5
	Well Depth	x	x	x	x	x		5
	pH (field)	x	x	x	x	x		5
	Specific Conductance	x	x	x	x	x		5
	Dissolved Oxygen	x	x	x	x	x		5
	ORP	x	x	x	x	x		5
	Temperature	x	x	x	x	x		5
	Turbidity	x	x	x	x	x		5
	Color	x	x	x	x	x		5
	Odor	x	x	x	x	x		5

Notes: All samples are unfiltered (total).

I:\25223073 00\Data and Calculations\Field Work Requests\[OML_CCR_Rule_Sampling_Detection.xls]Sheet1

Login Sample Receipt Checklist

Client: SCS Engineers

Job Number: 310-267271-1

Login Number: 267271

List Source: Eurofins Cedar Falls

List Number: 1

Creator: Homolar, Dana J

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	True	
Sample custody seals, if present, are intact.	N/A	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Groundwater Monitoring Results - Field Parameters
Ottumwa Midland Landfill / SCS Engineers Project #25223073.00
October 2023

Sample	Date	Groundwater Elevation (ft. amsl)	Temperature (Deg. C)	pH (Std. Units)	DO (mg/L)	Specific Conductivity ($\mu\text{mhos}/\text{cm}$)	ORP (mV)	Turbidity (NTU)
MW-301	10/11/2023	684.55	13.4	6.74	0.39	1,562	-97.3	6.55
MW-302	10/11/2023	684.12	13.6	7.24	0.44	1,129	-100.9	68.96
MW-303	10/11/2023	684.95	14.1	6.81	0.55	1,617	-85.7	64.61
MW-102M	10/11/2023	720.93	20.0	7.73	6.39	2,272.0	8.4	17.31
MW-122M	10/11/2023	707.90	--	--	--	--	--	--

note - MW-122M field parameters not collected

Abbreviations:

amsl = above mean sea level

mg/L = milligrams per liter

$\mu\text{mhos}/\text{cm}$ = microSiemens per centimeter

NM = not measured.

Laboratory Notes/Qualifiers:

none

Created by: EMS
Last revision by: RM
Checked by: NLB

Date: 4/13/2023
Date: 10/24/2023
Date: 10/25/2023

C:\Users\hld0\AppData\Local\Microsoft\Windows\INetCache\Content.Outlook\USG3GGC\[2310_OML_GW_Field Data.xlsx]GW Field Data

ANALYTICAL REPORT

PREPARED FOR

Attn: Meghan Blodgett
SCS Engineers
2830 Dairy Drive
Madison, Wisconsin 53718

Generated 4/22/2024 8:43:46 AM

JOB DESCRIPTION

Ottumwa Midland Landfill 25224073

JOB NUMBER

310-278396-1

Eurofins Cedar Falls

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Environment Testing North Central, LLC Project Manager.

Authorization



Generated
4/22/2024 8:43:46 AM

Authorized for release by
Sandie Fredrick, Senior Project Manager
Sandra.Fredrick@et.eurofinsus.com
(920)261-1660

Table of Contents

Cover Page	1
Table of Contents	3
Case Narrative	4
Sample Summary	5
Detection Summary	6
Client Sample Results	8
Definitions	14
QC Sample Results	15
QC Association	18
Chronicle	20
Certification Summary	22
Method Summary	23
Chain of Custody	24
Receipt Checklists	26
Field Data Sheets	27

Case Narrative

Client: SCS Engineers
Project: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Job ID: 310-278396-1

Eurofins Cedar Falls

Job Narrative 310-278396-1

Receipt

The samples were received on 4/5/2024 4:40 PM. Unless otherwise noted below, the samples arrived in good condition, and where required, properly preserved and on ice. The temperature of the cooler at receipt was 2.1° C.

HPLC/IC

Method 9056A: The following sample was diluted due to the nature of the sample matrix: MW-122M (310-278396-5). Elevated reporting limits (RLs) are provided.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

Metals

Method 3005A: The reference method requires samples to be preserved to a pH of <2. The following sample was received with insufficient preservation at a pH of >2: MW-122M (310-278396-5). The sample(s) was preserved to the appropriate pH in the laboratory.

No additional analytical or quality issues were noted, other than those described above or in the Definitions/Glossary page.

General Chemistry

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Eurofins Cedar Falls

Sample Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
310-278396-1	MW-301	Water	04/04/24 09:00	04/05/24 16:40
310-278396-2	MW-302	Water	04/03/24 09:25	04/05/24 16:40
310-278396-3	MW-303	Water	04/03/24 10:30	04/05/24 16:40
310-278396-4	MW-102M	Water	04/04/24 08:20	04/05/24 16:40
310-278396-5	MW-122M	Water	04/04/24 08:00	04/05/24 16:40
310-278396-6	Field Blank	Water	04/04/24 09:30	04/05/24 16:40

Detection Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Client Sample ID: MW-301

Lab Sample ID: 310-278396-1

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloride	22		5.0	2.3	mg/L	5		9056A	Total/NA
Fluoride	0.77	J	1.0	0.38	mg/L	5		9056A	Total/NA
Sulfate	310		5.0	2.1	mg/L	5		9056A	Total/NA
Boron	770		100	76	ug/L	1		6020B	Total/NA
Calcium	110		0.50	0.19	mg/L	1		6020B	Total/NA
Total Dissolved Solids	850		50	34	mg/L	1		SM 2540C	Total/NA
pH	6.6	HF	1.0	1.0	SU	1		SM 4500 H+ B	Total/NA
Groundwater Elevation	684.96				ft	1		Field Sampling	Total/NA
Oxidation Reduction Potential	-92.7				mV	1		Field Sampling	Total/NA
Oxygen, Dissolved	0.44				mg/L	1		Field Sampling	Total/NA
Field pH	6.66				SU	1		Field Sampling	Total/NA
Field Conductivity	1332				umhos/cm	1		Field Sampling	Total/NA
Field Temperature	12.2				Degrees C	1		Field Sampling	Total/NA
Field Turbidity	14.94				NTU	1		Field Sampling	Total/NA

Client Sample ID: MW-302

Lab Sample ID: 310-278396-2

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloride	6.2		5.0	2.3	mg/L	5		9056A	Total/NA
Fluoride	1.1		1.0	0.38	mg/L	5		9056A	Total/NA
Sulfate	73		5.0	2.1	mg/L	5		9056A	Total/NA
Boron	840		100	76	ug/L	1		6020B	Total/NA
Calcium	45		0.50	0.19	mg/L	1		6020B	Total/NA
Total Dissolved Solids	630		50	34	mg/L	1		SM 2540C	Total/NA
pH	7.2	HF	1.0	1.0	SU	1		SM 4500 H+ B	Total/NA
Groundwater Elevation	684.00				ft	1		Field Sampling	Total/NA
Oxidation Reduction Potential	-111.0				mV	1		Field Sampling	Total/NA
Oxygen, Dissolved	0.60				mg/L	1		Field Sampling	Total/NA
Field pH	7.15				SU	1		Field Sampling	Total/NA
Field Conductivity	1009				umhos/cm	1		Field Sampling	Total/NA
Field Temperature	12.0				Degrees C	1		Field Sampling	Total/NA
Field Turbidity	37.92				NTU	1		Field Sampling	Total/NA

Client Sample ID: MW-303

Lab Sample ID: 310-278396-3

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloride	8.1		5.0	2.3	mg/L	5		9056A	Total/NA
Fluoride	0.70	J	1.0	0.38	mg/L	5		9056A	Total/NA
Sulfate	300		5.0	2.1	mg/L	5		9056A	Total/NA
Boron	760		100	76	ug/L	1		6020B	Total/NA
Calcium	110		0.50	0.19	mg/L	1		6020B	Total/NA
Total Dissolved Solids	890		50	34	mg/L	1		SM 2540C	Total/NA
pH	6.9	HF	1.0	1.0	SU	1		SM 4500 H+ B	Total/NA
Groundwater Elevation	684.82				ft	1		Field Sampling	Total/NA
Oxidation Reduction Potential	-92.5				mV	1		Field Sampling	Total/NA
Oxygen, Dissolved	0.46				mg/L	1		Field Sampling	Total/NA
Field pH	6.73				SU	1		Field Sampling	Total/NA
Field Conductivity	1458				umhos/cm	1		Field Sampling	Total/NA
Field Temperature	12.3				Degrees C	1		Field Sampling	Total/NA
Field Turbidity	102.35				NTU	1		Field Sampling	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Cedar Falls

Detection Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Client Sample ID: MW-102M

Lab Sample ID: 310-278396-4

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloride	31		5.0	2.3	mg/L	5		9056A	Total/NA
Fluoride	4.5		1.0	0.38	mg/L	5		9056A	Total/NA
Sulfate	430		5.0	2.1	mg/L	5		9056A	Total/NA
Boron	1500		100	76	ug/L	1		6020B	Total/NA
Calcium	15		0.50	0.19	mg/L	1		6020B	Total/NA
Total Dissolved Solids	1500		50	34	mg/L	1		SM 2540C	Total/NA
pH	7.7 HF		1.0	1.0	SU	1		SM 4500 H+ B	Total/NA
Groundwater Elevation	709.84				ft	1		Field Sampling	Total/NA
Oxidation Reduction Potential	-53.5				mV	1		Field Sampling	Total/NA
Oxygen, Dissolved	8.80				mg/L	1		Field Sampling	Total/NA
Field pH	7.61				SU	1		Field Sampling	Total/NA
Field Conductivity	2095				umhos/cm	1		Field Sampling	Total/NA
Field Temperature	8.9				Degrees C	1		Field Sampling	Total/NA
Field Turbidity	20.43				NTU	1		Field Sampling	Total/NA

Client Sample ID: MW-122M

Lab Sample ID: 310-278396-5

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
Chloride	8.6		5.0	2.3	mg/L	5		9056A	Total/NA
Sulfate	9000		200	84	mg/L	200		9056A	Total/NA
Boron	5500		400	300	ug/L	4		6020B	Total/NA
Calcium	450		2.0	0.76	mg/L	4		6020B	Total/NA
Groundwater Elevation	700.90				ft	1		Field Sampling	Total/NA
Oxidation Reduction Potential	-36.6				mV	1		Field Sampling	Total/NA
Oxygen, Dissolved	9.58				mg/L	1		Field Sampling	Total/NA
Field pH	7.04				SU	1		Field Sampling	Total/NA
Field Conductivity	13249				umhos/cm	1		Field Sampling	Total/NA
Field Temperature	7.3				Degrees C	1		Field Sampling	Total/NA
Field Turbidity	33.24				NTU	1		Field Sampling	Total/NA

Client Sample ID: Field Blank

Lab Sample ID: 310-278396-6

Analyte	Result	Qualifier	RL	MDL	Unit	Dil Fac	D	Method	Prep Type
pH	5.9 HF		1.0	1.0	SU	1		SM 4500 H+ B	Total/NA

This Detection Summary does not include radiochemical test results.

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Job ID: 310-278396-1

Project/Site: Ottumwa Midland Landfill 25224073

Client Sample ID: MW-301

Lab Sample ID: 310-278396-1

Date Collected: 04/04/24 09:00

Matrix: Water

Date Received: 04/05/24 16:40

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	22		5.0	2.3	mg/L			04/12/24 14:28	5
Fluoride	0.77	J	1.0	0.38	mg/L			04/12/24 14:28	5
Sulfate	310		5.0	2.1	mg/L			04/12/24 14:28	5

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	770		100	76	ug/L			04/09/24 09:00	04/15/24 14:56
Calcium	110		0.50	0.19	mg/L			04/09/24 09:00	04/12/24 17:10

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids (SM 2540C)	850		50	34	mg/L			04/09/24 11:50	1
pH (SM 4500 H+ B)	6.6	HF	1.0	1.0	SU			04/05/24 17:44	1

Method: EPA Field Sampling - Field Sampling

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Groundwater Elevation	684.96				ft			04/04/24 09:00	1
Oxidation Reduction Potential	-92.7				mV			04/04/24 09:00	1
Oxygen, Dissolved	0.44				mg/L			04/04/24 09:00	1
Field pH	6.66				SU			04/04/24 09:00	1
Field Conductivity	1332				umhos/cm			04/04/24 09:00	1
Field Temperature	12.2				Degrees C			04/04/24 09:00	1
Field Turbidity	14.94				NTU			04/04/24 09:00	1

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Job ID: 310-278396-1

Project/Site: Ottumwa Midland Landfill 25224073

Client Sample ID: MW-302

Lab Sample ID: 310-278396-2

Matrix: Water

Date Collected: 04/03/24 09:25

Date Received: 04/05/24 16:40

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	6.2		5.0	2.3	mg/L			04/11/24 18:57	5
Fluoride	1.1		1.0	0.38	mg/L			04/11/24 18:57	5
Sulfate	73		5.0	2.1	mg/L			04/11/24 18:57	5

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	840		100	76	ug/L		04/09/24 09:00	04/15/24 14:58	1
Calcium	45		0.50	0.19	mg/L		04/09/24 09:00	04/12/24 17:12	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids (SM 2540C)	630		50	34	mg/L			04/08/24 15:53	1
pH (SM 4500 H+ B)	7.2	HF	1.0	1.0	SU			04/05/24 17:44	1

Method: EPA Field Sampling - Field Sampling

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Groundwater Elevation	684.00				ft			04/03/24 09:25	1
Oxidation Reduction Potential	-111.0				mV			04/03/24 09:25	1
Oxygen, Dissolved	0.60				mg/L			04/03/24 09:25	1
Field pH	7.15				SU			04/03/24 09:25	1
Field Conductivity	1009				umhos/cm			04/03/24 09:25	1
Field Temperature	12.0				Degrees C			04/03/24 09:25	1
Field Turbidity	37.92				NTU			04/03/24 09:25	1

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Job ID: 310-278396-1

Project/Site: Ottumwa Midland Landfill 25224073

Client Sample ID: MW-303

Lab Sample ID: 310-278396-3

Date Collected: 04/03/24 10:30

Matrix: Water

Date Received: 04/05/24 16:40

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	8.1		5.0	2.3	mg/L			04/11/24 19:35	5
Fluoride	0.70	J	1.0	0.38	mg/L			04/11/24 19:35	5
Sulfate	300		5.0	2.1	mg/L			04/11/24 19:35	5

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	760		100	76	ug/L		04/09/24 09:00	04/15/24 15:00	1
Calcium	110		0.50	0.19	mg/L		04/09/24 09:00	04/12/24 17:24	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids (SM 2540C)	890		50	34	mg/L			04/08/24 15:53	1
pH (SM 4500 H+ B)	6.9	HF	1.0	1.0	SU			04/05/24 19:02	1

Method: EPA Field Sampling - Field Sampling

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Groundwater Elevation	684.82				ft			04/03/24 10:30	1
Oxidation Reduction Potential	-92.5				mV			04/03/24 10:30	1
Oxygen, Dissolved	0.46				mg/L			04/03/24 10:30	1
Field pH	6.73				SU			04/03/24 10:30	1
Field Conductivity	1458				umhos/cm			04/03/24 10:30	1
Field Temperature	12.3				Degrees C			04/03/24 10:30	1
Field Turbidity	102.35				NTU			04/03/24 10:30	1

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Client Sample ID: MW-102M

Lab Sample ID: 310-278396-4

Matrix: Water

Date Collected: 04/04/24 08:20

Date Received: 04/05/24 16:40

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	31		5.0	2.3	mg/L			04/12/24 14:40	5
Fluoride	4.5		1.0	0.38	mg/L			04/12/24 14:40	5
Sulfate	430		5.0	2.1	mg/L			04/12/24 14:40	5

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	1500		100	76	ug/L			04/09/24 09:00	04/15/24 15:02
Calcium	15		0.50	0.19	mg/L			04/09/24 09:00	04/12/24 17:26

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids (SM 2540C)	1500		50	34	mg/L			04/09/24 11:50	1
pH (SM 4500 H+ B)	7.7	HF	1.0	1.0	SU			04/05/24 19:11	1

Method: EPA Field Sampling - Field Sampling

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Groundwater Elevation	709.84				ft			04/04/24 08:20	1
Oxidation Reduction Potential	-53.5				mV			04/04/24 08:20	1
Oxygen, Dissolved	8.80				mg/L			04/04/24 08:20	1
Field pH	7.61				SU			04/04/24 08:20	1
Field Conductivity	2095				umhos/cm			04/04/24 08:20	1
Field Temperature	8.9				Degrees C			04/04/24 08:20	1
Field Turbidity	20.43				NTU			04/04/24 08:20	1

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Client Sample ID: MW-122M

Lab Sample ID: 310-278396-5

Matrix: Water

Date Collected: 04/04/24 08:00

Date Received: 04/05/24 16:40

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	8.6		5.0	2.3	mg/L			04/12/24 14:52	5
Fluoride	<0.38		1.0	0.38	mg/L			04/12/24 14:52	5
Sulfate	9000		200	84	mg/L			04/15/24 10:44	200

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	5500		400	300	ug/L			04/15/24 15:05	4
Calcium	450		2.0	0.76	mg/L			04/15/24 15:05	4

Method: EPA Field Sampling - Field Sampling

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Groundwater Elevation	700.90				ft			04/04/24 08:00	1
Oxidation Reduction Potential	-36.6				mV			04/04/24 08:00	1
Oxygen, Dissolved	9.58				mg/L			04/04/24 08:00	1
Field pH	7.04				SU			04/04/24 08:00	1
Field Conductivity	13249				umhos/cm			04/04/24 08:00	1
Field Temperature	7.3				Degrees C			04/04/24 08:00	1
Field Turbidity	33.24				NTU			04/04/24 08:00	1

Eurofins Cedar Falls

Client Sample Results

Client: SCS Engineers

Job ID: 310-278396-1

Project/Site: Ottumwa Midland Landfill 25224073

Client Sample ID: Field Blank**Lab Sample ID: 310-278396-6**

Matrix: Water

Date Collected: 04/04/24 09:30

Date Received: 04/05/24 16:40

Method: SW846 9056A - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	<0.45		1.0	0.45	mg/L			04/12/24 15:04	1
Fluoride	<0.075		0.20	0.075	mg/L			04/12/24 15:04	1
Sulfate	<0.42		1.0	0.42	mg/L			04/15/24 10:32	1

Method: SW846 6020B - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	<76		100	76	ug/L		04/09/24 09:00	04/15/24 15:07	1
Calcium	<0.19		0.50	0.19	mg/L		04/09/24 09:00	04/12/24 17:31	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids (SM 2540C)	<34		50	34	mg/L			04/09/24 11:50	1
pH (SM 4500 H+ B)	5.9	HF	1.0	1.0	SU			04/05/24 18:58	1

Eurofins Cedar Falls

Definitions/Glossary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Qualifiers

HPLC/IC

Qualifier	Qualifier Description
J	Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

General Chemistry

Qualifier	Qualifier Description
HF	Parameter with a holding time of 15 minutes. Test performed by laboratory at client's request. Sample was analyzed outside of hold time.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
☒	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

QC Sample Results

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Method: 9056A - Anions, Ion Chromatography

Lab Sample ID: MB 310-418642/3

Matrix: Water

Analysis Batch: 418642

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	<0.45		1.0	0.45	mg/L			04/11/24 13:42	1
Fluoride	<0.075		0.20	0.075	mg/L			04/11/24 13:42	1
Sulfate	<0.42		1.0	0.42	mg/L			04/11/24 13:42	1

Lab Sample ID: LCS 310-418642/4

Matrix: Water

Analysis Batch: 418642

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte		Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride		10.0	10.1		mg/L		101	90 - 110
Fluoride		2.00	2.12		mg/L		106	90 - 110
Sulfate		10.0	10.9		mg/L		109	90 - 110

Lab Sample ID: MB 310-418758/3

Matrix: Water

Analysis Batch: 418758

Client Sample ID: Method Blank
Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	<0.45		1.0	0.45	mg/L			04/12/24 11:05	1
Fluoride	<0.075		0.20	0.075	mg/L			04/12/24 11:05	1
Sulfate	<0.42		1.0	0.42	mg/L			04/12/24 11:05	1

Lab Sample ID: LCS 310-418758/4

Matrix: Water

Analysis Batch: 418758

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte		Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Chloride		10.0	10.1		mg/L		101	90 - 110
Fluoride		2.00	2.20		mg/L		110	90 - 110
Sulfate		10.0	10.6		mg/L		106	90 - 110

Method: 6020B - Metals (ICP/MS)

Lab Sample ID: MB 310-418157/1-A

Matrix: Water

Analysis Batch: 418695

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 418157

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Calcium	<0.19		0.50	0.19	mg/L			04/09/24 09:00	04/12/24 16:06

Lab Sample ID: MB 310-418157/1-A

Matrix: Water

Analysis Batch: 418822

Client Sample ID: Method Blank
Prep Type: Total/NA
Prep Batch: 418157

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Boron	<76		100	76	ug/L			04/09/24 09:00	04/15/24 14:09

Eurofins Cedar Falls

QC Sample Results

Client: SCS Engineers

Job ID: 310-278396-1

Project/Site: Ottumwa Midland Landfill 25224073

Method: 6020B - Metals (ICP/MS) (Continued)

Lab Sample ID: LCS 310-418157/2-A

Matrix: Water

Analysis Batch: 418695

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 418157

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Calcium	2.00	1.81		mg/L	91	80 - 120	

Lab Sample ID: LCS 310-418157/2-A

Matrix: Water

Analysis Batch: 418822

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Prep Batch: 418157

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Boron	200	205		ug/L	103	80 - 120	

Method: SM 2540C - Solids, Total Dissolved (TDS)

Lab Sample ID: MB 310-418158/1

Matrix: Water

Analysis Batch: 418158

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids	<34		50	34	mg/L			04/08/24 15:53	1

Lab Sample ID: LCS 310-418158/2

Matrix: Water

Analysis Batch: 418158

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Total Dissolved Solids	1000	950		mg/L	95	90 - 110	

Lab Sample ID: MB 310-418249/1

Matrix: Water

Analysis Batch: 418249

Client Sample ID: Method Blank

Prep Type: Total/NA

Analyte	MB Result	MB Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Dissolved Solids	<34		50	34	mg/L			04/09/24 11:50	1

Lab Sample ID: LCS 310-418249/2

Matrix: Water

Analysis Batch: 418249

Client Sample ID: Lab Control Sample

Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
Total Dissolved Solids	1000	920		mg/L	92	90 - 110	

Lab Sample ID: 310-278396-1 DU

Matrix: Water

Analysis Batch: 418249

Client Sample ID: MW-301

Prep Type: Total/NA

Analyte	Sample Result	Sample Qualifier	DU Result	DU Qualifier	Unit	D	RPD	RPD Limit
Total Dissolved Solids	850		864		mg/L		1	20

Eurofins Cedar Falls

QC Sample Results

Client: SCS Engineers

Job ID: 310-278396-1

Project/Site: Ottumwa Midland Landfill 25224073

Method: SM 4500 H+ B - pH

Lab Sample ID: LCS 310-418046/1

Matrix: Water

Analysis Batch: 418046

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
pH	7.00	7.0		SU		100	98 - 102

Lab Sample ID: LCS 310-418076/1

Matrix: Water

Analysis Batch: 418076

Client Sample ID: Lab Control Sample
Prep Type: Total/NA

Analyte	Spike Added	LCS Result	LCS Qualifier	Unit	D	%Rec	%Rec Limits
pH	7.00	7.0		SU		100	98 - 102

Eurofins Cedar Falls

QC Association Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

HPLC/IC

Analysis Batch: 418642

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-278396-2	MW-302	Total/NA	Water	9056A	
310-278396-3	MW-303	Total/NA	Water	9056A	
MB 310-418642/3	Method Blank	Total/NA	Water	9056A	
LCS 310-418642/4	Lab Control Sample	Total/NA	Water	9056A	

Analysis Batch: 418758

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-278396-1	MW-301	Total/NA	Water	9056A	
310-278396-4	MW-102M	Total/NA	Water	9056A	
310-278396-5	MW-122M	Total/NA	Water	9056A	
310-278396-5	MW-122M	Total/NA	Water	9056A	
310-278396-6	Field Blank	Total/NA	Water	9056A	
310-278396-6	Field Blank	Total/NA	Water	9056A	
MB 310-418758/3	Method Blank	Total/NA	Water	9056A	
LCS 310-418758/4	Lab Control Sample	Total/NA	Water	9056A	

Metals

Prep Batch: 418157

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-278396-1	MW-301	Total/NA	Water	3005A	
310-278396-2	MW-302	Total/NA	Water	3005A	
310-278396-3	MW-303	Total/NA	Water	3005A	
310-278396-4	MW-102M	Total/NA	Water	3005A	
310-278396-5	MW-122M	Total/NA	Water	3005A	
310-278396-6	Field Blank	Total/NA	Water	3005A	
MB 310-418157/1-A	Method Blank	Total/NA	Water	3005A	
LCS 310-418157/2-A	Lab Control Sample	Total/NA	Water	3005A	

Analysis Batch: 418695

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-278396-1	MW-301	Total/NA	Water	6020B	418157
310-278396-2	MW-302	Total/NA	Water	6020B	418157
310-278396-3	MW-303	Total/NA	Water	6020B	418157
310-278396-4	MW-102M	Total/NA	Water	6020B	418157
310-278396-6	Field Blank	Total/NA	Water	6020B	418157
MB 310-418157/1-A	Method Blank	Total/NA	Water	6020B	418157
LCS 310-418157/2-A	Lab Control Sample	Total/NA	Water	6020B	418157

Analysis Batch: 418822

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-278396-1	MW-301	Total/NA	Water	6020B	418157
310-278396-2	MW-302	Total/NA	Water	6020B	418157
310-278396-3	MW-303	Total/NA	Water	6020B	418157
310-278396-4	MW-102M	Total/NA	Water	6020B	418157
310-278396-5	MW-122M	Total/NA	Water	6020B	418157
310-278396-6	Field Blank	Total/NA	Water	6020B	418157
MB 310-418157/1-A	Method Blank	Total/NA	Water	6020B	418157
LCS 310-418157/2-A	Lab Control Sample	Total/NA	Water	6020B	418157

Eurofins Cedar Falls

QC Association Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

General Chemistry

Analysis Batch: 418046

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-278396-1	MW-301	Total/NA	Water	SM 4500 H+ B	
310-278396-2	MW-302	Total/NA	Water	SM 4500 H+ B	
LCS 310-418046/1	Lab Control Sample	Total/NA	Water	SM 4500 H+ B	

Analysis Batch: 418076

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-278396-3	MW-303	Total/NA	Water	SM 4500 H+ B	
310-278396-4	MW-102M	Total/NA	Water	SM 4500 H+ B	
310-278396-6	Field Blank	Total/NA	Water	SM 4500 H+ B	
LCS 310-418076/1	Lab Control Sample	Total/NA	Water	SM 4500 H+ B	

Analysis Batch: 418158

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-278396-2	MW-302	Total/NA	Water	SM 2540C	
310-278396-3	MW-303	Total/NA	Water	SM 2540C	
MB 310-418158/1	Method Blank	Total/NA	Water	SM 2540C	
LCS 310-418158/2	Lab Control Sample	Total/NA	Water	SM 2540C	

Analysis Batch: 418249

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-278396-1	MW-301	Total/NA	Water	SM 2540C	
310-278396-4	MW-102M	Total/NA	Water	SM 2540C	
310-278396-6	Field Blank	Total/NA	Water	SM 2540C	
MB 310-418249/1	Method Blank	Total/NA	Water	SM 2540C	
LCS 310-418249/2	Lab Control Sample	Total/NA	Water	SM 2540C	
310-278396-1 DU	MW-301	Total/NA	Water	SM 2540C	

Field Service / Mobile Lab

Analysis Batch: 418836

Lab Sample ID	Client Sample ID	Prep Type	Matrix	Method	Prep Batch
310-278396-1	MW-301	Total/NA	Water	Field Sampling	
310-278396-2	MW-302	Total/NA	Water	Field Sampling	
310-278396-3	MW-303	Total/NA	Water	Field Sampling	
310-278396-4	MW-102M	Total/NA	Water	Field Sampling	
310-278396-5	MW-122M	Total/NA	Water	Field Sampling	

Eurofins Cedar Falls

Lab Chronicle

Client: SCS Engineers
Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Client Sample ID: MW-301
Date Collected: 04/04/24 09:00
Date Received: 04/05/24 16:40

Lab Sample ID: 310-278396-1
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		5	418758	QTZ5	EET CF	04/12/24 14:28
Total/NA	Prep	3005A			418157	QTZ5	EET CF	04/09/24 09:00
Total/NA	Analysis	6020B		1	418695	NFT2	EET CF	04/12/24 17:10
Total/NA	Prep	3005A			418157	QTZ5	EET CF	04/09/24 09:00
Total/NA	Analysis	6020B		1	418822	NFT2	EET CF	04/15/24 14:56
Total/NA	Analysis	SM 2540C		1	418249	DGU1	EET CF	04/09/24 11:50
Total/NA	Analysis	SM 4500 H+ B		1	418046	A3GU	EET CF	04/05/24 17:44
Total/NA	Analysis	Field Sampling		1	418836	BJ0R	EET CF	04/04/24 09:00

Client Sample ID: MW-302
Date Collected: 04/03/24 09:25
Date Received: 04/05/24 16:40

Lab Sample ID: 310-278396-2
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		5	418642	QTZ5	EET CF	04/11/24 18:57
Total/NA	Prep	3005A			418157	QTZ5	EET CF	04/09/24 09:00
Total/NA	Analysis	6020B		1	418695	NFT2	EET CF	04/12/24 17:12
Total/NA	Prep	3005A			418157	QTZ5	EET CF	04/09/24 09:00
Total/NA	Analysis	6020B		1	418822	NFT2	EET CF	04/15/24 14:58
Total/NA	Analysis	SM 2540C		1	418158	D7CP	EET CF	04/08/24 15:53
Total/NA	Analysis	SM 4500 H+ B		1	418046	A3GU	EET CF	04/05/24 17:44
Total/NA	Analysis	Field Sampling		1	418836	BJ0R	EET CF	04/03/24 09:25

Client Sample ID: MW-303
Date Collected: 04/03/24 10:30
Date Received: 04/05/24 16:40

Lab Sample ID: 310-278396-3
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		5	418642	QTZ5	EET CF	04/11/24 19:35
Total/NA	Prep	3005A			418157	QTZ5	EET CF	04/09/24 09:00
Total/NA	Analysis	6020B		1	418695	NFT2	EET CF	04/12/24 17:24
Total/NA	Prep	3005A			418157	QTZ5	EET CF	04/09/24 09:00
Total/NA	Analysis	6020B		1	418822	NFT2	EET CF	04/15/24 15:00
Total/NA	Analysis	SM 2540C		1	418158	D7CP	EET CF	04/08/24 15:53
Total/NA	Analysis	SM 4500 H+ B		1	418076	D7CP	EET CF	04/05/24 19:02
Total/NA	Analysis	Field Sampling		1	418836	BJ0R	EET CF	04/03/24 10:30

Client Sample ID: MW-102M
Date Collected: 04/04/24 08:20
Date Received: 04/05/24 16:40

Lab Sample ID: 310-278396-4
Matrix: Water

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		5	418758	QTZ5	EET CF	04/12/24 14:40

Eurofins Cedar Falls

Lab Chronicle

Client: SCS Engineers
Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Client Sample ID: MW-102M

Lab Sample ID: 310-278396-4

Matrix: Water

Date Collected: 04/04/24 08:20

Date Received: 04/05/24 16:40

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Prep	3005A			418157	QTZ5	EET CF	04/09/24 09:00
Total/NA	Analysis	6020B		1	418695	NFT2	EET CF	04/12/24 17:26
Total/NA	Prep	3005A			418157	QTZ5	EET CF	04/09/24 09:00
Total/NA	Analysis	6020B		1	418822	NFT2	EET CF	04/15/24 15:02
Total/NA	Analysis	SM 2540C		1	418249	DGU1	EET CF	04/09/24 11:50
Total/NA	Analysis	SM 4500 H+ B		1	418076	D7CP	EET CF	04/05/24 19:11
Total/NA	Analysis	Field Sampling		1	418836	BJ0R	EET CF	04/04/24 08:20

Client Sample ID: MW-122M

Lab Sample ID: 310-278396-5

Matrix: Water

Date Collected: 04/04/24 08:00

Date Received: 04/05/24 16:40

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		5	418758	QTZ5	EET CF	04/12/24 14:52
Total/NA	Analysis	9056A		200	418758	QTZ5	EET CF	04/15/24 10:44
Total/NA	Prep	3005A			418157	QTZ5	EET CF	04/09/24 09:00
Total/NA	Analysis	6020B		4	418822	NFT2	EET CF	04/15/24 15:05
Total/NA	Analysis	Field Sampling		1	418836	BJ0R	EET CF	04/04/24 08:00

Client Sample ID: Field Blank

Lab Sample ID: 310-278396-6

Matrix: Water

Date Collected: 04/04/24 09:30

Date Received: 04/05/24 16:40

Prep Type	Batch Type	Batch Method	Run	Dilution Factor	Batch Number	Analyst	Lab	Prepared or Analyzed
Total/NA	Analysis	9056A		1	418758	QTZ5	EET CF	04/12/24 15:04
Total/NA	Analysis	9056A		1	418758	QTZ5	EET CF	04/15/24 10:32
Total/NA	Prep	3005A			418157	QTZ5	EET CF	04/09/24 09:00
Total/NA	Analysis	6020B		1	418695	NFT2	EET CF	04/12/24 17:31
Total/NA	Prep	3005A			418157	QTZ5	EET CF	04/09/24 09:00
Total/NA	Analysis	6020B		1	418822	NFT2	EET CF	04/15/24 15:07
Total/NA	Analysis	SM 2540C		1	418249	DGU1	EET CF	04/09/24 11:50
Total/NA	Analysis	SM 4500 H+ B		1	418076	D7CP	EET CF	04/05/24 18:58

Laboratory References:

EET CF = Eurofins Cedar Falls, 3019 Venture Way, Cedar Falls, IA 50613, TEL (319)277-2401

Eurofins Cedar Falls

Accreditation/Certification Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Laboratory: Eurofins Cedar Falls

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Iowa	State	007	12-01-25

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Eurofins Cedar Falls

Method Summary

Client: SCS Engineers

Project/Site: Ottumwa Midland Landfill 25224073

Job ID: 310-278396-1

Method	Method Description	Protocol	Laboratory
9056A	Anions, Ion Chromatography	SW846	EET CF
6020B	Metals (ICP/MS)	SW846	EET CF
SM 2540C	Solids, Total Dissolved (TDS)	SM	EET CF
SM 4500 H+ B	pH	SM	EET CF
Field Sampling	Field Sampling	EPA	EET CF
3005A	Preparation, Total Metals	SW846	EET CF

Protocol References:

EPA = US Environmental Protection Agency

SM = "Standard Methods For The Examination Of Water And Wastewater"

SW846 = "Test Methods For Evaluating Solid Waste, Physical/Chemical Methods", Third Edition, November 1986 And Its Updates.

Laboratory References:

EET CF = Eurofins Cedar Falls, 3019 Venture Way, Cedar Falls, IA 50613, TEL (319)277-2401

Eurofins Cedar Falls

Environment Testing
America

310-278396 Chain of Custody

Cooler/Sample Receipt and Temperature L

Client Information			
Client: SCS			
City/State:	CITY	STATE	Project:
Receipt Information			
Date/Time Received:	DATE 4-5-24	TIME 1640	Received By: MV
Delivery Type:	<input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input type="checkbox"/> FedEx Ground <input type="checkbox"/> US Mail <input type="checkbox"/> Spee-Dee <input checked="" type="checkbox"/> Lab Courier <input type="checkbox"/> Lab Field Services <input type="checkbox"/> Client Drop-off <input type="checkbox"/> Other: _____		
Condition of Cooler/Containers			
Sample(s) received in Cooler?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	If yes: Cooler ID: _____
Multiple Coolers?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	If yes: Cooler # _____ of _____
Cooler Custody Seals Present? No	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	If yes: Cooler custody seals intact? <input type="checkbox"/> Yes <input type="checkbox"/>
Sample Custody Seals Present? No	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	If yes: Sample custody seals intact? <input type="checkbox"/> Yes <input type="checkbox"/>
Trip Blank Present?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	If yes: Which VOA samples are in cooler? ↓ _____
Temperature Record			
Coolant:	<input checked="" type="checkbox"/> Wet ice	<input type="checkbox"/> Blue ice	<input type="checkbox"/> Dry ice <input type="checkbox"/> Other: _____ <input type="checkbox"/> NONE
Thermometer ID:	T	Correction Factor (°C): O	
• Temp Blank Temperature – If no temp blank, or temp blank temperature above criteria, proceed to Sample Container Temperature			
Uncorrected Temp (°C):	2.1	Corrected Temp (°C): 2.1	
• Sample Container Temperature			
Container(s) used:	CONTAINER 1		CONTAINER 2
Uncorrected Temp (°C):			
Corrected Temp (°C):			
Exceptions Noted			
1) If temperature exceeds criteria, was sample(s) received same day of sampling? <input type="checkbox"/> Yes <input type="checkbox"/> No a) If yes: Is there evidence that the chilling process began? <input type="checkbox"/> Yes <input type="checkbox"/> No			
2) If temperature is <0°C, are there obvious signs that the integrity of sample containers is compromised? (e.g., bulging septa, broken/cracked bottles, frozen solid?) <input type="checkbox"/> Yes <input type="checkbox"/> No			
NOTE If yes, contact PM before proceeding. If no, proceed with login			
Additional Comments			

Login Sample Receipt Checklist

Client: SCS Engineers

Job Number: 310-278396-1

SDG Number:

Login Number: 278396

List Source: Eurofins Cedar Falls

List Number: 1

Creator: Muehling, Angela C

Question	Answer	Comment
Radioactivity wasn't checked or is </= background as measured by a survey meter.	N/A	
The cooler's custody seal, if present, is intact.	N/A	
Sample custody seals, if present, are intact.	N/A	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is acceptable.	True	
Cooler Temperature is recorded.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
Is the Field Sampler's name present on COC?	True	
There are no discrepancies between the containers received and the COC.	True	
Samples are received within Holding Time (excluding tests with immediate HTs)	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
Sample Preservation Verified.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
Containers requiring zero headspace have no headspace or bubble is <6mm (1/4").	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	
Residual Chlorine Checked.	N/A	

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

Groundwater Monitoring Results - Field Parameters
Ottumwa Midland Landfill / SCS Engineers Project #25224073.00
April 2024

Sample	Date	Groundwater Elevation (ft. amsl)	Temperature (Deg. C)	pH (Std. Units)	DO (mg/L)	Specific Conductivity ($\mu\text{mhos}/\text{cm}$)	ORP (mV)	Turbidity (NTU)
MW-301	4/4/2024	684.96	12.2	6.66	0.44	1,332	-92.7	14.94
MW-302	4/3/2024	684.00	12.0	7.15	0.60	1,009	-111.0	37.92
MW-303	4/3/2024	684.82	12.3	6.73	0.46	1,458	-92.5	102.35
MW-102M	4/4/2024	709.84	8.9	7.61	8.80	2,095	-53.5	20.43
MW-122M	4/4/2024	700.90	7.3	7.04	9.58	13,249	-36.6	33.24

Abbreviations:

ft amsl = feet above mean sea level

mg/L = milligrams per liter

$\mu\text{mhos}/\text{cm}$ = microhoms per centimeter

Created by: EMS
 Last revision by: RM
 Checked by: JJK

Date: 4/13/2023
 Date: 4/10/2024
 Date: 4/16/2024

C:\Users\hld0\AppData\Local\Microsoft\Windows\INetCache\Content.Outlook\USG3GGC\[2404_0ML_GW_Field Data.xlsx]GW Field Data

Appendix D

Historical Monitoring Results

Single Location

Name: IPL - Ottumwa
Midland Landfill

Location ID: MW-102M
Number of Sampling Dates: 24

Parameter Name	Units	5/4/2016	6/22/2016	6/23/2016	8/10/2016	10/25/2016	10/26/2016	1/18/2017	4/20/2017	6/21/2017	8/22/2017	11/8/2017	4/17/2018	10/16/2018	4/18/2019	10/15/2019	5/21/2020
Boron	ug/L	1510	1440	--	1480	--	1420	1480	1460	1410	1440	1480	1550	1340	1400	1500	1500
Calcium	mg/L	45.9	147	--	129	--	31.5	23.6	26	67.7	79.7	10.4	25.3	12.9	51	14	38
Chloride	mg/L	16.3	13.8	--	13.4	--	13	12.3	12.5	12.8	13.1	12.3	13.5	13.6	14	15	16
Fluoride	mg/L	4.2	4.2	--	4.4	--	4.6	4.1	4	4.6	4.5	4.6	4.5	4.7	5.7	4.5	5
Field pH	Std. Units	8.09	7.68	--	--	--	--	7.62	7.35	7.64	6.89	8.16	8.34	7.8	8.55	7.81	7.82
Sulfate	mg/L	378	350	--	354	--	384	415	348	356	358	335	352	384	340	350	350
Total Dissolved Solids	mg/L	1670	1530	--	1620	--	1420	1530	1620	1480	1400	1410	1540	1500	1700	1400	3700
Antimony	ug/L	0.38	0.19	--	0.17	--	0.51	0.26	0.1	0.21	0.16	--	--	--	--	--	--
Arsenic	ug/L	0.64	0.68	--	0.78	--	0.9	0.89	0.92	0.9	0.9	--	--	--	--	--	--
Barium	ug/L	48.5	39.5	--	55.4	--	28.2	21.1	28.4	37.2	31	--	--	--	--	--	--
Beryllium	ug/L	0.74	1.4	--	1.1	--	0.37	0.19	0.34	0.54	0.41	--	--	--	--	--	--
Cadmium	ug/L	<0.029	0.12	--	0.078	--	0.11	<0.029	0.046	0.063	0.062	--	--	--	--	--	--
Chromium	ug/L	20.5	17.9	--	27.1	--	11.8	2.8	8.7	16	9.6	--	--	--	--	--	--
Cobalt	ug/L	3.5	4.5	--	7.3	--	2.4	0.74	1.7	2.1	2.5	--	--	--	--	--	--
Lead	ug/L	3.1	3.6	--	3.8	--	1.7	0.87	1.4	2.2	1.8	--	--	--	--	--	--
Lithium	ug/L	46.7	80.7	--	52.3	--	75.4	71.8	73.6	52.7	54	--	--	--	--	--	--
Mercury	ug/L	<0.039	<0.039	--	<0.039	--	<0.039	<0.039	<0.046	<0.046	<0.046	--	--	--	--	--	--
Molybdenum	ug/L	21.7	10.3	--	20.9	--	11.7	10.6	10.8	11.1	9.5	--	--	--	--	--	--
Selenium	ug/L	0.42	1	--	1.4	--	0.31	0.24	0.4	0.49	0.43	--	--	--	--	--	--
Thallium	ug/L	<0.5	<0.5	--	<0.5	--	<0.5	<0.5	0.04	0.084	0.067	--	--	--	--	--	--
Total Radium	pCi/L	2.64	--	1.66	1.17	--	0.814	0.567	1.57	1.12	0.594	--	--	--	--	--	--
Radium-226	pCi/L	-0.058	--	0.58	0.144	--	0.444	0.209	0.754	0.285	0.368	--	--	--	--	--	--
Radium-228	pCi/L	2.64	--	1.08	1.03	--	0.37	0.358	0.816	0.832	0.226	--	--	--	--	--	--
pH at 25 Degrees C	Std. Units	7.9	7.9	--	7.9	--	7.8	8.1	7.9	8	8	7.8	8	8	8.2	7.9	7.9
Collected By		--	--	--	0	--	--	0	0	0	0	--	--	--	--	--	--
Groundwater Elevation	feet	728.73	718.74	--	730.49	716.94	--	717.91	717.8	714.83	713.23	713.53	717.38	717.05	717.97	715.5	717.61
Field Oxidation Potential	mV	128.2	-102.4	--	--	--	--	--	--	--	219.9	-77.8	-104.7	--	--	21.2	
Field Specific Conductance	umhos/cm	2197	2037	--	--	--	--	--	--	--	2751	2085	2113	0	--	--	2260
Field Temperature	deg C	14	14.2	--	--	--	--	--	--	--	13.4	12.9	10.1	12.9	--	--	13.1
Oxygen, Dissolved	mg/L	0.79	3.06	--	--	--	--	--	--	--	0.73	4.51	2.14	--	--	--	1.59
Turbidity	NTU	350.9	614.3	--	--	--	--	--	--	--	--	--	--	--	--	--	297

Single Location

Name: IPL - Ottumwa
Midland Landfill

Location ID: MW-102M
Number of Sampling Dates: 24

Parameter Name	Units	10/7/2020	4/15/2021	10/5/2021	4/13/2022	10/27/2022	4/4/2023	10/11/2023	4/4/2024
Boron	ug/L	1600	1600	1300	1400	1400	1500	1500	1500
Calcium	mg/L	150	43	71	32	14	31	15	15
Chloride	mg/L	14	14	16	14	16	16	28	31
Fluoride	mg/L	5.3	4.3	2.9	4.3	4.8	4.2	5	4.5
Field pH	Std. Units	8.29	7.85	7.81	7.91	7.55	7.93	7.73	7.61
Sulfate	mg/L	350	330	360	330	390	370	400	430
Total Dissolved Solids	mg/L	1700	1500	1300	1300	1500	1500	1500	1500
Antimony	ug/L	--	--	--	--	--	--	--	--
Arsenic	ug/L	--	--	--	--	--	--	--	--
Barium	ug/L	--	--	--	--	--	--	--	--
Beryllium	ug/L	--	--	--	--	--	--	--	--
Cadmium	ug/L	--	--	--	--	--	--	--	--
Chromium	ug/L	--	--	--	--	--	--	--	--
Cobalt	ug/L	--	--	--	--	--	--	--	--
Lead	ug/L	--	--	--	--	--	--	--	--
Lithium	ug/L	--	--	--	--	--	--	--	--
Mercury	ug/L	--	--	--	--	--	--	--	--
Molybdenum	ug/L	--	--	--	--	--	--	--	--
Selenium	ug/L	--	--	--	--	--	--	--	--
Thallium	ug/L	--	--	--	--	--	--	--	--
Total Radium	pCi/L	--	--	--	--	--	--	--	--
Radium-226	pCi/L	--	--	--	--	--	--	--	--
Radium-228	pCi/L	--	--	--	--	--	--	--	--
pH at 25 Degrees C	Std. Units	8.1	8	7.9	7.9	7.8	7.9	8.3	7.7
Collected By		--	--	--	--	--	--	--	--
Groundwater Elevation	feet	712.05	710.95	714.85	710.24	709.07	701.93	720.93	709.84
Field Oxidation Potential	mV	22	164	82.2	-25.9	25.7	13.2	8.4	-53.5
Field Specific Conductance	umhos/cm	2123	2145	2041	1954	1912	--	2272	2095
Field Temperature	deg C	14.5	11.5	13.5	8.5	10.5	12	20	8.9
Oxygen, Dissolved	mg/L	5.11	5.24	2.32	4.4	7.53	7.92	6.39	8.8
Turbidity	NTU	--	196	28.1	121	19.23	116	17.31	20.43

Single Location

Name: IPL - Ottumwa
Midland Landfill

Location ID: MW-122M
Number of Sampling Dates: 25

Parameter Name	Units	5/4/2016	5/5/2016	6/22/2016	6/23/2016	8/10/2016	10/25/2016	10/26/2016	1/18/2017	4/20/2017	6/21/2017	8/22/2017	11/8/2017	4/17/2018	10/16/2018	4/17/2019	10/15/2019
Boron	ug/L	--	3140	--	1720	4550	--	4060	4720	4480	4710	4980	5220	5560	4580	5500	4100
Calcium	mg/L	--	599	--	312	419	--	415	386	382	386	386	383	402	366	400	400
Chloride	mg/L	--	16.4	--	21.9	11.8	--	8.2	8.3	8	7.8	7.8	7.2	8	8.6	8.8	10
Fluoride	mg/L	--	1.1	--	0.89	0.74	--	0.48	<0.027	0.88	1.1	0.6	0.5	<0.063	<0.19	0.7	<0.23
Field pH	Std. Units	--	6.97	--	6.68	--	--	--	6.06	--	6.42	6.32	6.16	6.65	6.31	7.34	6.6
Sulfate	mg/L	--	8260	--	5330	8950	--	8600	9680	14300	17500	9190	9440	10400	<0.24	8300	8400
Total Dissolved Solids	mg/L	--	11500	--	7430	14200	--	13200	14100	18100	12800	14300	13400	14400	13300	13000	13000
Antimony	ug/L	--	0.36	--	1	0.26	--	0.29	0.12	<0.079	<0.13	<0.13	--	--	--	--	--
Arsenic	ug/L	--	<0.52	--	<0.52	<0.21	--	<0.52	0.11	0.19	<0.26	<0.26	--	--	--	--	--
Barium	ug/L	--	31.5	--	17.9	14.5	--	16.8	11.8	13	11.2	10.3	--	--	--	--	--
Beryllium	ug/L	--	<0.4	--	<0.24	<0.16	--	<0.24	<0.4	0.054	<0.035	<0.058	--	--	--	--	--
Cadmium	ug/L	--	<0.14	--	<0.14	<0.058	--	<0.14	<0.029	<0.053	<0.089	<0.089	--	--	--	--	--
Chromium	ug/L	--	<1.7	--	<1.7	<0.68	--	1.3	0.51	0.26	<0.27	0.56	--	--	--	--	--
Cobalt	ug/L	--	5.3	--	6.5	3.5	--	6	2.1	1.4	1.2	0.96	--	--	--	--	--
Lead	ug/L	--	<0.96	--	<0.96	<0.39	--	<1.9	<0.19	0.22	<0.16	<0.16	--	--	--	--	--
Lithium	ug/L	--	450	--	332	601	--	544	679	643	640	667	--	--	--	--	--
Mercury	ug/L	--	<0.039	--	<0.039	<0.039	--	<0.039	<0.039	<0.046	<0.046	<0.046	--	--	--	--	--
Molybdenum	ug/L	--	2.6	--	2.6	0.57	--	0.58	0.15	2.1	0.6	0.43	--	--	--	--	--
Selenium	ug/L	--	<0.92	--	<0.92	<0.37	--	<0.92	<0.18	0.33	<0.43	<0.43	--	--	--	--	--
Thallium	ug/L	--	<2.5	--	<2.5	<1	--	<5	<0.5	<0.11	<0.18	<0.18	--	--	--	--	--
Total Radium	pCi/L	--	2.12	--	1.25	2.26	--	1.83	1.07	1.1	1.55	1.09	--	--	--	--	--
Radium-226	pCi/L	--	0.157	--	0.56	0.75	--	0.392	0.32	0.796	0.333	0.559	--	--	--	--	--
Radium-228	pCi/L	--	1.96	--	0.691	1.51	--	1.44	0.752	0.305	1.22	0.532	--	--	--	--	--
pH at 25 Degrees C	Std. Units	--	6.5	--	6.7	6.1	--	6.2	6.1	6.4	6.2	6	6.2	6.4	6.4	6.6	6.7
Collected By		--	--	--	--	0	--	--	0	0	0	0	--	--	--	--	--
Groundwater Elevation	feet	729.27	--	725.67	--	710.32	724.61	--	742.02	724.04	723.51	722.02	720.52	723.25	723.36	723.43	708.94
Field Oxidation Potential	mV	--	34.3	--	-50.7	--	--	--	--	--	--	-7.7	195.4	-61.1	-53.5	--	--
Field Specific Conductance	umhos/cm	--	3025	--	8161	--	--	--	--	--	--	--	13375	13773	0	--	--
Field Temperature	deg C	--	16.1	--	14.9	--	--	--	--	--	--	16.2	13.1	13.4	11.8	--	--
Oxygen, Dissolved	mg/L	--	1.92	--	2.29	--	--	--	--	--	--	--	0.49	0.36	1.48	--	--
Turbidity	NTU	--	212.1	--	-46.36	--	--	--	--	--	--	--	--	--	--	--	--

Single Location

Name: IPL - Ottumwa
Midland Landfill

Location ID: MW-122M
Number of Sampling Dates: 25

Parameter Name	Units	5/21/2020	10/7/2020	4/15/2021	10/5/2021	4/14/2022	10/27/2022	4/4/2023	10/11/2023	4/4/2024
Boron	ug/L	5100	4100	5100	5500	4800	6400	4300	4400	5500
Calcium	mg/L	430	430	410	440	420	440	430	450	450
Chloride	mg/L	9	8.3	8	8.7	8.5	14	9	8.2	8.6
Fluoride	mg/L	0.23	<0.23	0.3	<0.28	<0.22	<0.22	0.52	0.57	<0.38
Field pH	Std. Units	6.91	7	6.78	7.18	6.7	6.79	6.49	--	7.04
Sulfate	mg/L	9800	8700	8700	8800	460	9300	8900	10000	9000
Total Dissolved Solids	mg/L	16000	14000	14000	12000	13000	11000	11000	15000	--
Antimony	ug/L	--	--	--	--	--	--	--	--	--
Arsenic	ug/L	--	--	--	--	--	--	--	--	--
Barium	ug/L	--	--	--	--	--	--	--	--	--
Beryllium	ug/L	--	--	--	--	--	--	--	--	--
Cadmium	ug/L	--	--	--	--	--	--	--	--	--
Chromium	ug/L	--	--	--	--	--	--	--	--	--
Cobalt	ug/L	--	--	--	--	--	--	--	--	--
Lead	ug/L	--	--	--	--	--	--	--	--	--
Lithium	ug/L	--	--	--	--	--	--	--	--	--
Mercury	ug/L	--	--	--	--	--	--	--	--	--
Molybdenum	ug/L	--	--	--	--	--	--	--	--	--
Selenium	ug/L	--	--	--	--	--	--	--	--	--
Thallium	ug/L	--	--	--	--	--	--	--	--	--
Total Radium	pCi/L	--	--	--	--	--	--	--	--	--
Radium-226	pCi/L	--	--	--	--	--	--	--	--	--
Radium-228	pCi/L	--	--	--	--	--	--	--	--	--
pH at 25 Degrees C	Std. Units	7	6.9	6.7	7	6.7	6.9	7.6	7.9	--
Collected By		--	--	--	--	--	--	--	--	--
Groundwater Elevation	feet	724.23	718.39	720.52	717.76	704.81	719.03	706.9	707.9	700.9
Field Oxidation Potential	mV	-4.4	-28.2	159.2	-5.9	22.3	14	140.3	--	-36.6
Field Specific Conductance	umhos/cm	14090	13603	13983	13044	1322	13350	13367	--	13249
Field Temperature	deg C	13	13.6	9	13.3	15.3	12.2	10.2	--	7.3
Oxygen, Dissolved	mg/L	0.61	0.56	5.03	0.84	2.43	5.47	5.84	--	9.58
Turbidity	NTU	2.31	--	0	29	56.9	62.39	18.3	--	33.24

Single Location

Name: IPL - Ottumwa
Midland Landfill

Location ID: MW-301
Number of Sampling Dates: 22

Parameter Name	Units	5/4/2016	6/22/2016	8/9/2016	10/26/2016	1/17/2017	4/20/2017	6/20/2017	8/22/2017	11/7/2017	4/17/2018	10/15/2018	4/16/2019	10/15/2019	5/26/2020	10/6/2020	4/12/2021
Boron	ug/L	2280	1860	1770	1410	1310	1040	1040	994	1010	854	784	660	600	660	770	790
Calcium	mg/L	596	472	479	393	337	224	202	158	161	131	135	110	100	120	180	160
Chloride	mg/L	42.4	112	46.6	43.4	32.6	58	38.9	40.8	28.9	33.9	26.9	45	46	61	24	28
Fluoride	mg/L	0.68	0.38	0.55	0.72	0.77	0.72	0.93	0.78	0.77	0.87	0.84	0.85	0.85	0.77	0.67	0.73
Field pH	Std. Units	6.44	6.62	7.81	6.33	6.31	6.15	6.73	6.51	6.56	7.09	6.59	7.1	6.67	5.67	7.22	6.62
Sulfate	mg/L	5160	5370	4050	2630	1780	1170	1180	902	926	638	837	360	310	390	620	530
Total Dissolved Solids	mg/L	6260	5380	5810	4030	2830	1990	2060	1870	1760	1400	1550	970	860	1100	1400	1300
Antimony	ug/L	<0.58	<0.12	<0.12	<0.058	0.089	<0.026	0.058	0.04	--	--	--	--	--	--	--	--
Arsenic	ug/L	<1	0.84	0.29	0.3	0.64	0.56	0.42	0.56	--	--	--	--	--	--	--	--
Barium	ug/L	28.1	26.6	24.2	32.1	41.5	41	47.1	45.7	--	--	--	--	--	--	--	--
Beryllium	ug/L	<0.8	<0.24	<0.16	<0.08	<0.08	<0.012	<0.012	<0.012	--	--	--	--	--	--	--	--
Cadmium	ug/L	<0.29	<0.058	<0.058	<0.029	<0.029	<0.018	<0.018	0.04	--	--	--	--	--	--	--	--
Chromium	ug/L	<3.4	<0.68	<0.68	0.46	0.5	0.31	0.16	0.2	--	--	--	--	--	--	--	--
Cobalt	ug/L	<5	<1	<1	<0.5	<0.5	0.21	0.22	0.17	--	--	--	--	--	--	--	--
Lead	ug/L	<1.9	<0.96	<0.39	<0.19	<0.19	0.046	0.038	0.091	--	--	--	--	--	--	--	--
Lithium	ug/L	274	268	195	171	156	110	111	114	--	--	--	--	--	--	--	--
Mercury	ug/L	<0.039	<0.039	<0.039	<0.039	<0.039	<0.046	<0.046	<0.046	--	--	--	--	--	--	--	--
Molybdenum	ug/L	4.6	2	2.1	2.9	2.9	6.3	5.3	6.5	--	--	--	--	--	--	--	--
Selenium	ug/L	<1.8	<0.37	<0.37	<0.18	<0.18	<0.086	<0.086	0.12	--	--	--	--	--	--	--	--
Thallium	ug/L	<5	<2.5	<1	<0.5	<0.5	<0.036	0.076	0.068	--	--	--	--	--	--	--	--
Total Radium	pCi/L	1.99	0.285	1.89	1.68	1.96	1.34	1.56	1.5	--	--	--	--	--	--	--	--
Radium-226	pCi/L	0.565	0.071	0.606	0.66	0.44	0.855	0.734	0.6	--	--	--	--	--	--	--	--
Radium-228	pCi/L	1.42	0.214	1.28	1.02	1.52	0.488	0.829	0.896	--	--	--	--	--	--	--	--
pH at 25 Degrees C	Std. Units	6.2	6.2	6.2	6.2	6.2	6.9	6.4	6.4	6.4	6.8	7.5	6.8	7	7.3	6.9	6.6
Collected By		--	--	0	--	0	0	0	0	--	--	0	--	--	--	--	--
Groundwater Elevation	feet	686.46	686.4	686.19	683.7	685.57	685.72	685.88	684.96	684.5	684.85	684.58	686.38	686.56	687.29	686.8	687.25
Field Oxidation Potential	mV	-58.5	-49.7	-53	-79.4	-57.8	-49.8	-63.1	-20.6	144.3	-102.8	88.2	-50.2	-58.4	-57.8	-105.9	-79.6
Field Specific Conductance	umhos/cm	7267	5132	5607	4377	3607	2631	2384	3187	2395	1910	2112	1603	1512	1546	1820	1875
Field Temperature	deg C	13.4	14.3	13.9	13.5	13.1	13	13.8	13.9	13.4	13	13.6	13.87	13.68	15.8	14.5	13
Oxygen, Dissolved	mg/L	0.27	0.14	0.1	0.55	0.19	0.18	0.16	0.11	0.37	0.16	0.2	1.27	0.4	0.41	0.25	0.46
Turbidity	NTU	2.86	3.34	1.05	0.92	0.63	1.12	2.69	0.99	1.91	1.13	4.91	8.88	4.75	21.8	21.4	4.6
Collected Date		--	--	--	--	--	--	--	--	--	--	10	--	--	--	--	--
Collected Time		--	--	--	--	--	--	--	--	--	--	15	--	--	--	--	--

Single Location

Name: IPL - Ottumwa
Midland Landfill

Location ID: MW-301
Number of Sampling Dates: 22

Parameter Name	Units	10/5/2021	4/14/2022	10/25/2022	4/5/2023	10/11/2023	4/4/2024
Boron	ug/L	700	710	640	650	710	770
Calcium	mg/L	150	150	140	130	120	110
Chloride	mg/L	29	24	27	22	21	22
Fluoride	mg/L	<0.28	<0.22	0.85	0.71	0.99	0.77
Field pH	Std. Units	6.71	6.84	6.58	6.75	6.74	6.66
Sulfate	mg/L	590	450	440	370	360	310
Total Dissolved Solids	mg/L	1200	1000	1100	970	960	850
Antimony	ug/L	--	--	--	--	--	--
Arsenic	ug/L	--	--	--	--	--	--
Barium	ug/L	--	--	--	--	--	--
Beryllium	ug/L	--	--	--	--	--	--
Cadmium	ug/L	--	--	--	--	--	--
Chromium	ug/L	--	--	--	--	--	--
Cobalt	ug/L	--	--	--	--	--	--
Lead	ug/L	--	--	--	--	--	--
Lithium	ug/L	--	--	--	--	--	--
Mercury	ug/L	--	--	--	--	--	--
Molybdenum	ug/L	--	--	--	--	--	--
Selenium	ug/L	--	--	--	--	--	--
Thallium	ug/L	--	--	--	--	--	--
Total Radium	pCi/L	--	--	--	--	--	--
Radium-226	pCi/L	--	--	--	--	--	--
Radium-228	pCi/L	--	--	--	--	--	--
pH at 25 Degrees C	Std. Units	6.8	6.8	7.1	6.8	7.6	6.6
Collected By		--	--	--	--	--	--
Groundwater Elevation	feet	686.87	687	686.01	686.58	684.55	684.96
Field Oxidation Potential	mV	-66.1	-76	-48.2	-91.2	-97.3	-92.7
Field Specific Conductance	umhos/cm	1717	1581	1539	1485	1562	1332
Field Temperature	deg C	13.8	11.3	13	12.5	13.4	12.2
Oxygen, Dissolved	mg/L	0.35	0.27	0.28	0.17	0.39	0.44
Turbidity	NTU	32.1	22.9	14.23	16.8	6.55	14.94
Collected Date		--	--	--	--	--	--
Collected Time		--	--	--	--	--	--

Single Location

Name: IPL - Ottumwa
Midland Landfill

Location ID: MW-302
Number of Sampling Dates: 22

Parameter Name	Units	5/4/2016	6/22/2016	8/10/2016	10/26/2016	1/17/2017	4/19/2017	6/20/2017	8/22/2017	11/7/2017	4/17/2018	10/15/2018	4/16/2019	10/15/2019	5/21/2020	10/6/2020	4/12/2021
Boron	ug/L	853	796	802	784	824	777	767	783	848	834	752	760	780	780	870	820
Calcium	mg/L	72.1	56.6	48.8	42.8	42.9	41	46.1	50.2	74	77.3	66.9	44	68	41	65	58
Chloride	mg/L	9.2	8.1	7.5	6	7.7	8	8	8.5	7.8	8.6	9.2	10	7.3	8.9	7.2	6.6
Fluoride	mg/L	1.1	1	0.98	1	0.97	1	1.1	1	1.2	1	1.1	1.5	1.2	1	1.1	1.1
Field pH	Std. Units	7.38	7.76	9.55	7.22	7.23	7.6	7.29	7.12	7.41	7.8	7.25	7.49	7.21	7.05	7.14	7.13
Sulfate	mg/L	201	133	102	78.9	76.7	76.7	79.3	77.2	77.5	79.3	80.9	83	73	79	73	64
Total Dissolved Solids	mg/L	784	715	671	644	639	671	656	672	607	690	708	690	680	930	700	620
Antimony	ug/L	0.12	0.15	0.095	<0.058	0.1	<0.026	0.094	0.056	--	--	--	--	--	--	--	--
Arsenic	ug/L	0.19	0.39	0.28	0.24	0.31	0.23	0.25	0.38	--	--	--	--	--	--	--	--
Barium	ug/L	39.3	45.4	50	54	57.2	48.9	49.9	47.5	--	--	--	--	--	--	--	--
Beryllium	ug/L	0.22	0.16	<0.08	<0.08	<0.08	0.051	0.084	0.15	--	--	--	--	--	--	--	--
Cadmium	ug/L	<0.029	<0.029	<0.029	<0.029	<0.029	<0.018	0.018	<0.018	--	--	--	--	--	--	--	--
Chromium	ug/L	5.5	6.2	1.9	1.8	1.4	1.4	2.2	2.9	--	--	--	--	--	--	--	--
Cobalt	ug/L	1.1	1.1	<0.5	<0.5	<0.5	0.24	0.38	0.66	--	--	--	--	--	--	--	--
Lead	ug/L	1.1	0.9	0.32	0.26	0.26	0.25	0.36	0.54	--	--	--	--	--	--	--	--
Lithium	ug/L	81.1	81.2	75.9	79.8	80.8	79.6	78.5	82	--	--	--	--	--	--	--	--
Mercury	ug/L	<0.039	<0.039	<0.039	<0.039	<0.039	<0.046	<0.046	<0.046	--	--	--	--	--	--	--	--
Molybdenum	ug/L	0.32	0.49	0.31	0.18	0.24	0.2	0.17	0.24	--	--	--	--	--	--	--	--
Selenium	ug/L	0.19	0.39	<0.18	<0.18	<0.18	<0.086	0.21	0.21	--	--	--	--	--	--	--	--
Thallium	ug/L	<0.5	<0.5	<0.5	<0.5	<0.5	<0.036	0.065	0.089	--	--	--	--	--	--	--	--
Total Radium	pCi/L	0.874	0.677	1.17	1.17	1.57	1.65	1.54	2.6	--	--	--	--	--	--	--	--
Radium-226	pCi/L	0.412	-0.066	0.426	0.505	0.525	0.872	0.987	1.74	--	--	--	--	--	--	--	--
Radium-228	pCi/L	0.462	0.677	0.744	0.663	1.04	0.777	0.549	0.863	--	--	--	--	--	--	--	--
pH at 25 Degrees C	Std. Units	7.3	7.1	7.3	7.4	7.6	7.5	7.6	7.4	7.2	7.6	7.5	7.4	7.5	7.5	7.6	6.7
Collected By		--	--	0	--	0	0	0	0	--	--	0	--	--	--	--	--
Groundwater Elevation	feet	685.8	685.79	685.48	684.94	685.68	684.73	684.76	683.89	683.38	683.87	683.52	685.35	685.44	686.25	685.86	686.26
Field Oxidation Potential	mV	-153.3	-114.6	-100.7	-126.7	-109.6	-64	-66.8	-96.2	112.3	-138.7	-103.6	8.13	-56.4	-83.4	-169.4	-74.2
Field Specific Conductance	umhos/cm	1326	1132	1102	1075	1081	1081	1018	1429	1079	1091	1102	1168	1067	1129	1025	1079
Field Temperature	deg C	13.6	14	13.9	13.5	12.9	14	14	13.7	13.1	12.7	13.4	13.63	14.26	13.1	13.5	13.2
Oxygen, Dissolved	mg/L	0.08	0.09	0.1	0.66	0.29	0.17	0.22	0.11	0.3	0.3	0.22	1.59	0.75	1.06	0.28	0.28
Turbidity	NTU	170.8	167.5	74.76	29.05	43.07	39.01	58.63	77.96	202.4	200.6	131.5	44.2	102.8	12.5	136	127
Collected Date		--	--	--	--	--	--	--	--	--	--	10	--	--	--	--	--
Collected Time		--	--	--	--	--	--	--	--	--	--	14	--	--	--	--	--

Single Location

Name: IPL - Ottumwa
Midland Landfill

Location ID: MW-302
Number of Sampling Dates: 22

Parameter Name	Units	10/5/2021	4/13/2022	10/25/2022	4/5/2023	10/11/2023	4/3/2024
Boron	ug/L	740	730	790	800	790	840
Calcium	mg/L	52	50	54	52	40	45
Chloride	mg/L	7.1	5.3	5.4	6.2	5.6	6.2
Fluoride	mg/L	0.5	1.1	0.93	0.91	1.2	1.1
Field pH	Std. Units	7.2	7.3	7.13	7.19	7.24	7.15
Sulfate	mg/L	70	61	64	66	72	73
Total Dissolved Solids	mg/L	400	630	600	550	640	630
Antimony	ug/L	--	--	--	--	--	--
Arsenic	ug/L	--	--	--	--	--	--
Barium	ug/L	--	--	--	--	--	--
Beryllium	ug/L	--	--	--	--	--	--
Cadmium	ug/L	--	--	--	--	--	--
Chromium	ug/L	--	--	--	--	--	--
Cobalt	ug/L	--	--	--	--	--	--
Lead	ug/L	--	--	--	--	--	--
Lithium	ug/L	--	--	--	--	--	--
Mercury	ug/L	--	--	--	--	--	--
Molybdenum	ug/L	--	--	--	--	--	--
Selenium	ug/L	--	--	--	--	--	--
Thallium	ug/L	--	--	--	--	--	--
Total Radium	pCi/L	--	--	--	--	--	--
Radium-226	pCi/L	--	--	--	--	--	--
Radium-228	pCi/L	--	--	--	--	--	--
pH at 25 Degrees C	Std. Units	7.6	7.5	7.6	7.4	8	7.2
Collected By		--	--	--	--	--	--
Groundwater Elevation	feet	685.85	685.07	684.97	685.65	684.12	684
Field Oxidation Potential	mV	-66.5	-43.2	-98.7	-81.5	-100.9	-111
Field Specific Conductance	umhos/cm	993	1002	1130	1034	1129	1009
Field Temperature	deg C	13.5	12	12.9	12.8	13.6	12
Oxygen, Dissolved	mg/L	0.35	0.36	0.1	1.31	0.44	0.6
Turbidity	NTU	67.1	75.3	122.97	99	68.96	37.92
Collected Date		--	--	--	--	--	--
Collected Time		--	--	--	--	--	--

Single Location

Name: IPL - Ottumwa
Midland Landfill

Location ID: MW-303
Number of Sampling Dates: 24

Parameter Name	Units	5/4/2016	6/22/2016	8/9/2016	10/26/2016	1/17/2017	4/19/2017	7/19/2017	8/22/2017	11/7/2017	4/17/2018	10/16/2018	4/16/2019	6/6/2019	10/15/2019	5/26/2020	6/29/2020
Boron	ug/L	3510	2430	1640	1100	955	800	755	737	738	738	661	850	--	760	770	--
Calcium	mg/L	686	462	250	157	116	97.4	87.7	94	94.9	103	90.5	150	--	120	120	--
Chloride	mg/L	13.5	11.5	8.7	7.5	7.1	6.9	7.2	7.3	6.9	7.3	7.4	8.1	8	7.5	8.5	6.9
Fluoride	mg/L	0.68	0.47	0.9	0.87	0.86	0.86	0.86	0.85	0.77	0.8	0.84	<0.23	--	0.87	0.81	--
Field pH	Std. Units	6.24	6.93	7.84	6.66	6.69	7.12	7.1	6.71	6.96	7.32	6.87	6.97	6.71	6.76	6.21	6.74
Sulfate	mg/L	6230	4690	1950	780	497	329	255	287	232	262	310	600	--	390	440	--
Total Dissolved Solids	mg/L	9540	7120	2750	1500	1080	931	809	868	783	839	891	1300	--	1100	1100	--
Antimony	ug/L	<0.58	<0.058	<0.12	<0.058	0.082	<0.026	0.042	0.041	--	--	--	--	--	--	--	--
Arsenic	ug/L	<1	0.3	<0.21	0.13	0.2	0.24	0.59	0.53	--	--	--	--	--	--	--	--
Barium	ug/L	55.8	47.6	19.3	13.4	11.7	11.9	12.8	13.1	--	--	--	--	--	--	--	--
Beryllium	ug/L	1.2	<0.24	0.16	0.11	0.099	0.13	0.24	0.24	--	--	--	--	--	--	--	--
Cadmium	ug/L	<0.29	<0.029	<0.058	0.037	<0.029	<0.018	0.019	0.026	--	--	--	--	--	--	--	--
Chromium	ug/L	22.1	3.1	2.7	2.6	1.1	2.6	5.1	4.5	--	--	--	--	--	--	--	--
Cobalt	ug/L	12.7	1.6	1.2	1	<0.5	1.1	2.5	2.1	--	--	--	--	--	--	--	--
Lead	ug/L	5.7	1.6	0.51	0.57	0.3	0.57	1	1.2	--	--	--	--	--	--	--	--
Lithium	ug/L	289	270	126	102	96.5	92.4	90.8	92.8	--	--	--	--	--	--	--	--
Mercury	ug/L	<0.039	<0.039	<0.039	<0.039	<0.039	<0.046	<0.046	<0.046	--	--	--	--	--	--	--	--
Molybdenum	ug/L	3	0.38	0.69	0.43	0.29	0.3	0.26	0.29	--	--	--	--	--	--	--	--
Selenium	ug/L	<1.8	0.38	<0.37	<0.18	<0.18	0.26	0.4	0.42	--	--	--	--	--	--	--	--
Thallium	ug/L	<5	<2.5	<1	<0.5	<0.5	<0.036	0.049	0.048	--	--	--	--	--	--	--	--
Total Radium	pCi/L	10.6	7.5	3.59	2.18	1.47	1.82	1.33	0.803	--	--	--	--	--	--	--	--
Radium-226	pCi/L	2.51	2.96	1.26	0.634	0.199	0.481	0.273	0.559	--	--	--	--	--	--	--	--
Radium-228	pCi/L	8.08	4.54	2.33	1.55	1.27	1.34	1.06	0.244	--	--	--	--	--	--	--	--
pH at 25 Degrees C	Std. Units	6.2	6.2	6.4	6.6	6.9	7	7	6.9	6.8	7.2	7.1	6.8	--	7	7.3	--
Collected By		--	--	0	--	0	0	0	--	--	--	--	--	--	--	--	--
Groundwater Elevation	feet	686.04	687.72	687.77	685.56	685.6	685.51	684.92	684.7	684.26	684.68	684.33	686.13	686.05	686.08	687.14	687.36
Field Oxidation Potential	mV	-50	-49.5	-76.7	-102.1	-93.5	-56.6	-83.6	-72.6	125.7	-103.8	-117.7	-20	-40	-55.6	-30	-53.3
Field Specific Conductance	umhos/cm	8206	6426	3419	2120	1681	1451	1300	1836	1307	1358	0	2209	1331	1628	1963	1739
Field Temperature	deg C	14	14	14	13.7	13	13.7	14.5	14	13.2	13.3	13.5	14.07	16.7	15.44	14.4	16.1
Oxygen, Dissolved	mg/L	0.16	0.11	0.08	0.46	0.16	0.17	0.5	0.31	0.45	0.38	0.41	1.41	0.42	0.43	2.31	0.49
Turbidity	NTU	677.5	160.2	169.9	84.13	113.7	120.3	179.4	161.5	258.2	248	61.64	99.2	169.9	27.9	57.1	59

Single Location

Name: IPL - Ottumwa
Midland Landfill

Location ID: MW-303
Number of Sampling Dates: 24

Parameter Name	Units	10/6/2020	4/12/2021	10/5/2021	4/13/2022	10/24/2022	4/4/2023	10/11/2023	4/3/2024
Boron	ug/L	740	730	630	680	640	730	740	760
Calcium	mg/L	100	100	92	100	91	110	110	110
Chloride	mg/L	7.3	7.6	8.3	7	7.2	7.8	7.9	8.1
Fluoride	mg/L	0.88	0.74	0.39	0.97	0.88	0.78	0.92	0.7
Field pH	Std. Units	7.01	6.8	6.76	6.89	6.76	6.86	6.81	6.73
Sulfate	mg/L	230	260	270	250	190	330	350	300
Total Dissolved Solids	mg/L	840	850	820	840	740	950	930	890
Antimony	ug/L	--	--	--	--	--	--	--	--
Arsenic	ug/L	--	--	--	--	--	--	--	--
Barium	ug/L	--	--	--	--	--	--	--	--
Beryllium	ug/L	--	--	--	--	--	--	--	--
Cadmium	ug/L	--	--	--	--	--	--	--	--
Chromium	ug/L	--	--	--	--	--	--	--	--
Cobalt	ug/L	--	--	--	--	--	--	--	--
Lead	ug/L	--	--	--	--	--	--	--	--
Lithium	ug/L	--	--	--	--	--	--	--	--
Mercury	ug/L	--	--	--	--	--	--	--	--
Molybdenum	ug/L	--	--	--	--	--	--	--	--
Selenium	ug/L	--	--	--	--	--	--	--	--
Thallium	ug/L	--	--	--	--	--	--	--	--
Total Radium	pCi/L	--	--	--	--	--	--	--	--
Radium-226	pCi/L	--	--	--	--	--	--	--	--
Radium-228	pCi/L	--	--	--	--	--	--	--	--
pH at 25 Degrees C	Std. Units	7.2	7	7.3	7	7.2	7	7.8	6.9
Collected By		--	--	--	--	--	--	--	--
Groundwater Elevation	feet	686.35	689.05	686.84	686.91	685.86	686.51	684.95	684.82
Field Oxidation Potential	mV	-137.3	-64.6	-55	-37.8	-51.9	-49.3	-85.7	-92.5
Field Specific Conductance	umhos/cm	1262	1431	1287	1344	1318	1544	1617	1458
Field Temperature	deg C	13.9	14.2	13.8	12.5	13.5	11.6	14.1	12.3
Oxygen, Dissolved	mg/L	0.3	0.38	0.48	0.35	0	0.19	0.55	0.46
Turbidity	NTU	240	168	79.6	61.2	183.4	--	64.61	102.35