



Alliant Energy
4902 North Biltmore Lane
P.O. Box 77007
Madison, WI 53707-1007

1-800-ALLIANT (800-255-4268)
alliantenergy.com

July 26, 2021

To: CCR Operating Record
Re: Notification of Groundwater Protection Standard Exceedance pursuant to 40 CFR 257.95

A constituent in Appendix IV to part 40 CFR 257 was detected at a statistically significant level above the groundwater protection standard (GPS) established under 40 CFR 257.95(h) in a monitoring well located at the Ottumwa Generating Station. The constituent exceeding the GPS is lithium, as sampled in monitoring wells MW-310A and MW-311A. These are delineation wells installed for assessment monitoring at the site; lithium has not been observed at a statistically significant level in monitoring wells installed at the waste boundary of the CCR unit listed below. This notification has been prepared in accordance with 40 CFR 257.95(g) and 257.105(h)(8).

This notification applies to the following CCR units at this facility:

CCR surface impoundment
OGS Ash Pond

Signed,

Print Name Jeff Maxted	Title Manager – Environmental Services
Phone No. or Email Address (608) 458-3853; jeffreymaxted@alliantenergy.com	