



**VIA EMAIL**

October 5, 2020

Mr. Jeffrey Maxted  
Alliant Energy – Environmental Services Manager  
4902 North Biltmore Lane  
Madison, WI 53718-2148

**Re: Unstable Areas Determination CCR Surface Impoundments - §257.64  
Interstate Power and Light Company (IPL)  
Ottumwa Generating Station  
Ottumwa, Iowa**

Mr. Jeffrey Maxted,

This Unstable Areas Determination has been prepared in accordance with the requirements of the United States Environmental Protection Agency (USEPA) published Final Rule for Hazardous and Solid Waste Management System – Disposal of Coal Combustion Residual (CCR) from Electric Utilities (40 CFR Parts 257 and 261, also known as the CCR Rule) published on April 17, 2015 (effective October 19, 2015) and subsequent amendments. This letter assesses the factors of both CCR units at Interstate Power and Light Company (IPL), Ottumwa Generating Station (OGS) in Ottumwa, Iowa in accordance with the CCR Rule §257.64 Unstable Areas. For purposes of this Report, “CCR unit” refers to an existing or inactive CCR surface impoundment.

## **Background Information**

In accordance with the requirements set forth in §257.64 of the CCR Rule a CCR unit must not be located in an unstable area. The owner or operator must consider all the following factors:

- On-site or local soil conditions that may result in significant differential settling,
- On-site or local geologic or geomorphologic features; and,
- On-site or local human-made features or events (both surface and subsurface).

## Facility Specific Information

The OGS is located at 20775 Power Plant Road, Ottumwa, IA 52501. Figure 1 provides both a topographic map and an aerial of the OGS facility location, with the approximate property boundary of the facility identified. Figure 2 identifies each CCR Unit. OGS has one existing and one inactive CCR surface impoundment, which are identified as follows:

- OGS Ash Pond (existing)
- OGS Zero Liquid Discharge Pond (inactive)

### Differential Settling

The embankment soils at OGS were documented by SCS Engineers<sup>1</sup> boring logs MW-304 and MW-305, Figure 2. The results indicate that the embankments of both impoundments are constructed of stiff compacted clay from the site overlying the medium stiff native clay which overlies very dense sand of the Des Moines River. The boring logs are shown in Exhibit A.

During the design phase, before the plant was constructed, a 1974 subsurface investigation was completed which included borings and testing of the native soils. These borings showed that the native clay was sampled and tested for Atterberg limits, unconfined compressive strength and both consolidated undrained (CU) and unconsolidated undrain (UU) triaxial strength. The test results are shown in Exhibit B and indicated that the native clay under the embankments is a low plasticity clay (CL) with unconfined compression values from 1,500 to 2,500 psf. Triaxial UU tests indicated a range of 750 to 2,000 psf for cohesion and the CU tests indicated 29° to 34° for friction angle and 0 to 600 psf cohesion. The CU test results imply the clay is normally consolidated.

Information on the compacted clay and river valley sand is available from the SCS soil boring standard split spoon (SPT) blowcount information, Exhibit A. The Terzaghi and Peck relationship of SPT blowcount to clay cohesion for the average blowcounts in each clay layer yields a value of cohesion of 1,000 psf for the native clay and 1,600 psf for the embankment clay, Exhibit C. The very dense sand is assigned a friction angle of 38°, based on the correlation of cohesionless soil strength to density provided in NAVFACs DM-7<sup>2</sup>, Appendix C.

The analysis of slope stability for the CCR embankments was completed with a cohesion value of 1,600 psf for the embankment clay, 1,000 psf for the native clay and a friction angle of 38° for the very dense sand. Soil borings show the soil conditions are consistent under the entire area of the two CCR ponds.

Based on the known geotechnical information, both the OGS Ash Pond and the OGS Zero Liquid Discharge Pond are not susceptible to significant differential settlement. Additionally, annual inspections of the embankments for the last 4 years have indicated no observable areas of differential settlement on the embankments.

---

<sup>1</sup> SCS Engineers, "Ottumwa Generating Station – Monitoring Well Construction Documentation", April 15, 2016

<sup>2</sup> Naval Facilities Engineering Command, Soil Mechanics, Foundations, and Earth Structures, Figure 3-7, NAVFAC DM-7, January 1971

### **Geologic and Geomorphologic Features**

The Bedrock Geologic Map of Iowa (Exhibit D) shows that the site contains up to four types of bedrock including the Lower Cherokee, Raccoon Creek, St. Louis, and Pella formations. The formations are comprised of dolomite, shale, and sandstone. The Bedrock Topography of Southeast Iowa by Robert. E Hansen from 1973 shows that the elevation of the bedrock in the general area of the facility varies between 600 and 650 feet. The 1974 boring logs (Exhibit B) on Section E-E show the bedrock near the CCR impoundments varies between 630 to 655 feet in elevation.

While there are karst formations known to exist in Iowa, they are predominately in the northeast part of the state, see Exhibit E. Additionally, an Iowa Department of Natural Resources map of known and potential karst terrain and/or paleosinks (sinkholes) near OGS has also been included in Exhibit E. This map shows that the OGS is in an area potentially susceptible to karst formations although there are no known paleosinks near the facility.

Several figures and tables have been included in Exhibit F from the OGS Selection of Remedy<sup>3</sup>. This document illustrates that the local groundwater direction is generally east toward the Des Moines River. Additionally, the nested well water elevation data for MW-305 and MW-305A suggests that a downward gradient exists. At this location limestone is located 35 feet below the bottom of the impoundment and the water recharging this area is likely at or above a pH of 7. As result, there is little risk for the formation of paleosinks.

### **Human-made Features or Events**

Based on the information provided herein, both the OGS Ash Pond and the OGS Zero Liquid Discharge Pond are not susceptible to anthropogenic activities that could exist in this area, which could include a large dam failure, failure due to improper cut and fill during construction, excessive drawdown of groundwater, extreme fluctuations in flooding from human-made changes, or failure due to underground mines.

## **Unstable Areas Determination**

After review of the reasonably and readily available documentation, the following CCR Units are not located in unstable areas:

- OGS Ash Pond
- OGS Zero Liquid Discharge Pond

---

<sup>3</sup> SCS Engineers, "Selection of Remedy", September 11, 2020

## Qualified Professional Engineer Certification

The owner or operator of the CCR unit must obtain a certification from a qualified professional engineer attesting that the documentation as to whether a CCR unit meets the requirements 40 CFR 257.64(b).

To meet the requirements of 40 CFR 257.64(c), I Mark W. Loerop hereby certify that I am a licensed Professional Engineer in the State of Iowa; and that, to the best of my knowledge, all information contained in this document is correct and the document was prepared in compliance with all applicable requirements in 40 CFR 257.64.



By: \_\_\_\_\_

Name: \_\_\_\_\_

Date: \_\_\_\_\_

*[Handwritten Signature]*

*MARK LOEROP*

*OCTOBER 5, 2020*

cc: Tony Morse, Alliant Energy

att: Figure 1 – Site Location  
Figure 2 – Location of Critical Cross Sections  
Exhibit A – 2016 Soil Boring  
Exhibit B – 1974 Soil Laboratory Results  
Exhibit C – Conversion of Blowcount to Soil Strength  
Exhibit D – Bedrock Maps  
Exhibit E – Karst Formation Maps  
Exhibit F – OGS Local Groundwater Information

MWL/tjh/MWL

Z:\Shared\Projects\154 - Alliant Energy\154.018 - CCR Projects\022 - 2020 OGS & COL Unstable Conditions Determination\001 - OGS  
UCD\Unstable Area Determination\OGS Unstable Areas - FINAL.doc

## **FIGURES**


---

Alliant Energy  
Wisconsin Power and Light Company  
Ottumwa Generating Station  
Ottumwa, Iowa


Unstable Area Determination  
Figure 1 – Site Location  
Figure 2 – Critical Section Location

Historical Topo Map

2013



This report includes information from the following map sheet(s).




TP, Chillicothe, 2013, 7.5-minute

SITE NAME: Otumwa Generating Station  
 ADDRESS: 20775 Power Plant Road  
 Otumwa, IA 52501  
 CLIENT: Environmental Site Assessors

4555570 - 5 page 4



Historical Aerial Photo 4/13/2016




----- Approximate Property Boundary



**HARD HAT SERVICES**<sup>TM</sup>  
 Engineering, Construction and Management Solutions

Site Location  
 Otumwa Generating Station  
 Intersate Power and Light Company

Drawing  
**Figure 1**  
 Date  
 7/12/2016



NOTICE  
THIS DRAWING IS THE PROPERTY  
OF HARD HAT SERVICES AND IS  
NOT TO BE REPRODUCED,  
CHANGED, OR COPIED IN ANY FORM  
OR MANNER WITHOUT PRIOR  
WRITTEN PERMISSION. ALL RIGHTS  
RESERVED.

REV	DATE	BY	DESCRIPTION



SCALE:	AS SHOWN
DATE:	8-29-16
DRAWN BY:	JFD
CHKD BY:	THJ
APRVD BY:	MWL

CLIENT / LOCATION	INTERSTATE POWER AND LIGHT (IPL) OTTUMWA GENERATING STATION OTTUMWA, IA
-------------------	---

DRAWING DESCRIPTION	SAFETY FACTOR ASSESSMENT CRITICAL CROSS-SECTION LOCATION
---------------------	---

JOB	154.018.002.003
SHT.	FIGURE 2
DWG.	154.018.002.003-D2

## **EXHIBIT A – 2016 SOIL BORINGS**

---

Alliant Energy  
Wisconsin Power and Light Company  
Ottumwa Generating Station  
Ottumwa, Iowa

Unstable Area Determination



Route To: Watershed/Wastewater  Waste Management   
Remediation/Redevelopment  Other

Facility/Project Name <b>IPL- Ottumwa Generating Station</b> SCS#: 25215135.40		License/Permit/Monitoring Number		Boring Number <b>MW-304</b>	
Boring Drilled By: Name of crew chief (first, last) and Firm <b>Todd Schmalfeld Cascade Drilling</b>		Date Drilling Started <b>11/11/2015</b>		Date Drilling Completed <b>11/11/2015</b>	
Unique Well No.		DNR Well ID No.		Common Well Name <b>MW-304</b>	
Final Static Water Level <b>Feet</b>		Surface Elevation <b>680.1 Feet</b>		Borehole Diameter <b>8.5 in</b>	
Local Grid Origin <input type="checkbox"/> (estimated: <input type="checkbox"/> ) or Boring Location <input checked="" type="checkbox"/> State Plane <b>401,152 N, 1,903,287 E S/C/N</b>		Lat <b>_____° _____'</b>		Local Grid Location <input type="checkbox"/> N <input type="checkbox"/> E <input type="checkbox"/> S <input type="checkbox"/> W	
SE 1/4 of NE 1/4 of Section <b>26, T 73 N, R 15 W</b>		Long <b>_____° _____'</b>		Feet <input type="checkbox"/> S Feet <input type="checkbox"/> W	
Facility ID		County <b>Wapello</b>		Civil Town/City/ or Village <b>Ottumwa</b>	

Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	PID/FID	Soil Properties					RQD/ Comments	
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200		
			1	TOPSOIL.	TOPSOIL										
			2	FAT CLAY, black (10YR 2/1).											
			3												
			4												
			5												
			6												
			7		CH										
			8												
			9												
			10												
S1	23	4 5 4 5	11								M				
			12												
			13	FAT CLAY, yellowish brown (10YR 5/4).											
S2	19.5	4 4 5 5	14		CH						M				
			15	FAT CLAY, yellowish brown (10YR 3/4).	CH										
			16												

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature for Kyle Kramer

Firm **SCS Engineers**  
2830 Dairy Drive Madison, WI 53718

Tel: (608) 224-2830  
Fax:

Boring Number MW-304

Page 2 of 3

Sample			Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	PID/FID	Soil Properties					RQD/ Comments	
Number and Type	Length Att. & Recovered (in)	Blow Counts							Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200		
S3	12	33 45	17	FAT CLAY, yellowish brown (10YR 3/4). (continued)											
S4	22	43 712	18												
S5	23	27 89	19												
S6	23	34 86	20												
S7	23	511 1511	21												CH
S8	15	44 56	22												
S9	18	46 99	23												
S10	24	46 76	24												
S11	16	22 46	25												FAT CLAY, DARK OLIVE BROWN (2.5Y 3/3).
S12	24	43 55	26												CH
S13	18	23 33	27												
			28												
			29												
			30												
			31												
			32												
			33												
			34												
			35												
			36												
			37												
			38												
			39												
			40												
			41												
			42												

Boring Number MW-304

Page 3 of 3

Sample		Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	PID/FID	Soil Properties					RQD/ Comments
Number and Type	Length Att. & Recovered (in)								Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
S14	24	3 4	43	FAT CLAY, DARK OLIVE BROWN (2.5Y 3/3). <i>(continued)</i>	CH									
		9 14	44	SANDY SILT, very dark gray.	ML					W				
S16	15	30 50/4	45	POORLY GRADED SAND, medium grained, gray (5Y 6/1), (weathered bedrock).	SP									
			46											
S17	5	33 50/2	47											
			48		W									
S18		50/4	49											
			50		W									
			51											
			52	End of Boring at 52 feet bgs.										

Route To:  Watershed/Wastewater  Waste Management   
 Remediation/Redevelopment  Other

Facility/Project Name <b>IPL- Ottumwa Generating Station</b> SCS#: 25215135.40		License/Permit/Monitoring Number		Boring Number <b>MW-305</b>	
Boring Drilled By: Name of crew chief (first, last) and Firm <b>Todd Schmalfeld Cascade Drilling</b>			Date Drilling Started <b>12/7/2015</b>		Date Drilling Completed <b>12/8/2015</b>
Unique Well No.	DNR Well ID No.	Common Well Name <b>MW-305</b>	Final Static Water Level <b>Feet</b>		Surface Elevation <b>681.5 Feet</b>
					Borehole Diameter <b>8.5 in</b>
Local Grid Origin <input type="checkbox"/> (estimated: <input type="checkbox"/> ) or Boring Location <input checked="" type="checkbox"/> State Plane <b>401,473 N, 1,903,023 E S/C/N</b>			Lat <input type="checkbox"/> ° <input type="checkbox"/> ' <input type="checkbox"/> "		Local Grid Location <input type="checkbox"/> N <input type="checkbox"/> E <input type="checkbox"/> S <input type="checkbox"/> W
SE 1/4 of NE 1/4 of Section 26, T 73 N, R 15 W			Long <input type="checkbox"/> ° <input type="checkbox"/> ' <input type="checkbox"/> "		Feet <input type="checkbox"/> S <input type="checkbox"/> W
Facility ID		County <b>Wapello</b>		Civil Town/City/ or Village <b>Ottumwa</b>	


Sample Number and Type	Length Att. & Recovered (in)	Blow Counts	Depth in Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	PID/FID	Soil Properties					RQD/ Comments		
									Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200			
			0	TOPSOIL	TOPSOIL											
			1	GRAVEL	GP											
			2	FAT CLAY												
			3													
			4													
			5													
			6													
			7													
			8													
			9		CH											
			10													
			11	FAT CLAY, very dark grayish brown (10YR 3/2).												
S1	18	36 9 11	11													
			12													
			13	same as above except, brown (10YR 4/3).												
S2	22	37 14 22	13													
			14													
			15													
			16													

I hereby certify that the information on this form is true and correct to the best of my knowledge.

Signature 	Firm <b>SCS Engineers</b> 2830 Dairy Drive Madison, WI 53718	Tel: (608) 224-2830 Fax:
---------------	---	-----------------------------

Boring Number MW-305

Page 2 of 3

Sample		Blow Counts	Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	USCS	Graphic Log	Well Diagram	PID/FID	Soil Properties					RQD/ Comments
Number and Type	Length Att. & Recovered (in)								Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200	
S3	22	5 15 14 15	17	FAT CLAY (continued)										
S4	20	3 5 13 15	18 19		CH									
S5	24	4 5 7 11	20 21 22	FAT CLAY WITH SILT, dark gray (10YR 4/1).					M					
S6	20	7 11 15 20	23 24	same as above except, very dark brown (10YR 2/2).					M					
S7	24	4 8 11 12	25 26 27	same as above except, very dark gray (10YR 3/1).	CH				M					
S8	24	8 12 16 21	28 29						M					
S9	13	4 4 7 12	30 31 32						M					
S10	24	5 6 9	33 34	LEAN CLAY, very dark brown (10YR 2/2).					W					
S11	24	4 4 5 7	35 36 37		CL				W					
S12	22	2 2 3 5	38 39	same as above except, very dark grayish brown (10YR 3/2).					W					
S13	6	3 9 11	40 41 42	POORLY GRADED SANDY GRAVEL, fine, brown (10YR 4/3).	GPS				W				water @ 41.0 ft bgs.	

Boring Number MW-305

Page 3 of 3

Sample			Depth In Feet	Soil/Rock Description And Geologic Origin For Each Major Unit	U S C S	Graphic Log	Well Diagram	PID/FID	Soil Properties					RQD/ Comments	
Number and Type	Length Att. & Recovered (in)	Blow Counts							Standard Penetration	Moisture Content	Liquid Limit	Plasticity Index	P 200		
S14	22	23 50	43	POORLY GRADED SAND, medium grained, yellowish brown (10YR 5/4), (weathered bedrock). <i>(continued)</i>	SP										
			44												
			45												
S15	6	5 10 50	46		SP										
			47												
			48												
S16	6	50	49												
			50												
				End of Boring at 50 ft bgs.											

## **EXHIBIT B – 1974 SOIL LABORATORY RESULTS**

---

Alliant Energy  
Wisconsin Power and Light Company  
Ottumwa Generating Station  
Ottumwa, Iowa

Unstable Area Determination

APPENDICES

APPENDIX A MAPS

Vicinity Map (Figure 1)  
Plan of Borings (Figure 2)

APPENDIX B PROFILES

Generalized Soil and Rock Profiles (Figures 3, 4,  
5, 6, 7)

APPENDIX C LABORATORY TESTING PROGRAM

Discussion of Laboratory Investigation  
Table C-1 Summary of Laboratory Test Results-  
Split Spoon Samples  
Table C-2 Summary of Laboratory Test Results-  
Undisturbed Samples  
Table C-3 Summary of Compression Test Results-  
Rock Samples  
Table C-4 Summary of Tests on Limestone

APPENDIX D CONSOLIDATION TESTS

Table D-1 Summary of Consolidation Test Results  
Void Ratio vs. Log Vertical Effective Stress Curves  
Table D-2 Coefficient of Consolidation Summary

APPENDIX E TRIAXIAL TESTS

Table E-1 Summary of Consolidated-Undrained  
Triaxial Test Results  
Consolidated-Undrained Triaxial Test Data and Curves  
Table E-2 Summary of Unconsolidated-Undrained  
Triaxial Test Results  
Unconsolidated-Undrained Triaxial Test Data and Curves

APPENDIX F GRADATION TESTS

Table F-1 Summary of Sieve Analysis Results  
Gradation Curves

APPENDIX G COMPACTION TESTS

Table G-1 Summary of Compaction Test Results  
Moisture Content vs. Dry Density Curves

APPENDIX H PERMEABILITY TESTS

Table H-1 Summary of Permeability Test Results


APPENDIX I FIELD INVESTIGATION

Discussion of Field Investigation  
Boring Logs  
Table I-1 Summary of Piezometer Locations  
and Water Level Measurements  
June 19 and October 11, 1975  
Field Classification System




APPENDIX A

MAPS




VICINITY MAP  
OTTUMWA GENERATING STATION-UNIT I  
CHILlicothe, IOWA


FIGURE 1




ATEC ASSOCIATES





PLAN OF BORINGS  
OTTUMWA GENERATING STATION-UNIT 1  
CHILLICOTHE, IOWA FIGURE 2



SECTION A-A




SECTION B-B




GENERALIZED SOIL AND ROCK PROFILES  
 OTTUMWA GENERATING STATION-UNIT 1  
 CHILLICOTHE, IOWA

FIGURE 3

ATEC ASSOCIATES




SECTION C-C



SECTION D-D



ATEC ASSOCIATES



GENERALIZED SOIL AND ROCK PROFILES

OTTUMWA GENERATING STATION-UNIT 1  
 CHILLICOTHE, IOWA

FIGURE 4



HORIZONTAL SCALE 1 INCH=600 FEET  
 VERTICAL EXAGGERATION 10:1


0 500 1000 1500  
 FEET

GENERALIZED SOIL AND ROCK PROFILES  
 OTTUMWA GENERATING STATION-UNIT 1  
 CHILLICOTHE, IOWA


ATEC ASSOCIATES

FIGURE 5






SECTION K-K



SECTION L-L



GENERALIZED SOIL AND ROCK PROFILES

OTTUMWA GENERATING STATION - UNIT 1  
 CHILlicothe, IOWA

FIGURE 7

ATEC ASSOCIATES

APPENDIX C  
LABORATORY TESTING PROGRAM

Discussion of Laboratory Investigation

The split spoon samples were inspected and classified in accordance with the Unified Classification System and the field boring logs were edited as necessary. To aid in classifying the soils and to determine general soil characteristics, natural moisture and density determinations, Atterberg limits tests and sieve analyses were performed on selected samples. The organic contents of some samples were estimated from loss-on-ignition tests.

The undisturbed Shelby tube samples were extruded from the tubes, classified, and natural moistures and densities determined. Atterberg limits tests were performed on selected Shelby tube samples. In order to determine compressibility characteristics, twelve consolidation tests were performed on samples selected to be critical based on probable locations of structures and the results of field and laboratory tests. The conventional load increment ratio of two was employed throughout each test.

To provide undrained shear strength estimates, unconfined compression tests and unconsolidated-undrained triaxial tests were performed on some of the undisturbed samples. Consolidated-undrained triaxial tests (with pore pressure measurements) were performed to determine effective strength parameters. All consolidated-undrained triaxial samples were saturated prior to consolidation.

Compaction tests (according to both ASTM D-698 and ASTM D-1557) were performed on selected bag samples taken from potential on-site borrow areas. Strength and permeability tests were conducted on recompacted samples.



Ottumwa Generating Station-Unit 1  
(E-7566)

Unconfined compression tests were performed on certain of the rock core samples. Abrasion, soundness and chemical tests were conducted on some of the limestone samples from the eastern portion of the site.

The results of all tests are included in the remainder of Appendix C and Appendices D, E, F, G, H and I.

Table C-1  
SUMMARY OF LABORATORY TEST RESULTS  
Split-Spoon Samples

Boring No.	Depth ft	Natural Dry Density, lbs/cu.ft	Natural Moisture Content, %	Liquid Limit	Plastic Limit	Plasticity Index	Loss-on-Ignition %
1	1.0-2.5		37.3				4.8
1	3.5-5.0	93.5	29.7				
1	6.0-7.5		28.9				
1	8.5-10.0		28.5	37	25	12	
1	11.0-12.5		25.0				
1	13.5-15.0		26.7				
1	16.0-17.5	106.3	22.6	49	23	16	
1	18.5-20.0		22.5				
1	23.5-25.0		20.9	32	20	11	
2	1.0-2.5		22.8				
2	3.5-5.0		30.0				
2	6.0-7.5		28.1				
2	8.5-10.0	98.3	30.0	41	25	16	
2	11.0-12.5		20.2				
2	13.5-15.0		21.5				
2	16.0-17.5	108.2	20.2				
2	18.5-20.0		25.9				
2	23.5-25.0		26.8				
3	1.0-2.5		23.6				
3	3.5-5.0		16.4				
3	6.0-7.5		13.2				
3	8.5-10.0		17.5				
3	11.0-12.5	113.2	17.0	45	23	19	
3	13.5-15.0		22.2				
3	16.0-17.5		20.9				
3	18.5-20.0		23.0				
4	1.0-2.5		21.3				2.8
4	3.5-5.0		24.2				
4	6.0-7.5	104.1	23.5	30	21	9	
5	1.0-2.5		21.0				
5	3.5-5.0		22.5				
5	6.0-7.5		27.3				
5	8.5-10.0		16.7				
5	11.0-12.5		13.4				
5	13.5-15.0		14.9				
5	16.0-17.5		10.3				
5	18.5-20.0		24.1				

cont'd.

Table C-1

SUMMARY OF LABORATORY TEST RESULTS  
Split-Spoon Samples (cont'd.)

Boring No.	Depth ft	Natural Dry Density, lbs/cu.ft	Natural Moisture Content, %	Liquid Limit	Plastic Limit	Plasticity Index	Loss-on-Ignition %
6	1.0-2.5		17.8				
6	3.5-5.0		20.6				
6	6.0-7.5		25.1				
6	8.5-10.0		13.0				
6	11.0-12.5		14.0				
6	13.5-15.0		53.3	90	33	57	
7	1.0-2.5		29.9				
7	3.5-5.0		28.9				
7	6.0-7.5		27.6				
7	8.5-10.0		26.5	33	20	13	
7	11.0-12.5		25.8				
7	13.5-15.0		25.8				
7	16.0-17.5		25.2				
8	1.0-2.5		16.7				
8	3.5-5.0		24.6				
8	6.0-7.5	98.8	27.1	37	25	12	
8	8.5-10.0		10.9				
8	11.0-12.5		11.5				
9	1.0-2.5		28.7				
9	3.5-5.0		36.8				
9	6.0-7.5		26.7	61	20	41	
9	8.5-10.0		23.9				
9	11.0-12.5		26.7				
9	13.5-15.0		18.8				
9	16.0-17.5		21.4				
9	18.5-20.0		22.6	56	21	35	
10	1.0-2.5		28.0				1.5
10	3.5-5.0		30.0				4.2
10	6.0-7.5		28.7	56	25	31	
10	8.5-10.0		36.0				
11	1.0-2.5		21.2				
11	3.5-5.0		26.1				
11	6.0-7.5		27.1				
11	8.5-10.0		21.2				
11	11.0-12.5		21.8				
11	13.5-15.0		21.5				
11	16.0-17.5		19.2				
11	18.5-20.0		20.0				

cont'd.

Table C-1

SUMMARY OF LABORATORY TEST RESULTS  
Split-Spoon Samples(cont'd.)

Boring No.	Depth ft	Natural Dry Density, lbs/cu.ft	Natural Moisture Content, %	Liquid Limit	Plastic Limit	Plasticity Index	Loss-on-Ignition %
12	1.0-2.5		18.1				
12	3.5-5.0		19.7				
12	6.0-7.5		24.4				
12	8.5-10.0		22.6				
12	11.0-12.5		23.0				
12	13.5-15.0		21.8				
13	1.0-2.5		27.2				
13	3.5-5.0		26.1				
13	6.0-7.5		19.8				
13	18.5-20.0		18.3	57	18	39	
14	1.0-2.5		19.8				
14	3.5-5.0		23.1				
14	6.0-7.5		20.7	44	21	23	
14	8.5-10.0		26.1				
14	11.0-12.5		25.9				
14	13.5-15.0		19.5				
15	1.0-2.5		31.8				
15	3.5-5.0		26.3				
15	6.0-7.5		27.0				
15	8.5-10.0		33.2				
16	1.0-2.5		23.9				
16	3.5-5.0		27.1				
16	11.0-12.5		28.6				
16	13.5-15.0		29.4				
17	1.0-2.5		24.1				
17	3.5-5.0		22.0				
17	6.0-7.5		34.1				
17	8.5-10.0		31.2				
18	1.0-2.5		24.7				
18	3.5-5.0		24.6	57	18	39	
18	6.0-7.5		24.8				
18	16.0-17.5		18.0				
18	18.5-20.0		22.9	47	24	23	

cont'd.

Ottumwa Generating Station-Unit 1  
(E-7566)

Table C-1

SUMMARY OF LABORATORY TEST RESULTS  
Split-Spoon Samples (cont'd.)

Boring No.	Depth ft	Natural Dry Density, lbs/cu.ft	Natural Moisture Content, %	Liquid Limit	Plastic Limit	Plasticity Index	Loss-on-Ignition %
19	1.0-2.5		19.3				
19	3.5-5.0		15.8				
19	6.0-7.5		22.0				
19	8.5-10.0		16.9				
19	13.5-15.0		17.4				
19	16.0-17.5		18.5				
20	1.0-2.5		23.0				
20	3.5-5.0		20.7				
21	1.0-2.5		22.2				
21	3.5-5.0		28.5				
21	6.0-7.5		26.1				
21	8.5-10.0		34.6				
22	1.0-2.5		33.2				
22	3.5-5.0		32.1				
22	6.0-7.5		30.0				
22	8.5-10.0		33.4	38	23	15	
24	1.0-2.5		23.8				
24	3.5-5.0		25.2				
24	6.0-7.5		28.3	44	22	22	
24	8.5-10.0		22.6				
25	1.0-2.5		22.2				
25	3.5-5.0		25.1				
25	6.0-7.5		29.3				
25	8.5-10.0		26.5				
26	1.0-2.5		28.2				5.3
26	3.5-5.0		27.9				3.0
26	6.0-7.5		29.3				
26	8.5-10.0		30.3				
26	13.5-15.0		31.8	54	27	27	
27	1.0-2.5		30.5				4.1
27	3.5-5.0		30.9	51	24	27	4.5
27	6.0-7.5		33.9				
27	8.5-10.0		26.0	51	28	23	
27	11.0-12.5		29.8				

Ottumwa Generating Station-Unit 1  
(E-7566)

Table C-1

SUMMARY OF LABORATORY TEST RESULTS  
Split-Spoon Samples

Boring No.	Depth ft	Natural Dry Density, lbs/cu.ft	Natural Moisture Content, %	Liquid Limit	Plastic Limit	Plasticity Index	Loss-on-Ignition %
28	3.5-5.0		18.5				
29	13.5-15.0		22.0	60	20	40	
30	3.0-5.0		26.2				
30	8.5-10.0		25.3	35	21	14	
30	13.5-15.0		19.3				
31	3.5-5.0		28.7				
31	8.5-10.0		24.4				
32	3.5-5.0		22.5				
33	23.5-25.0		29.8	57	21	36	
34	3.5-5.0		23.0				
35	3.5-5.0		27.6				
35	8.5-10.0		27.6				
36	1.0-2.5		20.7				3.1
36	3.5-5.0		25.3				
36	6.0-7.5		24.2				
36	8.5-10.0		24.2				
36	11.0-12.5		23.8	36	16	20	
36	13.5-15.0		25.5				
36	28.5-30.0		22.7				
37	1.0-2.5		21.4				
37	3.5-5.0		21.0				
37	6.0-7.5		23.4				
37	8.5-10.0		21.5				
37	11.0-12.5		20.2				
37	13.5-15.0		20.7				
37	16.0-17.5		17.5				
37	18.5-20.0		22.3				
38	1.0-2.5		18.6				
38	3.5-5.0		21.1				
38	6.0-7.5		27.7				
38	8.5-10.0		27.3				
38	11.0-12.5		25.8				
38	13.5-15.0		43.2				
38	23.5-25.0		29.2	43	22	21	

Ottumwa Generating Station-Unit 1  
(E-7566)

Table C-1 SUMMARY OF LABORATORY TEST RESULTS  
Split-Spoon Samples

Boring No.	Depth ft	Natural Dry Density, lbs/cu.ft	Natural Moisture Content, %	Liquid Limit	Plastic Limit	Plasticity Index	Loss-on-Ignition %
39	1.0-2.5		28.7				5.6
39	3.5-5.0		32.8				
39	6.0-7.5		26.5				
39	8.5-10.0		29.5				
39	11.0-12.5		35.9				
39	13.5-15.0		35.2				
39	16.0-17.0		11.4				
40	1.0-2.5		29.0				
40	3.5-5.0		31.5	56	18	38	
40	6.0-7.5		27.2				
40	8.5-9.0		27.4				
41	1.0-2.5		21.3				4.2
41	3.5-5.0		16.1				
41	6.0-7.5		22.2				
41	8.5-10.0		23.7				
41	11.0-11.8		25.3				
42	1.0-2.5		20.4				
42	3.5-5.0		19.9				
42	6.0-7.5		20.3				
42	8.5-10.0		26.2				
42	11.0-12.5		25.7				
43	3.5-5.0		25.4				
43	8.5-10.0		26.1				
43	13.5-15.0		21.0				
43	18.5-20.0		24.3				
44	1.0-2.5		11.9				5.0
44	3.5-5.0		11.3				
44	16.0-17.5		23.3				
45	3.5-5.0		17.0				
45	8.5-10.0		18.3				
45	13.5-15.0		18.9				
45	18.5-20.0		20.4				
45	23.5-25.0		23.2				
46	1.0-2.5		25.0				3.3
46	3.5-5.0		27.2				
46	6.0-7.5		27.4				
46	8.5-10.0		25.2	32	13	19	

Ottumwa Generating Station-Unit 1  
(E-7566)

Table C-1 SUMMARY OF LABORATORY TEST RESULTS  
Split-Spoon Samples

Boring No.	Depth ft	Natural Dry Density, lbs/cu.ft	Natural Moisture Content, %	Liquid Limit	Plastic Limit	Plasticity Index	Loss-on-Ignition %
46	11.0-12.5		23.8				
46	13.5-15.0		25.4				
46	16.0-17.5		22.5				
46	18.5-20.0		27.0				
47	3.5-5.0		25.2				
47	13.5-15.0		24.2				2.8
47	18.5-20.0		30.9	40	22	18	
48	1.0-2.5		22.9				
48	3.5-5.0		25.0				
48	6.0-7.5		25.4				
48	8.5-10.0		24.6				
48	16.0-17.5		40.4				
49	3.5-5.0		22.5				
49	8.5-10.0		25.2				
49	13.5-15.0		31.2				
49	18.5-20.0		32.1				
50	3.5-5.0		18.8				
50	8.5-10.0		17.9				
50	13.5-15.0		24.3				
50	18.5-20.0		30.6				
51	3.5-5.0		13.5				
51	8.5-10.0		16.5				
51	13.5-15.0		24.1				
51	18.5-20.0		28.0	32	17	15	
52	1.0-2.5		24.4				
52	3.5-5.0		24.1	37	18	19	

Ottumwa Generating Station-Unit 1  
(E-7566)

Ottumwa Generating Station-Unit 1  
(E-7566)

Table C-2

SUMMARY OF LABORATORY TEST RESULTS  
Undisturbed Samples

Boring No.	Depth, ft	Natural Dry Density, lbs/cu. ft	Natural Moisture Content, %	Atterberg Limits %			Unconfined Compressive Strength, tsf
				LL	PL	PI	
1A	6.0-8.0	96.4	28.2				0.71
1A	8.0-10.0	98.4	26.6				0.96 *
4A	3.0-5.0	100.2	24.8				0.63
4A	6.0-8.0	101.9	23.6				
8A	5.0-7.0	95.2	28.2				*
8A	7.0-9.0	99.5	25.2				1.15
9A	4.0-5.0	79.8	39.7				
9A	5.0-6.0	94.6	29.2				
9A	6.0-6.5		46.3				
9A	6.5-8.0	100.5	26.3				1.88
9A	13.0-14.5	106.5	22.5				**
9A	18.0-19.0	96.4	27.6				
9A	19.0-20.0	110.0	19.6				0.75
9A	22.0-24.0	99.9	25.7				0.42
10A	3.0-5.0	90.8	30.0				*
10A	5.0-7.0	94.4	28.5				**
10A	7.0-9.0	97.5	26.4				* **
12A	2.0-4.0	93.1	31.0				
12A	4.0-6.0	100.6	23.3				
12A	7.0-9.0	104.4	22.6				
14A	4.0-6.0	94.5	29.3				
14A	8.0-10.0	94.6	28.5				
14A	10.0-12.0	98.5	27.9				
15A	2.0-4.0	94.7	28.8				
15A	5.0-7.0	93.4	28.9				
15A	8.0-10.0	88.4	33.7				
15A	10.0-12.0	95.7	25.5				
18A	3.0-5.0	101.0	25.0				1.20
18A	19.0-21.0	107.8	20.6				**
26A	3.0-5.0	88.8	31.9				0.14
26A	9.0-9.5		34.4				
26A	9.5-11.0	97.3	26.9				0.97
26A	13.0-15.0	87.6	33.6				0.36 *
27	6.0-8.0	90.5	31.2				0.74 *
27A	13.0-15.0	92.6	30.9				0.91

cont'd.

Table C-2

SUMMARY OF LABORATORY TEST RESULTS  
Undisturbed Samples

Boring No.	Depth, ft	Natural Dry Density, lbs/cu. ft	Natural Moisture Content, %	Atterberg Limits %			Unconfined Compressive Strength, tsf
				LL	PL	PI	
36	10.0-12.0	101.4	22.5				0.81
36	12.0-14.0	104.9	22.1				
36	18.0-20.0	103.3	24.1				
36	23.0-25.0	104.7	20.3				
36	28.0-29.9	95.2	27.4				1.11
38	7.0-8.9	93.3	28.5	37	20	17	0.66 *
38	9.0-11.0	88.1	30.5				
38	14.0-15.9	97.2	30.9				1.18
38	18.0-20.0	103.3	23.3				
38	23.0-25.0	107.1	19.6				
39	3.0-5.0	85.7	32.4	52	25	27	0.70 *
39	11.0-13.0	89.5	29.3				
39	13.0-15.0	82.0	38.8	42	25	17	* **
40	3.0-5.0	87.5	31.9				1.24
41	3.0-5.0	105.1	15.0				
41	8.0-10.0	99.3	22.3	41	16	25	**
42	2.0-4.0	102.1	20.1				
42	10.0-12.0	96.5	26.6	34	22	12	
43	3.0-5.0	98.3	20.8				2.89
43	8.0-10.0	99.0	26.7				1.00 **
43	13.0-15.0	104.0	23.1				1.07
43	18.0-20.0	104.1	22.1	32	15	17	**
44	3.0-5.0	106.2	12.7	29	16	13	
45	3.0-5.0	98.8	20.0				
45	9.0-11.0	111.4	17.0	35	11	24	0.97 **
45	11.0-13.0	111.9	19.5				
45	18.0-19.8	105.3	21.2				
45	28.0-30.0	109.8	19.3				
46	3.0-4.8	98.6	22.0				
46	10.0-12.0	104.3	22.9				
46	18.0-19.9	102.6	23.3				1.04 **
46	28.0-30.0	102.7	23.8				

cont'd.

Table C-2 SUMMARY OF LABORATORY TEST RESULTS  
Undisturbed Samples

Boring No.	Depth, ft	Natural Dry Density, lbs/cu.ft	Natural Moisture Content, %	Atterberg Limits %			Unconfined Compressive Strength, tsf
				LL	PL	PI	
48	8.0-10.0	96.5	25.4				0.81
48	16.0-17.9	82.9	37.7	53	23	30	* **
49	8.0-10.0	99.2	24.1				0.46
49	13.0-15.0	96.5	27.5	38	18	20	0.76 *
49	18.0-20.0	96.9	28.0				
50	8.0-10.0	108.7	18.1				1.32
50	19.0-21.0	86.5	34.5	49	25	24	0.62 * **
51	8.0-10.0	103.3	21.5				0.72
51	19.0-21.0	96.6	23.3				
52	3.0-5.0	94.8	24.4				.85
52	6.0-8.0	108.3	16.2				
52	8.0-10.0	111.5	15.4				

\* See Appendix D for Consolidation Test Results

\*\* See Appendix E for Triaxial Test Results

Table C-3 SUMMARY OF COMPRESSION TEST RESULTS  
Rock Samples

Boring No.	Depth ft	Sample Height, in.	Sample Diameter, in.	Unconfined Compressive Strength, psi	Rock Description
1	43.0	4.38	2.03	2460	Gray Sandstone
2A	38.6	4.67	2.06	14070	White Limestone
2A	44.3	4.25	2.06	7030	Gray Sandy Shale and Limestone
2A	51.3	4.44	2.06	5990	Gray Sandstone
2A	57.7	4.44	2.06	12720	White Limestone
4	20.0	4.88	2.00	1070	Green Sandstone
4	29.4	3.88	2.06	13170	White Limestone
4	46.3	4.53	2.06	5160	Gray Sandstone
6	25.0	4.97	2.03	2500	Dark Gray Shaly Sandstone
7	27.5	4.44	2.06	14520	Gray Limestone
19	29.5	3.44	1.88	2670	Gray Sandstone
23	29.4	4.88	1.88	9270	White Limestone
28	18.7	4.63	2.06	14790	Gray Limestone
29	36.1	3.69	2.06	19150	Gray Limestone
29	42.8	5.00	2.06	16970	Gray Sandstone
30	25.0	5.94	2.06	14540	White Limestone
31	29.5	6.00	2.00	8000	Gray Limestone
32	38.5	5.63	2.06	16490	Gray Limestone
33	28.7	5.25	2.06	15030	Gray Sandstone
33	36.0	4.38	2.06	5820	Gray Sandstone
34	15.7	5.69	2.06	6550	Gray Shaly Limestone
35	26.7	4.38	2.06	12850	Gray Limestone
35	28.2	6.00	2.06	16730	Green Shale
35	30.0	6.00	2.06	17460	White Limestone
4I	31.8	6.00	2.06	14000	Green Sandstone
43	41.0	3.88	2.00	5150	Gray Sandstone
43	57.9	6.00	2.06	6788	White Limestone
47	31.0	4.69	2.00	6750	Gray Sandstone
48	22.0	4.13	2.06	5820	Gray Sandstone
50	26.2	5.38	2.06	4850	Gray Sandstone
51	30.5	5.06	2.06	5820	Gray Sandstone

Ottumwa Generating Station-Unit 1  
(E-7566)

Table C-4 SUMMARY OF TESTS ON LIMESTONE

1. Test for Determining the Soundness of Coarse Aggregate by Freezing and Thawing  
(ISHC Test Method No 211-Method A)

Sample: Boring No 15, 24.2 to 26.4 ft depth  
Boring No 15, 29.9 to 31.9 ft depth  
Boring No 15, 31.9 to 39.6 ft depth  
Boring No 16, 31.0 to 32.4 ft depth  
Boring No 16, 32.4 to 36.0 ft depth  
Boring No 17, 24.3 to 29.3 ft depth  
Boring No 22, 25.6 to 30.3 ft depth

Results: Loss - 16.8%

2. Resistance to Abrasion of Coarse Aggregate by use of the Los Angeles Machine (RASHTO T 96)

Sample: (Same as above)

Results: Loss - 27.8%

3. Analysis of Limestone (ASTM C 25)

Sample: Boring No 15, 31.9 to 40.0 ft depth

Results:

Insoluble matter	1.29%
Total neutralizing value in terms of Ca CO <sub>3</sub>	98.25%
Calcium Carbonate (Ca CO <sub>3</sub> )	97.00%
Magnesium Carbonate (Mg CO <sub>3</sub> )	1.25%

APPENDIX D

CONSOLIDATION TESTS

Ottumwa Generating Station-Unit 1  
(E-7566)

COEFFICIENT OF CONSOLIDATION SUMMARY

Table D-2 Boring No.	Depth, ft	Load Increment, tons/sq.ft	Coefficient of Consolidation cm <sup>2</sup> /sec	Coefficient of Compressibility, cm <sup>2</sup> /kg	Average Void Ratio	Estimated Coefficient of Permeability, cm/sec
1A	8.5	0.25 to 0.5	1.69 x 10 <sup>-3</sup>	0.024	0.839	2.2 x 10 <sup>-4</sup>
1A	8.5	0.5 to 1.0	5.19 x 10 <sup>-3</sup>	0.030	0.829	0.85 x 10 <sup>-4</sup>
1A	8.5	1.0 to 2.0	3.78 x 10 <sup>-3</sup>	0.031	0.806	0.65 x 10 <sup>-4</sup>
1A	8.5	2.0 to 4.0	3.43 x 10 <sup>-3</sup>	0.027	0.764	0.51 x 10 <sup>-4</sup>
1A	8.5	4.0 to 8.0	4.26 x 10 <sup>-3</sup>	0.016	0.706	0.40 x 10 <sup>-4</sup>
8A	6.0	0.25 to 0.5	1.05 x 10 <sup>-3</sup>	0.016	0.816	0.92 x 10 <sup>-5</sup>
8A	6.0	0.5 to 1.0	1.31 x 10 <sup>-3</sup>	0.018	0.810	1.29 x 10 <sup>-5</sup>
8A	6.0	1.0 to 2.0	1.47 x 10 <sup>-3</sup>	0.017	0.797	1.38 x 10 <sup>-5</sup>
8A	6.0	2.0 to 4.0	1.25 x 10 <sup>-3</sup>	0.017	0.772	1.16 x 10 <sup>-5</sup>
8A	6.0	4.0 to 8.0	0.98 x 10 <sup>-3</sup>	0.015	0.725	0.86 x 10 <sup>-5</sup>
10A	4.0	0.25 to 0.5	3.95 x 10 <sup>-4</sup>	0.084	0.934	1.71 x 10 <sup>-5</sup>
10A	4.0	0.5 to 1.0	4.99 x 10 <sup>-4</sup>	0.086	0.907	1.72 x 10 <sup>-5</sup>
10A	4.0	1.0 to 2.0	3.67 x 10 <sup>-4</sup>	0.050	0.875	0.97 x 10 <sup>-5</sup>
10A	4.0	2.0 to 4.0	4.48 x 10 <sup>-4</sup>	0.035	0.805	0.86 x 10 <sup>-5</sup>
10A	4.0	4.0 to 8.0	3.35 x 10 <sup>-4</sup>	0.020	0.731	0.37 x 10 <sup>-5</sup>
10A	7.5	0.25 to 0.5	1.0 x 10 <sup>-4</sup>	0.156	0.916	8.1 x 10 <sup>-6</sup>
10A	7.5	0.5 to 1.0	0.9 x 10 <sup>-4</sup>	0.110	0.869	5.2 x 10 <sup>-6</sup>
10A	7.5	1.0 to 2.0	1.0 x 10 <sup>-4</sup>	0.089	0.807	3.8 x 10 <sup>-6</sup>
10A	7.5	2.0 to 4.0	1.0 x 10 <sup>-4</sup>	0.039	0.733	2.2 x 10 <sup>-6</sup>
10A	7.5	4.0 to 8.0	0.9 x 10 <sup>-4</sup>	0.020	0.576	1.1 x 10 <sup>-6</sup>
26A	13.5	0.25 to 0.5	1.60 x 10 <sup>-4</sup>	0.120	0.807	1.06 x 10 <sup>-5</sup>
26A	13.5	0.5 to 1.0	1.84 x 10 <sup>-4</sup>	0.084	0.771	0.85 x 10 <sup>-5</sup>
26A	13.5	1.0 to 2.0	2.01 x 10 <sup>-4</sup>	0.051	0.725	0.57 x 10 <sup>-5</sup>
26A	13.5	2.0 to 4.0	2.84 x 10 <sup>-4</sup>	0.029	0.671	0.47 x 10 <sup>-5</sup>
26A	13.5	4.0 to 8.0	2.83 x 10 <sup>-4</sup>	0.015	0.602	0.26 x 10 <sup>-5</sup>

cont'd.

Ottumwa Generating Station-Unit 1  
(E-7566)

Table D-1

SUMMARY OF CONSOLIDATION TEST RESULTS

Boring No.	Depth, ft	Existing Effective Overburden Pressure, tsf	Compression Index	Initial Moisture Content, %	Initial Void Ratio	Initial Dry Density, lbs/cu.ft
1A	8.5	0.529	0.211	27.8	0.848	94.3
8A	6.0	0.821	0.218	26.7	0.821	90.7
10A	4.0	0.246	0.258	32.1	0.962	88.7
10A	7.5	0.462	0.261	34.9	0.971	85.1
26A	13.5	0.556	0.205	30.9	0.864	91.4
27A	7.0	0.416	0.238	31.0	0.958	88.6
38A	8.5	0.501	0.282	28.2	0.888	81.9
39A	4.5	0.262	0.235	27.8	0.875	91.2
39A	14.5	0.819	0.184	32.9	0.937	89.7
48A	17.5	0.915	0.369	37.5	1.077	84.5
49A	14.0	0.795	0.257	29.1	0.861	94.0
50A	20.0	0.945	0.304	37.1	1.064	84.8




COEFFICIENT OF CONSOLIDATION SUMMARY

Table D-2		Load Increment, tons/sq.ft	Coefficient of Consolidation cm <sup>2</sup> /sec.	Coefficient of Compressibility, cm <sup>2</sup> /kg	Average Void Ratio	Estimated Coefficient of Permeability, cm/sec
Boring No.	Depth, ft					
27A	7.0	0.25 to 0.5	1.55 x 10 <sup>-3</sup>	0.060	0.931	4.81 x 10 <sup>-5</sup>
27A	7.0	0.5 to 1.0	0.84 x 10 <sup>-3</sup>	0.050	0.912	2.19 x 10 <sup>-5</sup>
27A	7.0	1.0 to 2.0	0.81 x 10 <sup>-3</sup>	0.037	0.881	1.58 x 10 <sup>-5</sup>
27A	7.0	2.0 to 4.0	1.03 x 10 <sup>-3</sup>	0.028	0.834	1.48 x 10 <sup>-5</sup>
27A	7.0	4.0 to 8.0	0.78 x 10 <sup>-3</sup>	0.018	0.771	0.79 x 10 <sup>-5</sup>
38A	8.5	0.25 to 0.5	5.73 x 10 <sup>-3</sup>	0.032	0.881	3.45 x 10 <sup>-4</sup>
38A	8.5	0.5 to 1.0	7.41 x 10 <sup>-3</sup>	0.028	0.869	1.11 x 10 <sup>-4</sup>
38A	8.5	1.0 to 2.0	3.38 x 10 <sup>-3</sup>	0.026	0.848	0.48 x 10 <sup>-4</sup>
38A	8.5	2.0 to 4.0	2.42 x 10 <sup>-3</sup>	0.031	0.805	0.42 x 10 <sup>-4</sup>
38A	8.5	4.0 to 8.0	1.91 x 10 <sup>-3</sup>	0.021	0.735	0.23 x 10 <sup>-4</sup>
39A	4.5	0.25 to 0.5	2.9 x 10 <sup>-4</sup>	0.036	0.867	0.55 x 10 <sup>-5</sup>
39A	4.5	0.5 to 1.0	7.3 x 10 <sup>-4</sup>	0.054	0.848	2.13 x 10 <sup>-5</sup>
39A	4.5	1.0 to 2.0	7.6 x 10 <sup>-4</sup>	0.035	0.817	1.46 x 10 <sup>-5</sup>
39A	4.5	2.0 to 4.0	7.9 x 10 <sup>-4</sup>	0.027	0.772	1.20 x 10 <sup>-5</sup>
39A	4.5	4.0 to 8.0	6.0 x 10 <sup>-4</sup>	0.017	0.711	5.9 x 10 <sup>-5</sup>
39A	14.5	0.25 to 0.5	6.43 x 10 <sup>-3</sup>	0.064	0.908	2.2 x 10 <sup>-4</sup>
39A	14.5	0.5 to 1.0	6.29 x 10 <sup>-3</sup>	0.048	0.889	1.6 x 10 <sup>-4</sup>
39A	14.5	1.0 to 2.0	5.42 x 10 <sup>-3</sup>	0.033	0.861	0.9 x 10 <sup>-4</sup>
39A	14.5	2.0 to 4.0	7.78 x 10 <sup>-3</sup>	0.022	0.822	0.9 x 10 <sup>-4</sup>
39A	14.5	4.0 to 8.0	6.31 x 10 <sup>-3</sup>	0.013	0.773	0.5 x 10 <sup>-4</sup>
48A	17.5	0.25 to 0.5	0.65 x 10 <sup>-3</sup>	0.040	1.067	1.25 x 10 <sup>-5</sup>
48A	17.5	0.5 to 1.0	1.20 x 10 <sup>-3</sup>	0.042	1.052	2.45 x 10 <sup>-5</sup>
48A	17.5	1.0 to 2.0	0.63 x 10 <sup>-3</sup>	0.049	1.017	1.52 x 10 <sup>-5</sup>
48A	17.5	2.0 to 4.0	0.47 x 10 <sup>-3</sup>	0.050	0.942	1.21 x 10 <sup>-5</sup>
48A	17.5	4.0 to 8.0	0.32 x 10 <sup>-3</sup>	0.028	0.837	0.48 x 10 <sup>-5</sup>

cont'd.

COEFFICIENT OF CONSOLIDATION SUMMARY


Table D-2		Load Increment, tons/sq.ft	Coefficient of Consolidation cm <sup>2</sup> /sec.	Coefficient of Compressibility, cm <sup>2</sup> /kg	Average Void Ratio	Estimated Coefficient of Permeability, cm/sec
Boring No.	Depth, ft					
49A	14.0	0.25 to 0.5	3.30 x 10 <sup>-3</sup>	0.056	0.847	1.00 x 10 <sup>-6</sup>
49A	14.0	0.5 to 1.0	4.27 x 10 <sup>-3</sup>	0.042	0.830	0.98 x 10 <sup>-6</sup>
49A	14.0	1.0 to 2.0	4.15 x 10 <sup>-3</sup>	0.029	0.805	0.67 x 10 <sup>-6</sup>
49A	14.0	2.0 to 4.0	4.36 x 10 <sup>-3</sup>	0.029	0.767	0.72 x 10 <sup>-6</sup>
49A	14.0	4.0 to 8.0	2.36 x 10 <sup>-3</sup>	0.016	0.713	0.22 x 10 <sup>-6</sup>
50A	20.0	0.25 to 0.5	5.78 x 10 <sup>-3</sup>	0.076	1.042	2.15 x 10 <sup>-4</sup>
50A	20.0	0.5 to 1.0	7.26 x 10 <sup>-3</sup>	0.062	1.017	2.23 x 10 <sup>-4</sup>
50A	20.0	1.0 to 2.0	3.25 x 10 <sup>-3</sup>	0.055	0.945	0.92 x 10 <sup>-4</sup>
50A	20.0	2.0-4.0	1.82 x 10 <sup>-3</sup>	0.043	0.905	0.40 x 10 <sup>-4</sup>
50A	20.0	4.0 to 8.0	2.76 x 10 <sup>-3</sup>	0.023	0.816	0.35 x 10 <sup>-4</sup>



CONSOLIDATION TEST RESULTS

ATEC ASSOCIATES


CN-1



CONSOLIDATION TEST RESULTS


ATEC ASSOCIATES

CN-1




ATEC ASSOCIATES

CN-1




ATEC ASSOCIATES

CN-1




ATEC ASSOCIATES

CN-1




ATEC ASSOCIATES

CN-1




ATEC ASSOCIATES

CN-1




ATEC ASSOCIATES

CN-1




ATEC ASSOCIATES

CN-1




ATEC ASSOCIATES

CN-1



ATEC ASSOCIATES

CN-1



ATEC ASSOCIATES

CN-1

Ottawa Generating Station-Unit 1  
(E-7566)



Table E-1 SUMMARY OF CONSOLIDATED-UNDRAINED  
TRIAxIAL TEST RESULTS

Boring No.	Depth, ft	c', kg/cm <sup>2</sup>	φ', degrees	Effective Confining Pressures tsf	Dry Densities, lbs/cu. ft	% Final Water Contents	Strain Rate %/min
9A	13.0-14.5	0.25	31	.35	101.2	26.2	1.0
				1.06	107.7	20.4	
				1.76	101.1	23.8	
10A	5.0-7.0	0.30	34.5	1.41	94.4	25.8	1.0
				1.82	91.6	27.0	
10A	7.0-9.0	0.30	29	1.06	91.3	27.7	1.0
				2.11	88.1	28.5	
				3.17	96.3	22.8	
18A	19.0-21.0	0.20	34	0.70	107.8	22.2	0.5
				1.41	104.5	19.9	
				2.11	105.7	21.3	
39A	13.0-15.0	0	34	1.06	89.1	30.0	.074
				2.11	82.9	29.4	
				3.17	90.0	27.1	
43A	18.0-20.0	0.3	31	0.35	104.1	23.6	0.5
				1.06	105.3	22.3	
				1.76	105.0	21.6	
48A	16.0-17.9	0	31	1.06	88.3	31.0	.071
				2.11	88.1	28.9	
				3.17	85.2	30.2	
32A *	0.0-7.0	0	40	0.70	109.2	23.1	.071
				1.41	109.6	21.5	
				2.11	109.7	22.0	

\* Samples recompactd from disturbed bag sample to approximately 95 percent of modified Proctor maximum dry density.

APPENDIX E  
TRIAxIAL TESTS







PROJECT NO.: E-7566	
BORING NO.: 9A	DEPTH: 13.0-14.5
LIQUID LIMIT: _____	PLASTIC LIMIT: _____
SOIL CLASSIFICATION: CH	
TYPE OF TEST: CONSOLIDATION - UNDRAINED	
RATE OF STRAIN: 1.0% / MIN.	
TEST DESIGNATION	● ■ ▼ ○
INITIAL WATER CONTENT, %	24.9 21.0 24.9
INITIAL DRY DENSITY, PCF	101.2 107.7 101.1
INITIAL SAMPLE HEIGHT, IN.	2.80 2.80 2.80
INITIAL SAMPLE DIAMETER, IN.	1.40 1.40 1.40
FINAL BACK PRESSURE, TSF	1.97 4.08 1.62
TOTAL CONSOLIDATION PRESSURE, TSF	2.32 5.14 3.38
EFFECTIVE CONFINING PRESSURE, TSF	0.35 1.06 1.76
FINAL WATER CONTENT, %	26.2 20.4 23.8
REMARKS:	

TRIAXIAL TEST RESULTS

ATEC ASSOCIATES

TX-1





PROJECT NO.: E-7566	
BORING NO.: 10A	DEPTH: 5.0-7.0
LIQUID LIMIT: 56	PLASTIC LIMIT: 25
SOIL CLASSIFICATION: CH	
TYPE OF TEST: CONSOLIDATED - UNDRAINED	
RATE OF STRAIN: 1.0% / MIN.	
TEST DESIGNATION	● ■ ▼ ○
INITIAL WATER CONTENT, %	28.5 30.7
INITIAL DRY DENSITY, PCF	94.4 91.6
INITIAL SAMPLE HEIGHT, IN.	2.80 2.80
INITIAL SAMPLE DIAMETER, IN.	1.40 1.40
FINAL BACK PRESSURE, TSF	1.62 1.97
TOTAL CONSOLIDATION PRESSURE, TSF	3.03 4.79
EFFECTIVE CONFINING PRESSURE, TSF	1.41 2.82
FINAL WATER CONTENT, %	25.8 27.0
REMARKS:	

TRIAXIAL TEST RESULTS



ATEC ASSOCIATES

TX-1





PROJECT NO.:		E-7566			
BORING NO.:	10A	DEPTH:	7.0 - 9.0		
LIQUID LIMIT:	56	PLASTIC LIMIT:	25		
SOIL CLASSIFICATION: CH					
TYPE OF TEST: CONSOLIDATED - UNDRAINED					
RATE OF STRAIN: 1.0 % / MIN.					
TEST DESIGNATION		●	■	▼	○
INITIAL	WATER CONTENT, %	32.1	32.7	27.5	
	DRY DENSITY, PCF	91.3	88.1	96.3	
	SAMPLE HEIGHT, IN.	2.80	2.80	2.80	
	SAMPLE DIAMETER, IN.	1.40	1.40	1.40	
	FINAL BACK PRESSURE, TSF	2.32	2.68	1.62	
	TOTAL CONSOLIDATION PRESSURE, TSF	3.38	4.79	4.79	
	EFFECTIVE CONFINING PRESSURE, TSF	1.06	2.11	3.17	
	FINAL WATER CONTENT, %	27.7	28.5	22.8	
REMARKS:					

TRIAXIAL TEST RESULTS



PROJECT NO.:		E-7566			
BORING NO.:	18A	DEPTH:	19.0 - 21.0		
LIQUID LIMIT:	47	PLASTIC LIMIT:	24		
SOIL CLASSIFICATION: CL					
TYPE OF TEST: CONSOLIDATED - UNDRAINED					
RATE OF STRAIN: 0.5 % / MIN.					
TEST DESIGNATION		●	■	▼	○
INITIAL	WATER CONTENT, %	20.6	23.0	20.9	
	DRY DENSITY, PCF	107.8	104.5	105.7	
	SAMPLE HEIGHT, IN.	5.60	5.60	5.60	
	SAMPLE DIAMETER, IN.	2.86	2.87	2.87	
	FINAL BACK PRESSURE, TSF	1.62	1.62	2.68	
	TOTAL CONSOLIDATION PRESSURE, TSF	2.32	3.03	4.79	
	EFFECTIVE CONFINING PRESSURE, TSF	0.70	1.41	2.11	
	FINAL WATER CONTENT, %	22.2	19.9	21.3	
REMARKS:					

TRIAXIAL TEST RESULTS





PROJECT NO.: E-7566			
BORING NO.: 39A		DEPTH: 13.0 - 15.0	
LIQUID LIMIT: 42		PLASTIC LIMIT: 25	
SOIL CLASSIFICATION: CL			
TYPE OF TEST: CONSOLIDATED - UNDRAINED			
RATE OF STRAIN: 0.074% / MIN.			
TEST DESIGNATION			
INITIAL	●	■	▼
WATER CONTENT, %	32.8	38.4	33.9
DRY DENSITY, PCF	89.1	82.9	90.0
SAMPLE HEIGHT, IN.	2.80	2.80	2.80
SAMPLE DIAMETER, IN.	1.40	1.40	1.40
FINAL BACK PRESSURE, TSF	1.97	1.27	1.62
TOTAL CONSOLIDATION PRESSURE, TSF	3.03	3.38	4.79
EFFECTIVE CONFINING PRESSURE, TSF	1.06	2.11	3.17
FINAL WATER CONTENT, %	30.0	27.4	27.1
REMARKS:			

TRIAXIAL TEST RESULTS

ATEC ASSOCIATES

TX-1




PROJECT NO.: E-7566			
BORING NO.: 43A		DEPTH: 18.0 - 20.0	
LIQUID LIMIT: 32		PLASTIC LIMIT: 15	
SOIL CLASSIFICATION: CL			
TYPE OF TEST: CONSOLIDATED - UNDRAINED			
RATE OF STRAIN: 0.5% / MIN.			
TEST DESIGNATION			
INITIAL	●	■	▼
WATER CONTENT, %	22.2	22.2	21.1
DRY DENSITY, PCF	104.1	105.0	105.3
SAMPLE HEIGHT, IN.	5.60	5.37	5.60
SAMPLE DIAMETER, IN.	2.87	2.87	2.86
FINAL BACK PRESSURE, TSF	1.27	1.97	2.32
TOTAL CONSOLIDATION PRESSURE, TSF	1.62	3.03	4.06
EFFECTIVE CONFINING PRESSURE, TSF	0.35	1.06	1.76
FINAL WATER CONTENT, %	23.6	22.3	21.6
REMARKS:			


TRIAXIAL TEST RESULTS

ATEC ASSOCIATES

TX-1



TRIAxIAL TEST RESULTS



TRIAxIAL TEST RESULTS

Ottumwa Generating Station-Unit 1  
(E-7566)


Table E-2 SUMMARY OF UNCONSOLIDATED-UNDRAINED  
TRIAXIAL TEST RESULTS

Boring No.	Depth, ft	Total Confining Pressure, tsf	Dry Density, lbs/cu.ft	Moisture Content, %	c (For $\beta=0$ ), tons/sq.ft	Remarks
41A	8.0-10.0	0.53	102.6	20.9	0.55	Small hole noted in membrane after test
43A	8.0-10.0	0.53	98.1	25.6	0.54	
45A	9.0-11.0	0.60	113.1	16.9	1.05	
46A	18.0-19.9	0.95	96.8	26.6	0.56	
50A	19.0-21.0	0.90	88.6	34.1	0.37	
32	0.0-7.0	1.41	104.6	19.3	0.85	Sample recompacted from disturbed Bag Sample at approx. 90% of modified Proctor maximum dry density
32	0.0-7.0	1.41	109.5	14.9	8.85 *	Sample recompacted from disturbed Bag Sample at approx. 95% of modified Proctor maximum dry density
32	0.0-7.0	1.41	108.5	20.1	3.38 **	Sample recompacted from disturbed Bag Sample at approx. 95% of modified Proctor maximum dry density

Note: All tests performed at a strain rate of approximately 1.0 percent per minute.

\* Unconfined compressive strength for similarly recompacted sample - 10.49 tons/sq.ft

\*\* Unconfined compressive strength for similarly recompacted sample - 5.37 tons/sq.ft



ATEC ASSOCIATES

TX-1

## **EXHIBIT C – CONVERSION OF BLOWCOUNT TO SOIL STRENGTH**

---

Alliant Energy  
Wisconsin Power and Light Company  
Ottumwa Generating Station  
Ottumwa, Iowa

Unstable Area Determination

nt and procedure

cedure of ASTM D-1586  
revisions:

h 20-in.-long split  
g 30 blows per foot, 12-  
of drive is permissible.  
ch 6 in. of penetration.  
ith water or drilling

s pumped from a central  
d while the drawdown of  
g from the well is ob-  
piezometers or obser-  
le 3 to 5 observation  
easing intervals along  
arated by 90° central

is raised or lowered  
position and readings  
vels at periodic inter-  
equilibrium. Observa-  
head and time elapsed  
n in Figure 4-3.

ased, open-end bore-  
borehole with double  
ch water flows out of  
constant head is meas-  
and procedures of


ws out of the uncased  
ntaining a constant wa-  
Use equipment and  
ethod E-19.

sture content of soil  
avated hole is deter-  
me of hole by sand  
quipment and proce-  
0-45-302, Appendix

sture content is deter-  
ed from a thin-wall  
pressed into the  
nd procedure of USCE  
dix III.

ncased boreholes.

hole to determine  
ctangular test pits



NATIVE CLAY SPT 8  
EMBANKMENT CLAY SPT 12

FIGURE 4-2  
Correlations of Standard Penetration Resistance

isticated shear tests a  
satisfactorily approxi  
ication (Table 1-3 and  
ction can be obtained  
the laboratory. As for  
l conditions, triaxial

isturbed samples pro  
n as one-half the unce  
n made between uncom  
t (Section 3, Chapter  
y disturbed in sampling  
urther useful when the

se soils are not well fo  
load. A practical,  
cohesion is substantial  
can be treated as a  
shear tests. The actio  
minations. Where the  
rformed under drainage  
rine deposits, the  
ngth and its increase

mployed in determining  
hesionless soils.

t compaction control  
l borrow materials.

ed base course or a  
ss earthwork, when  
isture content that,

t free draining cohesi  
han those provided b  
niversally accepted.

s classified in the





FIGURE 3-7  
Correlations of Strength Characteristics




## **EXHIBIT D – BEDROCK MAPS**

---

Alliant Energy  
Wisconsin Power and Light Company  
Ottumwa Generating Station  
Ottumwa, Iowa

Unstable Area Determination



EXPLANATION

- Log data
- Bedrock penetrated
- Log data
- Bedrock not penetrated
- Published data
- Bedrock penetrated
- Published data
- Bedrock not penetrated
- X
- Quarry or outcrop
- 750
- Bedrock contours
- Show altitude of bedrock surface. Dashed lines represent contours. Contour interval is 50 feet. Datum is mean sea level.

The alluvial deposits range in thickness up to about 60 feet and contain sand and gravel aquifers that will yield from 10 to 40 gpm to individual wells. Because few wells have been completed in the alluvium and information is limited, a program of test drilling is recommended, especially when attempting to develop a large supply of water.

The map will help the drilling contractor when planning the construction of a well. By determining the depth to bedrock, the contractor can estimate casing needs and prepare more accurate cost estimates. And, where overburden is particularly thick, the contractor can be better prepared for any problems attendant to drilling this material.

Other uses for the map are in river basin hydrology studies and in determining surface-water and ground-water relationships at selected locations.

**Environment.**—The bedrock information is particularly valuable to State, regional, and local planners concerned with environmental problems such as the location of landfill sites. The thickness of overburden, which can be determined with the aid of this map, is an important factor to consider for the protection of ground-water supplies from potential contamination.

**Geology.**—The bedrock map shows the location of bedrock highs, which are of interest to quarry operators and to construction engineers concerned with foundation problems. The map also aids in the interpretation of drainage changes caused by glacial advances and in determining the areal distribution of consolidated rocks.

Approximate Site Location

INTRODUCTION

The bedrock in Iowa is covered nearly everywhere by unconsolidated deposits of glacial drift and alluvium, which range in thickness from less than 1 foot to more than 400 feet, and from less than 1 foot to about 60 feet, respectively. The configuration of the bedrock surface is the result of a complex system of ancient drainage courses which were developed during a long period of preglacial erosion and during shorter, but more intense, periods of interglacial erosion.

ACKNOWLEDGMENTS

Particular recognition is made to the present and past members of the Iowa Geological Survey who, over a period of many years, have collected and analyzed drillhole samples, determined land-surface altitudes, and compiled other information necessary to the preparation of this map. Further acknowledgment is made to the many well drilling contractors who have voluntarily collected drill cuttings and have provided other well data.

SELECTED REFERENCES

Arey, M. F., 1909, Geology of Davis County: Iowa Geol. Survey Ann. Rept., v. 20, p. 487-524.

Bain, H. R., 1894, Geology of Keokuk County: Iowa Geol. Survey Ann. Rept., v. 4, p. 255-311.

—, 1894, Geology of Mahaska County: Iowa Geol. Survey Ann. Rept., v. 4, p. 313-380.

—, 1895, Geology of Washington County: Iowa Geol. Survey Ann. Rept., v. 5, p. 113-173.

Beveridge, T. R., 1947, Subdrift valleys of southeastern Iowa: Unpublished M.S. thesis, State Univ. of Iowa.

Cagle, J. W., Bedrock topography of southeastern Iowa: U.S. Geol. Survey Misc. Geol. Inv. Map I-763 (in print).

Coble, R. W., 1971, The water resources of southeastern Iowa: Iowa Geol. Survey, Iowa Geol. Survey Water Atlas no. 4, p. 36.

Gordon, C. H., 1893, Buried river channels in southeastern Iowa: Iowa Geol. Survey Ann. Rept., v. 3, p. 237-245.

—, 1894, Geology of Van Buren County: Iowa Geol. Survey Ann. Rept., v. 4, p. 197-254.

Hansen, R. E., 1972, Bedrock topography of east-central Iowa: U.S. Geol. Survey Misc. Geol. Inv. Map I-717.

Hershey, H. G., 1969, Geologic map of Iowa: Iowa Geol. Survey.

Jones, R. G., and Highland, J. D., 1971, Soil Survey of Keokuk County, Iowa, U.S. Dept. Agriculture, S.C.S., in cooperation with Iowa Agr. Exper. Station.

Kay, G. F., and Apfel, E. T., 1929, The pre-Illinoian Pleistocene geology of Iowa: Iowa Geol. Survey Ann. Rept., v. 34, p. 304 p.

Kay, G. F., and Graham, J. B., 1943, The Illinoian and post-Illinoian Pleistocene geology of Iowa: Iowa Geol. Survey Ann. Rept., v. 38, p. 262 p.

Keyes, C. R., 1893, Geology of Lee County: Iowa Geol. Survey Ann. Rept., v. 3, p. 305-407.

—, 1893, Geology of Des Moines County: Iowa Geol. Survey Ann. Rept., v. 3, p. 409-492.

Leonard, A. G., 1901, Geology of Wapello County: Iowa Geol. Survey Ann. Rept., v. 12, p. 439-499.

Leverett, Frank, 1942, Shifts of the Mississippi River in relation to glaciation: Geol. Soc. America Bull., vol. 53, p. 1283-1298.

Norton, W. H., and others, 1912, Underground water resources of Iowa: U.S. Geol. Survey Water-Supply Paper 293, p. 514-618.

—, 1912, Underground water resources of Iowa: Iowa Geol. Survey Ann. Rept., v. 21, p. 618-748.

Savage, T. E., 1901, Geology of Henry County: Iowa Geol. Survey Ann. Rept., v. 12, p. 237-302.

Udden, J. A., 1900, Geology of Louisa County: Iowa Geol. Survey Ann. Rept., v. 11, p. 55-126.

—, 1901, Geology of Jefferson County: Iowa Geol. Survey Ann. Rept., v. 12, p. 355-437.

USES OF MAP

The bedrock map, when used in conjunction with land-surface altitudes, is a vital tool for studying hydrologic, environmental, and geologic problems.

**Hydrology.**—The map is an aid in locating supplies of ground-water. The areas that are most favorable for the development of ground-water supplies are the buried-bedrock channels and the alluvial valleys of present-day streams. In areas that are underlain by shale the bedrock channels often are the principal source of potable water for private domestic and stock wells and a few small towns. Though not all channels contain sand and gravel aquifers that supply many farm and rural-domestic needs. Recorded yields generally range from 10 to 30 gpm (gallons per minute) but yields as high as 100 gpm have been reported.

Base from U.S. Geological Survey 1:250,000  
Centerville, and Des Moines, 1954;  
Burlington and Davenport, 1958  
Roads as of 1969

SCALE 1:125,000  
0 2 4 6 8 10 MILES  
0 2 4 6 8 10 KILOMETERS

1800  
I  
no 808  
Sheet 1  
C. 2

U.S. GEOLOGICAL SURVEY, WASHINGTON, D.C. 20508  
MAR 25 1974  
LIBRARY  
Jowa (Southeast). Structure. 1:125,000. 4973.  
Sheet 1  
cop. 2

3 1618 00125856 0  
For sale by U.S. Geological Survey, price \$1.00 per set

BEDROCK TOPOGRAPHY OF SOUTHEAST IOWA

By  
Robert E. Hansen  
1973




## **EXHIBIT E – KARST FORMATION MAPS**

---

Alliant Energy  
Wisconsin Power and Light Company  
Ottumwa Generating Station  
Ottumwa, Iowa


Unstable Area Determination

# NE Iowa Karst



Map layers Legend

- AFO Siting Data
  - Sinkholes
  - Ag Drainage Well
  - Wells
  - Animal Feeding Operation
    - Active, Confined/Open
    - Active, Confinement
    - Active, Open Feedlot
    - Inactive
  - Public Drainage Infrastructure
- Drainage Districts
- High Qty Wtr Resource (Rivers)
- High Qty Wtr Resource (Waterbody)
- Major Water Source (Rivers)
- Major Water Source (Lake)
- Surface Water
- Public Land
- Public Land Survey (PLSS)
- Designated Wetland
  - Designated Wetland
  - Wetland Buffer(2500ft)
- Sinkhole or Potential Karst
  - Sinkhole w/ 1000 ft radius
  - Karst and Potential Karst
- 100 Year Flood Plain
- Alluvial Soils




## **EXHIBIT F – OGS GROUNDWATER MAP**

---

Alliant Energy  
Wisconsin Power and Light Company  
Ottumwa Generating Station  
Ottumwa, Iowa

Unstable Area Determination



**LEGEND**

MONITORING WELL  
 GEOLOGIC CROSS SECTION

- NOTES:**
1. 2014 AERIAL PHOTOGRAPH SOURCES: ESRI, DIGITALGLOBE, GEOEYE, I-CUBED, USDA FSA, USGS, AEX, GETMAPPING, AEROGRIID, IGN, IGP, SWISSTOPO, AND THE GIS USER COMMUNITY.
  2. MONITORING WELLS MW-301, MW-302, AND MW-304, WERE INSTALLED BY CASCADE DRILLING, LLP. UNDER THE SUPERVISION OF SCS ENGINEERS FROM NOVEMBER 11-12, 2015.
  3. MONITORING WELLS MW-303 AND MW-305 WERE INSTALLED BY CASCADE DRILLING LLP. UNDER THE SUPERVISION OF SCS ENGINEERS ON DECEMBER 7-8, 2015.
  4. MONITORING WELLS MW-307, MW-308, AND MW-309 WERE INSTALLED BY CASCADE DRILLING, LLP. UNDER THE SUPERVISION OF SCS ENGINEERS FROM OCTOBER 25-27, 2016.
  5. MONITORING WELLS MW-310 AND MW-311 WERE INSTALLED BY ROBERTS ENVIRONMENTAL DRILLING ON AUGUST 27, 2019.
  6. MONITORING WELLS MW-305A, MW-310A, AND MW-311A WERE INSTALLED BY ROBERTS ENVIRONMENTAL DRILLING BETWEEN FEBRUARY 27, 2020 AND MARCH 3, 2020.

**N**


800 0 800

SCALE: 1" = 800'


PROJECT NO. 25220083.00	DRAWN BY: BSS	<b>SCS ENGINEERS</b> 2830 DAIRY DRIVE MADISON, WI 53718-6751 PHONE: (608) 224-2830	CLIENT INTERSTATE POWER AND LIGHT CO. 20775 POWER PLANT ROAD OTTUMWA, IA 52501	SITE ALLIANT ENERGY OTTUMWA GENERATING STATION OTTUMWA, IOWA	SITE PLAN AND MONITORING WELL LOCATIONS	FIGURE
DRAWN: 11/15/2019	CHECKED BY: MDB					2
REVISED: 05/11/2020	APPROVED BY: EJN 9/11/2020					

I:\25220083.00\Drawings\Site Plan and Monitoring Well Locations.dwg, 5/11/2020 7:55:48 AM






- LEGEND
- CCR UNIT
  - OGS ASH POND CCR MONITORING WELL
  - ADDITIONAL CCR MONITORING WELL
  - ⊙ RIVER ELEVATION MEASUREMENT LOCATION
  - 645.91** POTENTIOMETRIC ELEVATION AT WELL (APRIL 13-14, 2020)
  - [645.7]** SURFACE WATER ELEVATION (APRIL 13, 2020)
  - POTENTIOMETRIC SURFACE CONTOUR
  - APPROXIMATE GROUNDWATER FLOW DIRECTION




PROJECT NO. 25220072.00	DRAWN BY: KP/BSS/RJG	<b>SCS ENGINEERS</b> 2830 DAIRY DRIVE MADISON, WI 53718-6751 PHONE: (608) 224-2830	CLIENT INTERSTATE POWER AND LIGHT CO. 20775 POWER PLANT ROAD OTTUMWA, IA 52501	SITE ALLIANT ENERGY OTTUMWA GENERATING STATION OTTUMWA, IOWA	SHALLOW POTENTIOMETRIC SURFACE APRIL 13-14, 2020	FIGURE
DRAWN: 04/28/2020	CHECKED BY: NDK/SCC					5
REVISED: 07/30/2020	APPROVED BY: EJN 9/11/2020					



LEGEND

- TOPSOIL/FILL
- SAND, POORLY GRADED (SP)
- SILT, WITH SAND AND GRAVEL (ML)
- CLAY
- GRAVEL, POORLY GRADED, LITTLE OR NO FINES (GP)
- SANDSTONE
- LIMESTONE
- DEEP POTENTIOMETRIC SURFACE MEASURED APRIL 13-14, 2020
- SHALLOW POTENTIOMETRIC SURFACE MEASURED APRIL 13-14, 2020
- POND SURFACE ELEVATION MEASURED JUNE 10-11, 2019



WELL DETAIL



HORIZONTAL SCALE: 1" = 500'  
 VERTICAL SCALE: 1" = 20'  
 VERTICAL EXAGGERATION = 25X

NOTES:

1. MW-305 AND MW-305A WERE HYDROVACED TO APPROXIMATELY 8.5'. MW-310 AND MW-310A WERE HYDROVACED TO APPROXIMATELY 8.0'. HYDROVACING IS PERFORMED TO DETERMINE IF UNDERGROUND UTILITIES ARE PRESENT. HIGH PRESSURE WATER AND A VACUUM ARE USED TO CLEAR THE BOREHOLE AND GEOLOGIC SAMPLES ARE NOT COLLECTED. NATIVE SOIL IN THE VICINITY OF MW-307 IS CLAY.
2. ASH POND BOTTOM ELEVATION IS BASED ON THE EMBANKMENT CREST ELEVATION (681 FEET) AND INTERNAL STORAGE DEPTH (25 FEET) REPORTED IN THE HISTORY OF CONSTRUCTION REPORT ISSUED SEPTEMBER 29, 2016, BY HARD HAT SERVICES.

PROJECT NO. 25220083.00	DRAWN BY: BSS/KP	ENGINEER	 2830 DAIRY DRIVE MADISON, WI 53718-6751 PHONE: (608) 224-2830	CLIENT	INTERSTATE POWER AND LIGHT CO. 15300 130th STREET OTTUMWA, IA 52501	SITE	OTTUMWA GENERATING STATION 20775 POWER PLANT ROAD OTTUMWA, IOWA	GEOLOGIC CROSS SECTION A-A' FIGURE 4
DRAWN: 07/03/2019	CHECKED BY: NDK/MDB							
REVISED: 05/13/2020	APPROVED BY: EJN 9/11/2020							

**Table 1. Water Level Summary**  
**IPL - Ottumwa Generating Station / SCS Engineers Project #25220083.00**

Depth to Water in feet below top of well casing/reference elevation															
Raw Data	MW-301	MW-302	MW-303	MW-304	MW-305	MW-305A	MW-306	MW-307	MW-308	MW-309	MW-310	MW-310A	MW-311	MW-311A	River at Intake
<b>Measurement Date</b>															
April 26, 2016	3.83	18.27	8.65	27.47	22.24	NI	12.61				NI	NI	NI	NI	NI
June 23, 2016	4.05	18.25	8.18	26.31	21.55	NI	12.83				NI	NI	NI	NI	NI
August 9, 2016	4.36	18.38	9.31	29.05	23.13	NI	13.12				NI	NI	NI	NI	NI
October 26-27, 2016	4.59	18.23	8.90	27.81	22.54	NI	13.26				NI	NI	NI	NI	NI
January 18-19, 2017	4.96	18.44	9.33	28.34	23.04	NI	13.58	8.75	7.97	8.28	NI	NI	NI	NI	NI
April 19-20, 2017	4.48	17.55	6.50	25.36	20.64	NI	12.78	3.94	4.30	4.78	NI	NI	NI	NI	NI
June 20-21, 2017	4.72	18.25	8.65	28.09	22.65	NI	13.53	7.71	7.13	7.34	NI	NI	NI	NI	NI
August 21-23, 2017	5.35	18.77	10.49	30.45	24.91	NI	14.70	11.78	12.27	13.12	NI	NI	NI	NI	NI
November 8, 2017	5.09	18.50	9.73	29.81	24.15	NI	14.43	10.19	10.40	10.74	NI	NI	NI	NI	NI
April 18, 2018	5.10	18.19	8.60	27.29	22.92	NI	14.55	7.90	7.48	7.29	NI	NI	NI	NI	NI
May 30, 2018	NM	NM	NM	NM	NM	NI	NM	5.11	4.34	3.96	NI	NI	NI	NI	NI
June 28, 2018	NM	NM	NM	NM	NM	NI	NM	4.69	3.96	3.47	NI	NI	NI	NI	NI
July 18, 2018	NM	NM	NM	NM	NM	NI	NM	5.29	4.72	4.25	NI	NI	NI	NI	NI
August 14-15, 2018	5.72	17.85	8.50	26.49	22.35	NI	14.81	NM	NM	NM	NI	NI	NI	NI	NI
August 29, 2018	5.54	18.01	6.00	25.02	NM	NI	NM	NM	NM	NM	NI	NI	NI	NI	NI
October 16, 2018	4.13	16.99	4.90	24.64	20.54	NI	13.23	3.43	NM	3.33	NI	NI	NI	NI	NI
January 8, 2019	4.41	17.87	6.42	26.56	21.78	NI	13.63	NM	NM	NM	NI	NI	NI	NI	NI
April 8, 2019	3.94	16.67	5.52	23.51	19.90	NI	12.51	2.66	1.69	1.39	NI	NI	NI	NI	NI
August 28, 2019	NM	NM	NM	NM	NM	NI	NM	NM	NM	NM	17.65	NI	12.08	NI	NI
October 23-24, 2019	3.56	13.76	7.21	25.13	20.70	NI	12.19	5.67	4.08	3.66	9.32	NI	6.38	NI	NI
December 11, 2019	NM	NM	NM	NM	NM	NI	NM	7.97	8.00	7.70	NM	NI	NM	NI	NI
February 5, 2020	3.33	NM	NM	NM	NM	NI	NM	7.68	5.27	6.60	13.92	NI	9.18	NI	NI
March 12-13, 2020	3.81	NM	NM	NM	22.50	32.39	NM	NM	NM	NM	13.18	40.09	10.00	29.43	NI
April 1, 2020	3.36	16.9	5.18	24.27	23.32	28.98	12.34	3.8	3.51	3.71	7.54	8.77	4.83	5.27	6.6
April 13-14, 2020	3.38	17.45	6.99	26.42	21.47	30.34	12.76	6.90	5.30	5.75	12.72	10.43	7.39	5.12	10.6
June 30, 2020	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	5.81	NM

Ground Water or Surface Water Elevation in feet above mean sea level (amsl)															
Well Number	MW-301	MW-302	MW-303	MW-304	MW-305	MW-305A	MW-306	MW-307	MW-308	MW-309	MW-310	MW-310A	MW-311	MW-311A	River at Intake
<b>Top of Well Casing Elevation / Surface Water Reference Elevation (feet amsl)</b>	686.63	673.90	661.07	682.84	683.91	684.03	683.47	657.56	655.39	654.94	658.63	657.93	654.18	653.54	656.31
<b>Screen Length (ft)</b>	10.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	5.00	NA
<b>Total Depth (ft from top of casing)</b>	17.0	25.8	17.5	52.3	51.5	81.91	36.6	28.0	25.0	27.5	55.55	17.9	47.68	NA	
<b>Top of Well Screen Elevation (ft)</b>	679.63	653.10	648.57	635.54	637.41	607.12	651.87	634.56	635.39	632.44	637.76	607.38	641.24	610.86	NA
<b>Measurement Date</b>															
April 26, 2016	682.80	655.63	652.42	655.37	661.67	NI	670.86				NI	NI	NI	NI	NI
June 23, 2016	682.58	655.65	652.89	656.53	662.36	NI	670.64				NI	NI	NI	NI	NI
August 9, 2016	682.27	655.52	651.76	653.79	660.78	NI	670.35				NI	NI	NI	NI	NI
October 26-27, 2016	682.04	655.67	652.17	655.03	661.37	NI	670.21				NI	NI	NI	NI	NI
January 18-19, 2017	681.67	655.46	651.74	654.50	660.87	NI	669.89	648.81	647.42	646.66	NI	NI	NI	NI	NI
April 19-20, 2017	682.15	656.35	654.57	657.48	663.27	NI	670.69	653.62	651.09	650.16	NI	NI	NI	NI	NI
June 20-21, 2017	681.91	655.65	652.42	654.75	661.26	NI	669.94	649.85	648.26	647.60	NI	NI	NI	NI	NI
August 21-23, 2017	681.28	655.13	650.58	652.39	659.00	NI	668.77	645.78	643.12	641.82	NI	NI	NI	NI	NI
November 8, 2017	681.54	655.40	651.34	653.03	659.76	NI	669.04	647.37	644.99	644.20	NI	NI	NI	NI	NI
April 18, 2018	681.53	655.71	652.47	655.55	660.99	NI	668.92	649.66	647.91	647.65	NI	NI	NI	NI	NI
May 30, 2018	NM	NM	NM	NM	NM	NI	NM	652.45	651.05	650.98	NI	NI	NI	NI	NI
June 28, 2018	NM	NM	NM	NM	NM	NI	NM	652.87	651.43	651.47	NI	NI	NI	NI	NI
July 18, 2018	NM	NM	NM	NM	NM	NI	NM	652.27	650.67	650.69	NI	NI	NI	NI	NI
August 14-15, 2018	680.91	656.05	652.57	656.35	661.56	NI	668.66	NM	NM	NM	NI	NI	NI	NI	NI
August 29, 2018	681.09	655.89	655.07	657.82	NM	NI	NM	NM	NM	NM	NI	NI	NI	NI	NI
October 16, 2018	682.50	656.91	656.17	658.20	663.37	NI	670.24	654.13	NM	651.61	NI	NI	NI	NI	NI
January 8, 2019	682.22	656.03	654.65	656.28	662.13	NI	669.84	NM	NM	NM	NI	NI	NI	NI	NI
April 8, 2019	682.69	657.23	655.55	659.33	664.01	NI	670.96	654.90	653.70	653.55	NI	NI	NI	NI	NI
August 28, 2019	NM	NM	NM	NM	NM	NI	NM	NM	NM	NM	640.98	NI	642.10	NI	NI
October 23-24, 2019	683.07	660.14	653.86	657.71	663.21	NI	671.28	651.89	651.31	651.28	649.31	NI	647.80	NI	NI
December 11, 2019	NM	NM	NM	NM	NM	NI	NM	649.59	647.39	647.24	NM	NI	NM	NI	NI
February 5, 2020	683.30	NM	NM	NM	NM	NI	NM	649.88	650.12	648.34	644.71	NI	645.00	NI	NI
March 12-13, 2020	682.82	NM	NM	NM	661.41	651.64	NM	NM	NM	NM	645.45	617.84	644.18	624.11	NI
April 1, 2020	683.27	657.00	655.89	658.57	660.59	655.05	671.13	653.76	651.88	651.23	651.09	649.16	649.35	648.27	649.71
April 13-14, 2020	683.25	656.45	654.08	656.42	662.44	653.69	670.71	650.66	650.09	649.19	645.91	647.50	646.79	648.42	645.71
June 30, 2020	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	647.73	NM
<b>Bottom of Well Elevation (ft)</b>	669.63	648.10	643.57	630.54	632.41	602.12	646.87	629.56	630.39	627.44	632.76	602.38	636.24	605.86	--

Notes: Created by: KAK Date: 5/1/2017  
 NM = not measured Last rev. by: NDK Date: 7/22/2020  
 NI = not installed Checked by: AJR Date: 7/22/2020  
 Proj Mgr QA/QC: EJJ Date: 9/11/2020

I:\25220083.00\Data and Calculations\Tables\wstat\_OGS.xls\levels

**Table 4. Vertical Hydraulic Gradients at Well Clusters  
Ottumwa Generating Station / SCS Engineers Project #25220083.00**

Well Pair		Vertical Hydraulic Gradient (feet/foot) <sup>(1,2)</sup>	
Shallower Well	Deeper Well	April 1, 2020	April 13-14, 2020
MW-305	MW-305A	-0.183	-0.289
MW-310	MW-310A	-0.064	0.052
MW-311	MW-311A	-0.036	0.054

Notes:

(1) A negative value indicates a downward gradient; a positive value indicates an upward gradient.

Created by:     MDB      
 Last rev. by:     MDB      
 Checked by:     LMH      
 Proj Mgr QA/QC:     TK    

Date:     5/14/2020      
 Date:     5/14/2020      
 Date:     5/14/2020      
 Date:     5/15/2020    

I:\25220083.00\Data and Calculations\Tables\[4\_Vertical Gradients\_OGS.xls]Gradients