



Alliant Energy  
4902 North Biltmore Lane  
P.O. Box 77007  
Madison, WI 53707-1007

1-800-ALLIANT (800-255-4268)  
alliantenergy.com

February 13, 2019

To: CCR Operating Record

Re: Notification of Groundwater Protection Standard Exceedance pursuant to 40 CFR 257.95

Two constituents in Appendix IV to part 40 CFR 257 were detected at a statistically significant level above the groundwater protection standard (GPS) established under 40 CFR 257.95(h) in monitoring wells located at the Prairie Creek Generating Station. The constituents exceeding the GPS are arsenic (monitoring wells MW-303, MW-304, MW-305) and molybdenum (MW-306). This notification has been prepared in accordance with 40 CFR 257.95(g) and 257.105(h)(8).

The CCR units at this facility have been closed in accordance with 40 CFR 102(d). This notification applies to the Closure Area.

Signed,

A handwritten signature in blue ink, appearing to read "Jeff Maxted", written over a white background.

Print Name Jeff Maxted	Title Lead Environmental Specialist
Phone No. or Email Address (608) 458-3853; jeffreymaxted@alliantenergy.com	