



Alliant Energy  
4902 North Biltmore Lane  
P.O. Box 77007  
Madison, WI 53707-1007

1-800-ALLIANT (800-255-4268)  
alliantenergy.com

March 14, 2025

To: CCR Operating Record  
Re: Notification of Groundwater Protection Standard Exceedance pursuant to 40 CFR 257.95

A constituent in Appendix IV to part 40 CFR 257 was detected at a statistically significant level above the groundwater protection standard (GPS) established under 40 CFR 257.95(h) in a monitoring well located at the Prairie Creek Generating Station. The constituent exceeding the GPS is lithium (monitoring well MW-308). Arsenic and molybdenum have previously been detected at statistically significant levels at site monitoring wells. The assessment of corrective measures will be updated to address all statistically significant levels above the GPS at the site. This notification has been prepared in accordance with 40 CFR 257.95(g) and 257.105(h)(8).

The CCR units at this facility have been closed in accordance with 40 CFR 257.102(d). This notification applies to the Closure Area.

Signed,

Print Name Matt Bizjack	Title Senior Environmental Specialist
Phone No. or Email Address (608) 458-3197; matthewbizjack@alliantenergy.com	