



Alliant Energy
4902 North Biltmore Lane
P.O. Box 77007
Madison, WI 53707-1007

1-800-ALLIANT (800-255-4268)
alliantenergy.com

November 17, 2021

To: CCR Operating Record
Re: Notification of Groundwater Protection Standard Exceedance pursuant to 40 CFR 257.95

A constituent in Appendix IV to part 40 CFR 257 was detected at a statistically significant level above the groundwater protection standard (GPS) established under 40 CFR 257.95(h) in a monitoring well located at the Sutherland Generating Station. The constituent exceeding the GPS is lithium, as sampled in monitoring well MW-306. This notification has been prepared in accordance with 40 CFR 257.95(g) and 257.105(h)(8).

This notification is provided for the Closure Area at this facility, which was formerly comprised of the following CCR units:

CCR Surface Impoundments (closed)

- SGS North Primary Pond
- SGS South Primary Pond
- SGS Main Pond
- SGS Polishing Pond

Signed,

Print Name Jeff Maxted	Title Manager – Environmental Services
Phone No. or Email Address (608) 458-3853; jeffreymaxted@alliantenergy.com	